

I/34480/2024



**भारत सरकार**  
**Government of India**  
**विद्युत मंत्रालय**  
**Ministry of Power**  
**केंद्रीय विद्युत प्राधिकरण**  
**Central Electricity Authority**  
**विद्युत प्रणाली योजना एवं मूल्यांकन प्रभाग- II**  
**Power System Planning & Appraisal Division-II**

सेवा में/To

As per list of Addresses

**विषय : ट्रांसमिशन पर राष्ट्रीय समिति (एनसीटी) की अठारहवीं बैठक के कार्यवृत्त का शुद्धिपत्र - के सम्बन्ध में ।**


**Subject: Corrigendum to the Minutes of the 18<sup>th</sup> Meeting of National Committee on Transmission (NCT) –regarding.**

महोदया (Madam) / महोदय (Sir),

Minutes of the 18<sup>th</sup> meeting of the "National Committee on Transmission" (NCT) held on 05<sup>th</sup> March, 2024 were issued vide CEA letter No. I/34370/2024 dated 11<sup>th</sup> March, 2024.

A corrigendum (Corrigendum-I) to the minutes is enclosed.

भवदीय/Yours faithfully,

  
 (राकेश गोयल / Rakesh Goyal)  
 मुख्य अभियंता/Chief Engineer

**प्रतिलिपि / Copy to:**

Joint Secretary (Trans), Ministry of Power, New Delhi

I/34480/2024

**List of Addressees:**

1.	Chairperson, Central Electricity Authority Sewa Bhawan, R.K. Puram, New Delhi – 110 066.	2.	Member (Power Systems), Central Electricity Authority Sewa Bhawan, R.K. Puram, New Delhi – 110 066.
3.	Member (Economic & Commercial), Central Electricity Authority Sewa Bhawan, R.K. Puram, New Delhi – 110 066.	4.	Director (Trans), Ministry of Power Shram Shakti Bhawan, New Delhi-110001.
5.	Sh. Lalit Bohra, Joint Secretary Room no 602, Atal Akshay Urja Bhawan Opposite CGO Complex gate No. 2, Lodhi Road, New Delhi – 110003	6.	Chief Operating Officer, CTUIL, Saudamini, Plot No. 2, Sector-29, Gurgaon – 122 001.
7.	Sh. Rajnath Ram, Adviser (Energy), NITI Aayog, Parliament Street, New Delhi – 110 001.	8.	CMD, Grid Controller of India, B-9, Qutub, Institutional Area, Katwaria Sarai, New Delhi – 110016
9.	Sh. Ravinder Gupta Ex. Chief Engineer CEA		

**Special Invitee**

Chief Engineer (PCD), CEA

**Corrigendum to the minutes of the 18<sup>th</sup> meeting of NCT****Issued on: 14.03.2024**

The minutes of the 18<sup>th</sup> meeting of NCT held on 05.03.2024 were issued vide CEA letter No. I/34370/2024 dated 11<sup>th</sup> March, 2024. Based on the comments received, the minutes stands amended as given below:

**1. Para 4.1.5 A:**

Sl. No. 3 of the table of para 4.1.5 A is modified as below:

3.	LILO of both ckts of Bikaner II PS- Bikaner III PS (Quad) direct 400 kV line at Bikaner-IV PS	Length -20 km (Quad) (LILO length)
----	---	------------------------------------

**Broad Scope iii of Sl. No. 1 of table under IV** of Summary of the deliberations of the 18<sup>th</sup> meeting of NCT held on 5<sup>th</sup> March, 2024 is modified as below:

LILO of both ckts of Bikaner II PS- Bikaner III PS (Quad) direct 400 kV line at Bikaner-IV PS.

**2. Para 4.6.6:**

Sl. No. 1 of the table of para 4.6.6 is modified as below:

1.	<p>Augmentation of transformation capacity at Jam Khambhaliya PS (GIS)</p> <p>Tentative implementation timeframe :</p> <ul style="list-style-type: none"> <li>• For scope at Sl. No. 1: 18 months</li> <li>• For scope at Sl. No. 3 &amp; 6: Matching with SCOD of 400kV bays at Jam Khambhaliya PS( being implemented under “Network Expansion scheme in Gujarat for drawl of about 3.6 GW load under Phase-I in Jamnagar area” scheme which is currently under tendering) and subject to minimum implementation schedule of 21 months.</li> <li>• For scope at Sl. No. 4: 30.03.2026 and 30.06.2027 respectively (subject to minimum schedule of 21 months from date of award of balance works).</li> <li>• For balance scope: 21 months</li> </ul>	310	Recommended under TBCB route with PFCCCL as the BPC.
----	---	-----	--

I/34480/2024

**3. Para 4.6.7:**

Sl. No. 5 of the table of para 4.6.7 is modified as below:

5.	Creation of New 220 kV Bus Section at Jam Khambhaliya PS (Section III)  (with space for 4 nos. 220 kV line bays: in same GIS hall. Implementation of 2 Nos. GIS bays to be taken up as per Sl.No.8 and space to be kept for future 2 Nos.)	220 kV Bus sectionaliser bay - 1 Set <i>(to be kept normally OPEN and may be closed based on system requirement)</i>  220 kV BC – 1 No.
----	--	---

**4. Para 4.7.6:**

BPC for the transmission scheme “Transmission scheme for integration of Tumkur-II REZ in Karnataka” to be read as RECPDCL.

**Table under III (b)** of Summary of the deliberations of the 18<sup>th</sup> meeting of NCT held on 5<sup>th</sup> March, 2024 is modified as below:

Sl. No.	Name of Transmission Scheme	Implementation Mode	Implementation timeframe	BPC	Estimated Cost (Rs. Crs)
1.	Augmentation of transformation capacity at Jam Khambhaliya PS (GIS)	TBCB	Tentative implementation timeframe : <ul style="list-style-type: none"> <li>• For scope at Sl. No. 1: 18 months</li> <li>• For scope at Sl. No. 3 &amp; 6: Matching with SCOD of 400kV bays at Jam Khambhaliya PS( being implemented under “Network Expansion scheme in Gujarat for drawl of about 3.6 GW load under Phase-I in Jamnagar area” scheme which is</li> </ul>	PFCCL	310

I/34480/2024

			<p>currently under tendering) and subject to minimum implementation schedule of 21 months.</p> <ul style="list-style-type: none"> <li>• For scope at Sl. No. 4: 30.03.2026 and 30.06.2027 respectively (subject to minimum schedule of 21 months from date of award of balance works).</li> <li>• For balance scope: 21 months</li> </ul>		
2.	Transmission scheme for integration of Tumkur-II REZ in Karnataka	TBCB	24 months	RECPDCL	465

\*\*\*