

भारत सरकार  
केंद्रीय विद्युत प्राधिकरण  
(विद्युत मंत्रालय)  
सेवा भवन (उत्तरी खंड) कक्ष सं. 622, छठा तल,  
आर.के.पुरम, नई दिल्ली-110066  
दूरभाष – 011-26732632,  
वेबसाइट – [www.cea.nic.in](http://www.cea.nic.in)

### सार्वजनिक नोटिस

विद्युत अधिनियम, 2003 की धारा 177 के अनुसार, केंद्रीय विद्युत प्राधिकरण (के.वि.प्रा.), मसौदा केंद्रीय विद्युत प्राधिकरण (ग्रेट इंडियन बस्टर्ड क्षेत्र में विद्युत लाइनों का निर्माण) विनियम, 2023 को अधिसूचित करने का प्रस्ताव करता है। प्रस्तावित मसौदा विनियम सार्वजनिक टिप्पणियों को आमंत्रित करने के लिए के.वि.प्रा. की वेबसाइट [www.cea.nic.in](http://www.cea.nic.in) पर उपलब्ध है। इन मसौदा विनियमों का निरीक्षण मुख्य अभियंता (पी.एस.ई.टी.डी.) के कार्यालय, सेवा भवन (नॉर्थ विंग), कमरा नंबर 335, तीसरी मंजिल, आर.के. पुरम , नई दिल्ली -110066 में किसी भी कार्य दिवस पर **03.03.2023** तक 1100 बजे से 1600 बजे के बीच भी किया जा सकता है।

2. मसौदा विनियमों पर अपनी टिप्पणी, अधिमानतः संलग्न प्रारूप में सेवा भवन (नॉर्थ विंग), कमरा नंबर 335, तीसरी मंजिल, आरके पुरम , नई दिल्ली -110066 को डाक द्वारा या ई-मेल ([ce-psetd@gov.in](mailto:ce-psetd@gov.in)) के माध्यम से शीघ्रातिशीघ्र **03.03.2023** तक भेजें।

**GOVERNMENT OF INDIA  
CENTRAL ELECTRICITY AUTHORITY  
(MINISTRY OF POWER)  
Sewa Bhawan (North Wing), Room No. 622, 6<sup>th</sup> Floor,  
R. K. Puram, New Delhi-110066  
Tel. -011-26732632,  
Website: [www.cea.nic.in](http://www.cea.nic.in)**

**PUBLIC NOTICE**

In accordance with the Section 177 of the Electricity Act, 2003, the Central Electricity Authority (CEA), proposes to notify the **Draft Central Electricity Authority (Construction of Electric Lines in Great Indian Bustard Area) Regulations, 2023**. The proposed draft regulations are available on the CEA Website [www.cea.nic.in](http://www.cea.nic.in) for inviting public comments. The Regulations can also be inspected in the office of Chief Engineer (P.S.E.T.D.), Sewa Bhawan (North Wing), Room No. 335, 3<sup>rd</sup> Floor, R. K. Puram, New Delhi-110066 on any working day till **03.03.2023 between 1100 hrs to 1600 hrs**.

2. All the Stakeholders including the public are requested to send their comments, preferably in the enclosed Format, on the draft regulations to Chief Engineer (P.S.E.T.D.), Sewa Bhawan (North Wing), Room No. 335, 3<sup>rd</sup> Floor, R. K. Puram, New Delhi-110066 by post or through e-mail (**[ce-psetd@gov.in](mailto:ce-psetd@gov.in)**) latest by **03.03.2023**.

[To be published in the Gazette of India, Extraordinary, in Part III, Section 4]

**Government of India**  
**Ministry of Power**  
**Central Electricity Authority**  
New Delhi, , 2023

**CEA-PS-14-77/2/2022-PSETD Division.**- In exercise of the powers conferred by clause (e) of sub-section (2) of section 177 of the Electricity Act, 2003 read with clause (b) of section 73 of the said Act, the Central Electricity Authority hereby makes the following regulations, namely: -

- 1. Short Title and Commencement-** (1) These regulations may be called the Central Electricity Authority (Construction of Electric Lines in Great Indian Bustard Area) Regulations, 2023.  
(2) They shall come into force on the date of their publication in the Official Gazette.
- 2. Definitions-** (1) In these regulations, unless the context otherwise requires,
  - (a) “Great Indian Bustard Area” means Great Indian Bustard habitat in priority and potential areas as identified by Wildlife Institute of India, an Autonomous Institution of the Ministry of Environment, Forest and Climate Change, Government of India.
  - (b) “Underground cable” means a length of insulated single conductor or of two or more such conductors each provided with its own insulation, which are laid up together in an external insulation and which are laid underground.  
(2) Words and expressions used but not defined above shall have the same meaning respectively assigned to them in the Act.
- 3. Applicability.** - These regulations shall apply to generating companies, transmission licensees, distribution licensees, Central Transmission Utility, State Transmission Utilities who plans or owns or operates or maintains electric lines in Great Indian Bustard Area.
- 4. Laying of electric lines through GIB area-** (1) Electric lines of 33 kV and below voltage level passing through Great Indian Bustard area shall be underground cable.  
  
(2) Electric lines of above 33 kV voltage level passing through Great Indian Bustard area shall be overhead lines installed with bird flight diverters.
- 5. Placement of bird flight diverter:** (1) In respect of overhead lines with single conductor per phase passing through Great Indian Bustard area, bird flight diverters shall be placed on each Phase conductor, Earthwire and Optical Ground Wire.

(2) In respect of overhead lines with bundled conductors having two or more conductors per phase passing through Great Indian Bustard Area, bird flight diverters shall be placed on each Earthwire and Optical Ground Wire.

(3) Bird flight diverters shall be placed at an interval of 10 m in the central 80% span of the overhead line.

6. **Technical specifications for bird flight diverter:** Technical specifications for bird flight diverter as issued by CEA through separate order shall be followed.
7. **Power to Relax-** The Authority may, by order and for reasons to be recorded in writing, relax any of provisions of these regulations in respect of the matters referred to the Authority on case to case basis.

(Rakesh Goyal)  
Secretary,  
Central Electricity Authority

Format for submitting Public Comments on the Draft Central Electricity Authority (Construction of Electric Lines in Great Indian Bustard Area) Regulations, 2023.

Sr. No.	Regulation/Clause no of the Draft Regulations	Comments on the Draft Regulation/Proposed Draft	Justification for the Comments
1			
2			
.			
.			