

भारत सरकार
Govt. of India
विद्युत मन्त्रालय, केन्द्रीय विद्युत प्राधिकरण
Ministry of Power, Central Electricity Authority
क्षेत्रीय निरीक्षण संगठन

REGIONAL INSPECTORIAL ORGANISATION

14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033

14 Golf Club Road, Tollygunj, Kolkata-700033

No.RIO/ER/CIPET/250KVA TRF/ 617

Date: 09.10.2017

Director & Head,
CIPET, Dept. of Chemicals & Fertilizers,
PO: Debhog, Haldia
Dist: Purba Medinipur
West Bengal - 721 657

Subject: Acceptance of FORM-III as self certification for energization of Electrical installations of 2 nos. of 250KVA Dry type Transformers and associated equipment at CIPET, Haldia under Regulation-43 of Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulation, 2010.

Ref: Your letter no. CIPET/HALDIA/Elec./2017-18/2335 dated 06.10.2017

With reference to the above mentioned subject, it is to intimate that a duly filled up FORM-III as self certification for energization of Electrical installations of 2 nos. of 250KVA Dry type Transformers and associated equipment at CIPET, Haldia has been received at this office vide your letter under reference above.

The self certification, as submitted in FORM-III, is accepted at this end for energization of Electrical installations of 2 nos. of 250KVA Dry type Transformers and associated equipment at CIPET, Haldia under Regulation-43 of CEA (Measures Relating to Safety and Electric Supply) Regulation, 2010, subject to strict compliance with all the relevant provisions of the said regulations.

The designated Electric safety officer shall routinely carry out periodic inspection of the said installations and submit the self certified reports for acceptance at this end.


(S. KEJRIWAL)

Deputy Director &

Electrical Inspector to the Govt. of India

**Copy to: The Chief Engineer (EI) CEA, 3rd Floor, NRPC, 18A, SJS Marg, Katwaria Sarai,
New Delhi-110016**

Received
R. S. Singh
09/10/2017