



Government of India
Central Electricity Authority
Regional Inspectorial Organisation
Block IV, Floor III, Shastri Bhawan, Chennai – 600 006



No.140/1/2016-RIO/ *amb*

Dated 31.10.2017.

To, *Balamurali B*
Head, CMD - Electrical,
Vikram Sarabai Space Centre,
Department of Space,
Thumba,
Thiruvananthapuram - 6950022.

O/c

Sub Self - Certification report submitted by M/s Vikram Sarabai Space Centre under regulation 32 for 500KVA DG Set and AMF Panel installed at MVIT building at TERLS, VSSC,ISRO, Thiruvananthapuram - Reg.

Ref: VSSC/CMD/ELE/TERLS(C)/95A/2017/179 dated 13.10.2017(Received 23.10.2017).

Vide letter under reference, M/s Vikram Sarabai Space Centre has submitted Self - Certification report under regulation 32 for 500KVA DG Set and AMF Panel installed at MVIT building at TERLS, VSSC,ISRO, Thiruvananthapuram and requested for acceptance of the same by this office.

It is hereby said that Self - Certification report submitted by M/s Vikram Sarabai Space Centre under regulation 32 for 500KVA DG Set and AMF Panel installed at MVIT building at TERLS, VSSC,ISRO, Thiruvananthapuram is found to be generally in order. Hence the Self - Certification report submitted by M/s Vikram Sarabai Space Centre under regulation 32 for 500KVA DG Set and AMF Panel installed at MVIT building at TERLS, VSSC,ISRO, Thiruvananthapuram is hereby accepted and can be energized. The acceptance of Self - Certification report submitted by M/s Vikram Sarabai Space Centre under regulation 32 for 500KVA DG Set and AMF Panel is subject to full compliance of relevant provisions of CEA (Measures relating to Safety and Electric supply) Regulations,2010 (as amended to date) in every respect.

M. L. Jh.
31/10/17

Maryk
(Mary Francis)
Deputy Director

For CEI to Govt. of India
उप निदेशक / Deputy Director
क्षेत्रीय निरीक्षण संगठन
Regional Inspectorial Organisation
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
चेन्नई / Chennai - 600 006.