

भारत सरकार
Govt. of India
विद्युत मन्त्रालय, केन्द्रीय विद्युत प्राधिकरण
Ministry of Power, Central Electricity Authority

Tel No.: 033-24235107

Tel/FAX No.: 24235108

क्षेत्रीय निरीक्षण संगठन

REGIONAL INSPECTORIAL ORGANISATION

14, गोल्फ क्लब रोड, टालीगंज, कोलकाता-700033
14 Golf Club Road, Tollygunj, Kolkata-700033

No. RIO/ER/IOCL/ 590

Dated: 26.09.2017

Harsh Ranjan Choudhary
Indian Oil Corporation, Raxaul depot
Raxaul, Bihar- 846 305
Ph: 7008822571


Subject: Acceptance of FORM-III for self certification for readiness of Electrical Installation at Raxaul Depot.

Reference:

- Your letter NO: 221 dated 25.09.2017

With reference to the above, this is to intimate that FORM-III has been received by RIO(E), Kolkata. While scrutinizing the same it was found that in Regulation-14 you mentioned cut-outs provided by the supplier at the consumer's premises are not within enclosed fire proof receptacle. Regulation-14 shall be duly complied with and it shall be ensured that the cut outs provided are within fireproof receptacle.

However, FORM-III, as submitted, is accepted at this end subject to compliance of above observation and other relevant provisions of CEA (Safety and Electric Supply) Regulations, 2010.


(S. Kejriwal)
Dy. Director
RIO(E), Kolkata-33