



Government of India  
Central Electricity Authority  
Regional Inspectorial Organisation  
Ground Floor, WRPC Building, F-3, MIDC Area  
Marol, Andheri (East), Mumbai 400 093



ISO: 9001:2008

Telefax:022-28211003

riowestcea@gmail.com

No. WRIO/ GAIL/Hazira/SC/2017/544-45

Dated: 01/11/2017

### Acceptance of Self-Certification

[Under Regulation 43 of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date)]

#### Electrical Installation: -

<b>System :</b> 30 kWp Solar PV Grid connected Roof-top power plant
<b>Electrical Apparatus:</b> a) Solar PV Module [Make: APS Solar: 250 Wp, Qty: 120 no.] b) Inverter [Make: Nil, Rating: 1x30 KW] c) AC Distribution Board, AC & DC Cables & Metering Panel
<b>Location:-</b> GAIL(INDIA) LIMITED, COMPRESSOR STATION, ICHCHAPUR, MAGDALLA ROAD, HAZIRA,P.O. ONGC NAGAR, SURAT394518.
<b>Ref:</b> 1. Your online application No. A/2016/01307 Dated 23.09.2016 2. Your letter No: Nill Dated 30.09.2016

With reference to the above, M/s GAIL, Hazira has submitted Self-Certification Report in Form-III of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended). The general condition of the installations submitted by M/s GAIL, Hazira in FORM III of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date) has been examined and it is found to be in order.

Therefore, the Self - Certification Report submitted by M/s GAIL, Hazira is hereby accepted for energisation of the electrical apparatus as per details given above under regulation 43 of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date).

The consistent compliance of relevant provisions of CEA (Measures relating to Safety and Electric Supply) Regulations, 2010 (as amended till date) shall be ensured for safety in operation and maintenance of the above electrical installation

(Sachin K. Bhise)  
Deputy Director  
For Chief Electrical Inspector  
to the Govt. of India

To: GAIL(INDIA) LIMITED, COMPRESSOR STATION, ICHCHAPUR, MAGDALLA ROAD, HAZIRA,P.O. ONGC NAGAR, SURAT394518.

Copy: Chief Engineer (EI), CEA, 3<sup>rd</sup> Floor, NRPC Building, Katwaria Sarai, New Delhi.