



Government of India
Central Electricity Authority
Regional Inspectorial Organisation
Block IV, Floor III, Shastri Bhawan, Chennai – 600 006



No.140/1/2016-RIO/ 1208

Dated 15.12.2017.

To,
Jakson Sebastian,
Head, CMD - Electrical,
Vikram Sarabai Space Centre,
Department of Space,
Vattiyookavu,
Thiruvananthapuram - 695013.

Sub: Acceptance of Self - certification report submitted by M/s Vikram Sarabai Space Centre under regulation 43 for 11kV Load break switches and new metering system installed in place of existing 8 pole structure at CMSE/IISU,VSSC - Reg.

Ref: F.No. CMD/VKC/191/2017/1031 dated 30.11.2017.

Vide letter under reference M/s Vikram Sarabai Space Centre under regulation 43 for 11kV Load break switches and new metering system installed in place of existing 8 pole structure at CMSE/IISU,VSSC and requested for acceptance of the same by this office. The list of equipment are as given below:

SNo.	Name of the Equipment	Qty
1.	11kV CCC type RMU with 3 load break switches	2sets
2.	Metering Panel	2sets
3.	11kV, 800A, 500MVA VCB Panel extension	
3.	3CX300 Sq.mm 11kV grade, XLPE Al conductor cable connecting between RMUs , Metering panel and feeder -1&2	225mts
4.	3CX240 Sq.mm 11kV grade, XLPE Al conductor cable connecting between Aux feeder 1& 2 and RMUs	70mt

It is hereby said that Self - Certification report submitted by M/s Vikram Sarabai Space Centre under regulation 43 for the above mentioned HT&MV installations which are erected installed in place of existing 8 pole structure at CMSE/IISU,VSSC is found to be generally in order. Hence the Self - Certification report submitted by M/s Vikram Sarabai Space Centre under regulation 43 for the aforesaid

electrical installations installed in place of existing 8 pole structure at CMSE/IISU,VSSC is hereby accepted and can be energizised. The acceptance of Self - Certification report of aforesaid electrical installations is subject to full compliance of relevant provisions of CEA (Measures relating to Safety and Electric supply) Regulations,2010 (as amended to date) in every respect.

Mary Francis

(Mary Francis)
Deputy Director
For CEI to Govt. of India

उप निदेशक / Deputy Director
क्षेत्रीय निरीक्षण संगठन
Regional Inspectorial Organisation
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
चेन्नै / Chennai-600 006.