



Government of India
Central Electricity Authority
Regional Inspectorial Organisation
Block IV, Floor III, Shastri Bhawan, Chennai – 600 006



No.140/1/2016-RIO/ 1006

Dated 08.11.2017.

To,
M/s Agile Electric Sub Assembly Pvt Ltd,
Unit - II, MEPZ- SEZ,
Tambaram,
Chennai - 45.

9/c

Sub: Acceptance of Self - certification report submitted by M/s Agile Electric Sub Assembly Pvt Ltd for HV&MV additions/alterations done at their premises - Reg.


Ref: Agile Electric Sub Assembly Pvt Ltd letter dated 28.10.2017.

Vide letter under reference, M/s Agile Electric Sub Assembly Pvt Ltd has submitted Self - Certification report under regulation 43 for HV&MV additions/alterations done at their premises and requested for acceptance of the same by this office. The list of equipment are as given below:

SNo.	Name of the Equipment	Qty
1.	11/0.433kV, 1600KVA T/F	1nos
2.	2500A TPN AL Bus Duct	1nos
3.	Main MV Panel	1nos
4.	LT Cables (mentioned in report)	-
5.	SSB Validation Panel	1nos

It is hereby said that Self - Certification report submitted by M/s Agile Electric Sub Assembly Pvt Ltd under regulation 43 for the above mentioned HT&MV installations which are erected at their premises is found to be generally in order. Hence the Self - Certification report submitted by M/s Agile Electric Sub Assembly Pvt Ltd under regulation 43 for the aforesaid electrical installations installed at their premises is hereby accepted and can be energised. The acceptance of Self - Certification report of aforesaid electrical installations is subject to full compliance of relevant provisions of CEA (Measures relating to Safety and Electric supply) Regulations,2010 (as amended to date) in every respect.

M.L.Ah
08/11/17


(Mary Francis)
Deputy Director
For CEI to Govt. of India
उप निदेशक / Deputy Director
क्षेत्रीय निरीक्षण संगठन
Regional Inspectorial Organisation
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
चेन्नई / Ch.ennai-600 006.