



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
पावर कम्युनिकेशन डवलपमेंट प्रभाग
Power Communication Development Division

No: CEA/PCD/PTCC/GUJ-767/ 151-152

Date: 07/02/2019

DET (PTCC), Inspection Circle,
Bharat Sanchar Nigam Limited (BSNL),
3rd Floor, D-Wing, BSNL Admin Bldg.
Juhu Tara Road, Santacruz (West),
Mumbai-400054

Subject: PTCC Route Approval for IWISL (Dayapar)-Bhuj PS 220kV D/C line

Ref (i) BSNL Ltr.No.IC/MBI/PTCC/GUJ-2586 dt. 01/11/2018
(ii) Western Railway Ltr No.SG.158/28/12/ 1015 dt.30/11/2018
(iii) Defense Letter No.B/46937/Sigs 7(b)/1249 dt.25/10/2018

Sir,

The low frequency induction on BSNL Telecommunication circuits as per details furnished vide above cited reference has been examined. The average Soil Resistivity (SR) value has been taken as 30,000 Ohm Cm, as intimated by the Power Authority, M/s Inox Wind Infrastructure Services Ltd. The voltages likely to be induced on paralleling telecom circuits of BSNL under Single Line to Ground fault condition have been computed and are enclosed at Annex. The screening factors, as applicable, have been considered. Western Railway and Defense vide above Ref.(ii) and (iii)respectively have accorded NOC for the above line.

Taking above into consideration, kindly take necessary action regarding issue of PTCC route approval

Encl.: As above

(Naresh Bhandari)
Chief Engineer


Copy to:

M/s Inox Wind Infrastructure Services Ltd, Plot No.17, Sector-16A, Film City, Noida-201301

ANNEXURE

Case No.: GUJ-767 Name of the Power line: IWISL (Dayapar)-Bhuj PS 220kV D/C line.		Map Scale : 1cm=500mts Total Length : 73 Km. S.R. Value : 30,000 Ohms-cm			
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.

BSNL DETAIL		Ref. No. IC/MBI/PTCC/GUJ/2586		Dated at Mumbai, the 01/11/2018	
1	NIRONA EXCHANGE				
1A	Nirona Exch.-Local.- 100x10x2P				
2A	Nirona Exch.-Local.- 50x1P				IV less than 430V
3A	Nirona Exch.-Local.- 20x3P				
2	DEVISAR EXCHANGE				
1B	Devisar Exch.-Local-20x3P				IV less than 430V
3	NAKHATRANA EXCHANGE				
1C	Nakhatrana Exch.-Local-200+100*2+50*4				
2C	Nakhatrana Exch.-Conterside-200x1P				
3C	Nakhatrana Exch.-Maninagar-50x1P				
4C	Nakhatrana Exch.-School-50x1P				IV less than 430 V
5C	Nakhatrana Exch.-Viranail-200+100P				
6C	Nakhatrana Exch.-Vathanpilla-200*3+50P				
4	UGEDI EXCHANGE				
1D	Ugedi Exch.-Local pillar-400x1P				IV less than 430 V
2D	Ugedi Exchange Ratadiya-50P				
5	RAWAPAR EXCHANGE				
1E	Rawapar Exch.-Local-800x1P				
2E	Rawapar Exchange GEB-100x1P				IV less than 430V
3E	Rawapar Exchange Vigodi-10x20P				
6	WALKA MOTA EXCHANGE				
1F	Walka mota Ex.-Local-100x1P				IV less than 430 V


 नरेश बंडारी / NARESH BHANDARI
 मुख्य अभियंता / Chief Engineer
 केन्द्रीय विद्युत प्राधिकरण / C.E.A.
 विद्युत मंत्रालय / Ministry of Power
 भारत सरकार / Govt. of India
 नई दिल्ली / New Delhi-86