



भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

पावर कम्युनिकेशन डवलपमेंट प्रभाग

Power Communication Development Division

No.:CEA/PCD/PTCC/HP-63

18/4-15

Date: 22.07.2019

DET (PTCC), Northern Zone,
Bharat Sanchar Nigam Ltd (BSNL),
O/o PGM(N), Inspection Circle,
CTS Compound, Netaji Nagar,
New Delhi - 110023

Subject: PTCC Route Approval for 220 kV D/C transmission line from 132/220 kV S/S Charor (Distt. Kullu) to 220/400 kV PGCIL Pooling S/S Banala (Distt. Mandi)

Reference: (i) BSNL letter no. DET/PTCC/ND/DV-9535/HP-243/2019-2020 dated 15.07.2019
(ii) Northern Railway letter no. 342-SIG/1/PTCC dated 18.07.2019

Sir,

The instant PTCC proposal has been examined. Vide ref. (i) above, BSNL have issued No Objection Certificate (NOC). Vide ref. (ii) above, Northern Railway have intimated that there is no Railway line appearing/existing in the route of Transmission line. Hence, Induced Voltage calculation is not required.

Telecommunication details from Defense are pending and the power authority has shown urgency for charging the line. In view of this, you are requested to issue provisional PTCC route approval.

m/c

शरद्विन्दु सराय सिंह
22.07.19
(R.P. Singh)
Director, PTCC

Copy to:

DGM & Head Trans Designs, HP Power Transmission Corporation Ltd, Anu, Hamirpur, Himachal Pradesh - 177001