



भारत सरकार

Government of India
विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

पावर कम्युनिकेशन डवलपमेंट प्रभाग

Power Communication Development Division

No.: CEA/PCD/PTCC/JHR-47/916-17

Date: 19.08.2019
22

DET (PTCC), Eastern Zone,
Inspection & QA Circle, BSNL
Q.A. Bhawan, EP-GP Block, Sector-V,
Salt Lake, Kolkata – 700091

Subject: PTCC Route Approval for 220 kV D/C line from 220/132/33 kV S/S Chatra to 220/132/33 kV S/S Pakribarwadih
Reference: (i) BSNL letter no. DE/PTCC/ER/EJH260320192390/01 dated 01.08.2019
(ii) East Central Railway letter no. ECR/S&T/PTCC/134, Pt.III/393 dated 28.05.2019
(iii) Defense letter no. B/46937/Sigs 7(b)/1548 dated 10.06.2019

Sir,

The instant PTCC proposal has been examined. Vide ref. (i) above, BSNL have issued No Objection Certificate (NOC). Vide ref. (ii) above, East Central Railway have intimated that there is no railway line within the vicinity of 8 km from the proposed power line. Hence, Induced Voltage calculation is not required. Vide ref. (iii) above, Defense Authority have issued No Objection Certificate (NOC) (enclosed as Annex).

Taking above into consideration, kindly take necessary action for PTCC route approval

Encl.: As above

राजेश्वर प्रसाद सिंह
(R. P. Singh)
Director, PTCC

Copy to:

DGM (Operations & Project), Transmission Circle, Jharkhand Urja Sancharan Nigam Limited, Sringeri Complex, 1st floor, Canary Hill Road, Near Montfort School, Hazaribagh, Jharkhand - 825301

R/K

Annex

JHR-47

Tele : 23019746

Directorate General of Signals
Signals 7
General Staff Branch
Integrated HQ of MoD, (Army)
DHQ PO, New Delhi - 110011


B/46937/Sigs 7(b)/1548/

10 Jun 2019

Office of the DGM (Operation & Projects)
Jharkhand Urja Sancharan Nigam Limited
Transmission Circle, Hazaribag
Circle Office: Sringeri Complex, 1st Floor,
Canary Hill Road, Near Montfort School
Hazaribag-825301, JH

SUBMISSION OF PROPOSAL FOR PTCC CLEARANCE FOR 220KV D/C 3-PHASE CHATRA-PAKRIBARWADIH (PBCMP) TRANSMISSION LINE (PKG-C)

1. Ref your letter No 170/DGM/TC-Hzb dt 16 Mar 2019 (copy att).
2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheet received under your letter mentioned above.
3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.



(A Rawat)
Maj
GSO 1 (Comn)
for SO-in-C

Enclosures : (As above)

Copy to :-

✓ The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi - 110016

for information.