

#### भारत सरकार

# Government of India

विद्युत मंत्रालय

Ministry of Power केन्द्रीय विद्युत प्राधिकरण

### Central Electricity Authority पावर कम्युनिकेशन डवलप्सेंट प्रभाग

Power Communication Development Division

No. CEA/PCD/ PTCC/MP-462/1223-25

Date: 13.12.2019

DET (PTCC), Western Zone, Bharat Sanchar Nigam Limited (BSNL), O/o DET(PTCC), QA & Inspection Circle, 3<sup>rd</sup> Floor, D-Wing, BSNL Admin Bldg., Juhu Tara Road, Santacurz (West), Mumbai – 400054.

Subject: Induced Voltage calculation in respect of PTCC proposal of 220 kV DCSS line from 400 kV S/S Badnawar for Power Supply of 12 MVA to M/s Wonder Cement ltd at Village Kherwas, Badnawar.

- Ref: (i) Chief Engineer(Procurement), MPPTCL letter no 04-01/PTCC/2616/TR-I/1025 dated 04.05.19
  - (ii) BSNL letter no. IC/MBI/PTCC/MP-621 dated 21.06.19
  - (iii) Western Railway letter no no. SG.158/28/10/L-209 dated 30.07.19
  - (iv) Defense letter no. B/46937/Sigs 7(b)/1666/ dated 23.07.19

The PTCC case submitted vide reference (i) has been examined. The low frequency induction on BSNL-Telecommunication circuits as per details furnished vide above references (ii) has been examined. The Soil Resistivity value has been taken as 7500 Ohms-cm, as per data submitted by Power Authority. Voltages likely to be induced on paralleling BSNL Telecom Cables under single line to ground fault condition are enclosed at Annex-I. The screening factors as applicable have been considered. Western Railway vide above ref (iii) informed that Railway lines are out of 8 km area of the proposed power line. Defense has accorded NOC vide above Ref.(iii) for the line (a copy enclosed at Annex-II).

Taking above into consideration, kindly take necessary action regarding issue of PTCC route approval.

Encl.: As above

For Chief Engineer (PCD)

#### Copy to:

Office of CSTE, Western Railway, S&T Dept., 5th Floor, Station Building, Churchgate, Mumbai – 400020
 Chief Engineer(Procurement), MPPTCL, Block No. 3, Shakti Bhawan, Rampur, Jabalpur (M.P.) - 482008

MIC

DE	A Office Case No.: MP-462 T (PTCC) Office Case No.: IC/MBI/PTCC/MP-621	<b>-</b>	M	ap Scale: 1:50	,000 ,000	· 	
Rail	Railway Office Case No.:			Route Length: 5.890 Kms			
Name of Power Line  220KV DCSS line from 400 to M/s Wonder Cement at V		KV S/s Ba	Average SR Value: 7500 (V S/s Badnawar for power supply of lage-Kherwas.				
D. 140		Illage-Khe Length of Parallelis	f	Mutual	Fault	f 12MVA Induce	
	DHAR SSA	in Kms.		Coupling in Ohms	Current in Amps	Voltage :	
(4)	SDOT Badnawar						
(A)	Badnawar T/Exchange	<del></del>		- -			
(1)	Badnawar Exch to Main Village - 400 Pair	~	_		,		
(2)	Badnawar Exch to Main Village - 400 Pair					<del></del>	
(3)	Badnawar Exch to Main Village - 200 Pair	> (v		is there	4300		
4)	Badnawar Exch to Chopati - 50 Pair						
	Multhan T/Exchange	<u> </u>	_				
	Multhan Exch to Chopati – 20 Pair						
, <del></del>	Multhan Exch to Main Village - 100 Pair	4-1V 10	246	than 43		<del></del>	
	Oholana T/Exchange						
_ <u></u>	Oholana Exch to Phata - 20 Pair						
	holana Exch to Main Village - 100 Pair		· · · ·	<del></del>		·  -	

mrc. of 142

सारवंद्र प्रताप निष्ठ RAGHVENDRA PRATAP SINGH विशेषाका/Director बेन्द्रीय विश्वास प्रकीयकरण/C.E.A. विद्युत प्रकारिक श्रीकारकार को Power पारत अस्तर्य (केंद्राके को किसी) Tele 23019746

MP-462

Directorate General of Signals Signals 7 General Staff Branch Integrated HQ of MoD, (Army) DHQ PO, New Delhi – 110011\

B/46937/Sigs 7(b)/1666/

23Jul 2019

Chief Engineer (Procurement)
Madhya Pradesh PowerTransmission Co. Ltd.
Block No.-3, Shakti Bhawan, Rampur,
Jabalpur(M.P.)482008

# CONSTRUCTION OF 220KV DCSS LINE FROM 400KV S/S BADNAWAR FOR POWER SUPPLY OF 12MVA TO M/S WONDER CEMENT AT VILLAGE KHERWAS UNDER CONSUMER CONTRIBUTION WORKS-PTCC ROUTE APPROVAL

- Ref your letter No 04-01/PTCC/2616/TR-I/1025 dt 04 May 2019. (copy att).
- 2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheet received under your letter mentioned above.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(A Rawat)
Maj
GSO 1 (Comn)
for SO-in-C

Enclosures : As above

## Copy to :-

The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi – 110016

for information.

Die St. St.