



भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

पावर कम्युनिकेशन डवलपमेंट प्रभाग

Power Communication Development Division

No. CEA/PCD/ PTCC/RAJ-604 / 51-52

Date: 15.01.2019

DET (PTCC), Northern Zone,
Bharat Sanchar Nigam Limited (BSNL),
O/o PGM(N), Inspection Circle,
CTS Compound, Netaji Nagar,
New Delhi - 110023


Subject: PTCC Route Approval for 220 kV D/C Bhiwadi – TSS Mundana of DFCC line

Ref: (i) BSNL letter no. DET/PTCC/ND/DV-9301/Raj-1136/ dated 12.04.2018
(ii) Northern Western Railway letter no. SG/158/NWR/PTCC/655 dated 16.06.2017
(iii) Defense letter no. B/46937/Sigs 7(b)/590/ dated 01.08.2017

The instant PTCC case has been examined. BSNL vide above ref.(i) has informed that there is no cable working within 8 kms along the proposed power line and Northern Western Railway vide above Ref.(ii) has informed that there is no railway track within the vicinity of 8km of the proposed power line, therefore IV calculations are not needed in case of BSNL and Railway. Defense has accorded NOC vide above Ref.(iii) for the above line.

Taking above into consideration, kindly take necessary action regarding issue of PTCC route approval.

MLC


(Naresh Bhandari)
Chief Engineer

Copy to:

Executive Engineer (PTCC), RRVPNL, First Floor, Room no. 129, Vidyut Bhawan, Jyoti Nagar, Jaipur – 302005.