



भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

पावर कम्युनिकेशन डवलपमेंट प्रभाग

Power Communication Development Division

No. CEA/PCD/ PTCC/RAJ-612/196-37

Date: 23/1/2019

DET (PTCC), Northern Zone,  
Bharat Sanchar Nigam Limited (BSNL),  
O/o PGM(N), Inspection Circle,  
CTS Compound, Netaji Nagar,  
New Delhi - 110023


**Subject:** PTCC Route Approval for 220kV LILO from STPS-Ratangarh line to 220kV GSS Halasar

**Ref:** (i) BSNL letter no. DET/PTCC/ND/DV-9392/Raj-1191/2018-19 dated 27.11.2018  
(ii) Northern Western Railway letter no. SG/158/NWR/PTCC/708 dated 13.06.2018  
(iii) Defense letter no. B/46937/Sigs 7(b)/1148/ dated 13.08.2018

Sir,

The instant PTCC case has been examined. BSNL vide ref.(i) above has conveyed NOC. North Western Railway vide ref.(ii) above has informed that there is no railway track within the vicinity of 8 km of the proposed power line, therefore, Induced Voltage (IV) calculations have not been carried out. Defense has accorded NOC vide ref.(iii) above.

Taking above into consideration, kindly take necessary action regarding issue of PTCC route approval.

  
(Naresh Bhandari)  
Chief Engineer  
23/1/19

**Copy to:**

Executive Engineer (PTCC), RRVPNL, Room no. 129, Vidyut Bhawan, Jyoti Nagar, Jaipur – 302005