



सत्यमेव जयते

भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

पावर कम्युनिकेशन डवलपमेंट प्रभाग

Power Communication Development Division

No. CEA/PCD/ PTCC/RAJ-628/956-57

Date: 18.09.2019

DET (PTCC), Northern Zone,
Bharat Sanchar Nigam Limited (BSNL),
O/o PGM(N), Inspection Circle,
CTS Compound, Netaji Nagar,
New Delhi - 110023

Subject: PTCC Route Approval for 220 kV S/C Transmission line from ACME 250 MW Pooling Station to PGCIL 765/400/220 kV Bhadla GSS

Ref: (i) BSNL letter no. DET/PTCC/ND/DV-9551/Raj-1237/2019-2020 dated 12.09.2019
(ii) Northern Western Railway letter no. SG/158/NWR/PTCC/749 dated 08.08.2019

The instant PTCC case has been examined. BSNL vide above ref.(i) has conveyed NOC. Northern Western Railway vide above Ref.(ii) has informed that there is no railway track within the vicinity of 8km of the proposed power line, therefore IV calculations are not needed.

Telecommunication details from Defense are pending and the power authority has shown urgency for charging the line. In view of this, you are requested to issue provisional PTCC route approval.

राजेश कुमार सिंह
18.09.19
R P Singh
Director(PTCC)

Copy to:

Manager-Projects, ACME solar Holdings limited, Plot No.152, Sector-44, Gurugram-122002, Haryana

M/C