

भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

पावर कम्युनिकेशन डवलप्मेंट प्रभाग

Power Communication Development Division

No. CEA/PCD/PTCC/UP-474/12-67-12-09

Date: 06.12.2019

DET (PTCC), Northern Zone, Bharat Sanchar Nigam Limited (BSNL), O/o PGM(N), Inspection Circle, CTS Compound, Netaji Nagar, New Delhi - 110023

Subject: Induced Voltage calculation in respect of PTCC proposal of 400 kV D/C Ghatampur – Kanpur transmission line

Ref: (i) Ghatampur Transmission limited letter no GTL/KNP/GKTL/PTCC/104 dated 21.02.19

- (ii) BSNL letter no. DET/PTCC/ND/DV-9537/UP-758/2019-20 dated 08.07.2019
- (iii) Northern Central Railway letter no: NCR/S&T/2074/TEL./PTCC(Part-I) dated 02.04.2019
- (iv) Defense letter no. B/46937/Sigs 7(b)/1497/ dated 11.11.2019

The PTCC proposal submitted vide above ref(i) has been examined. The low frequency induction on telecom cables of BSNL and Block & Telecom circuits of Railway with respect to details furnished vide above references have been computed. The Soil Resistivity (SR) value has been taken as 36,000 Ohm-cm. The voltages likely to be induced on paralleling telecom cables of BSNL and Block & Telecom circuits of Railway under Single Line to Ground fault condition are enclosed at Annex-I & II respectively. The screening factors, as applicable, have been considered. Vide ref. (iv) above, Defence Authority have issued No Objection Certificate (NOC) (a copy enclosed as Annex-III).

Taking above into consideration, kindly take necessary action for PTCC route approval.

Encl.: As above

(Upendra Kumar)

Chief Engineer

Copy to:

Me

- 1) ASTE/Tele/HQ, North Central Railway, HQ's Office (S&T) Branch, Ganga Parisar, Subedarganj, Allahabad 211015 (Annex II only)
- 2) Associate Manager, Ghatampur Transmission Limited (Kanpur), 644 & 644A, Lakhanpur Co-operative Housing Society, Vikas Nagar, Kanpur 208024

ANNEXURE -I Case No.: UP-474 Name of the Power line: 400 KV D/C Ghatampur-Kanpur Map Scale : 1cm=500mts Transmission Line Total Length: 49.076Km. S.R. Value : 30,000 Ohms-cm Effective Length of Mutual Fault 1,V **Parallelism** Coupling current in S.No. Telecom. Details in Km. in Ohms. in Amps. Volts. BSNL DETAIL Ref. No: DET / PTCC / ND / DV-9537 / UP-758 / 2019 - 2020 DATED: 08-07-2019 Affected Blocks & Telcom Circuits Details Ghatampur TE to Musanagar Road' (200 Pair, 05 KM) Ghatampur TE to Sajedi Road(200 Pair, 04 KM) Ghatampur TE to Jahangirabad Road (200 Pair, 03 KM) Gajner Exch to Thana end onwards (100 Pair, 1.5 KM) Rania Exch to NH Road (Popular Dharam Kanta) 400 Pair. 0.3 KM Gajner Exch to Raipur side Road (50 Pair, -0.5-KM) --IV LESS THAN -----Gajner Exch to Sarwankhera Side (50 Pair, $0.5 \,\mathrm{KM}$ 430 V 8 Rania Exch to State Bank Rania (50 Pair. 0.8 KM Sarwankhera TE to Sarwankhera Chauraha (100 Pair, 1.5 KM) 10 Sarwankhera TE to Raipura Side (50 Pair, $0.5 \, \text{KM}$ 11 Jainpur TE to Navipura Pullia (100 Pair,01 KM) Jainpur TE to Gajner Road, Nabipura (100 12 Pair, 01 KM) मुख्य अभियंता/Chief Engineer

केन्द्रायं वियुत्त प्राधिकरण/C.E.A.

विद्युत मंत्रालंब/Ministry of Power

भारत सरकार/Govt. of India

बद्दे विल्ली/New Delhi

Name of the Power line: 400 KV D/C Ghatampur-Kanpur Transmission Line			Map Scale: 1cm=500mts Total Length: 49.076Km. S.R. Value: 30,000 Ohms-cm		
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
Ref. No:	I CENTRAL RAILWAY NCR / S&T / 2074 / TEL./ PTCC (PA	RT-1) DATED: 02	-04-2019		
Kanpur	-Jhansi section				<u>. </u>
1	Lalpur - Tilaunchi	OI	ut of //sm		0
2	Tilaunchi - Paman	3	0.0039	13300	52
3	Paman – Rasalpur Gogamau			_	,
Bhimse	n-Khairar	1.5	0.0007	13000	9
1	Pitara - Ghatampur	·	0.0040		· · ·
2	Ghatampur - Dohru	6	0.0012	7800	9
3	Dohru – Hamiirapur Road	8.5	0.0066	9600	
4	Hamienin Dand Dan	4.0	0.0138	10400	143
5 .	Dapsaura – Yamuna South bank		0.0065	13500	88
-1	The state of the s	out of //sm			0
		de, de		34-54KK	
a =.				-06/12/	Engineer
-:			· · · · · · · · · · · · · · · · · · ·	मुख्य अभिकार ∕Chief केन्द्रीय विद्युत प्राधकर	r/C.E.A.
				वेद्युत मंत्रालय/शिक्षांक्री भारत सरकार/Gowt	of India
	······································			नई दिल्ली/(५७)	Delhi
Ü		-		 	<u></u>
	<u>, , , , , , , , , , , , , , , , , , , </u>			· -	
<u></u> -		· · · · · · · · · · · · · · · · · · ·			
		· · · · · · · · · · · · · · · · · · ·	<u> </u>	<u></u>	
	· · · · · · · · · · · · · · · · · · ·	-	·		····
-			······································	· · · · · · · · · · · · · · · · · · ·	
	······································	· · · · · · · · · · · · · · · · · · ·	·		·
	· · · · · · · · · · · · · · · · · · ·		<u>-</u> <u>.</u>	<u> </u>	·
					· · · · · · · · · · · · · · · · · · ·
				•	
	· · · · · · · · · · · · · · · · · · ·				

Tele: 23019746

Directorate General of Signals Signals 7 General Staff Branch Integrated HQ of MoD, (Army) DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/1497/

Nov 2019

Chatampur Transmission Limited 644&644A, Lakhanpur Co-operative Housing Society, Vikas Nagar, Kanpur, Pin Code-208024 (U.P.)

PROPOSAL FOR PTCC APPROVAL OF 400KV D/C (TWIN MOOSE) GHATAMPUR-KANPUR T/L

- 1. Ref your letter No. GTL/KNP/GKTL/PTCC/04 dt 21 Feb 2019 (copy att).
- 2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheet received under your letter mentioned above.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(A Rawat)
Maj
GSO 1 (Comn)
for SO-in-C

Enclosures : (As above)

Copy to :-

The Director (PTCC) CEA
Power Communication Development Division
NRPC Complex, 18 A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi – 110016

Divisional Engineer Telegraph (PTCC)
O/o GM (North); BSNL, QA & Inspection Circle,
CTS Compound, Africa Avenue Road;
Netaji Nagar, New Delhi-110023

for information