



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
पावर कम्युनिकेशन डवलपमेंट प्रभाग
Power Communication Development Division

No.: CEA/PCD/ PTCC/UP-475/ १०-४१

Date: 29.01.2020

The Divisional Engineer (Telecom), BSNL
PTCC O/o GM (North), Inspection Circle (T & D),
CTS Compound, Netaji Nagar,
Africa Avenue, New Delhi - 110023

Subject: PTCC proposal of 400 kV D/C overhead transmission line on Monopole from 400 kV S/S at Sector-148, Noida to 400 kV S/S at Sector-123, Noida.

Ref. : (i) UPPTCL Ref. No. 550/ETD-II/Noida Dated: 13.03.2019
(ii) BSNL Ref. No. DET/PTCC/ND/DV-9537/UP-761/2019-2020 Dated: 24.07.2019
(iii) Northern Railway Ref. No. 342-SIG/1/PTCC Dated: 22.07.2019

The PTCC proposal submitted vide above ref. (i) has been examined. BSNL vide ref. (ii) above, has intimated that there are no primary U/G cable and no armoured OFC within 08 kms of the proposed power line and hence, issued No objection Certificate (NOC). Vide ref. (iii) above, Northern Railway have intimated that there is no Railway line appearing/existing in the route of the proposed transmission line. Therefore, Induced voltage calculation is not required for this line.

Telecommunication details from Defense are pending and the power authority has shown urgency for charging the line. In view of this, you are requested to issue provisional PTCC route approval.

Upendra Kumar
29.01.2020

(Upendra Kumar)
Chief Engineer

Copy to:

M/C

1. Executive Engineer, UPPTCL, Electricity Transmission Division-II, 220 kV Substation Sec.-20, Noida-201301.