



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
पावर कम्युनिकेशन डवलपमेंट प्रभाग
Power Communication Development Division

No. CEA/PCD/ PTCC/UP-525/117-119

Date: 17.02.2020


DET (PTCC), Northern Zone,
Bharat Sanchar Nigam Limited (BSNL),
O/o PGM(N), Inspection Circle,
CTS Compound, Netaji Nagar,
New Delhi - 110023

Subject: Induced Voltage calculation in respect of PTCC proposal of LILO of 220 kV D/C Bareilly (400) – Shahjahanpur line at 200 kV S/S Faridpur

- Ref:** (i) Executive Engineer, UPPTCL letter no.1438/ ETD (B)/ dated 30.10.2019
(ii) BSNL letter no. DET/PTCC/ND/DV-9658/UP-830/2019-2020 dated 06.02.2020
(iii) North Eastern Railway letter no. N/242/0/(Tele)(PTCC)-Pt.-II/839 dated 27.12.2019

The PTCC case submitted vide reference (i) has been examined. BSNL vide above Ref. (ii) has accorded NOC for the line. North Eastern Railway vide reference (iii) has informed that there are no signaling and telecom circuits within the corridor of 8 Kms of the proposed power line, hence no induced voltage calculations are done.

Telecommunication details from Defense are pending and the power authority has shown urgency for charging the line. In view of this, you may issue provisional PTCC route approval.


17.02.2020

(Upendra Kumar)
Chief Engineer

Copy to:

- 1) GM(S&T), North Eastern Railway, State Entry Road, Gorakhpur
- 2) Executive Engineer, Electricity Transmission Division, UPPTCL, Near LIC Office, Rampur Garden, Bareilly – 243001 (U.P.)

MIC