

सत्यमेव जयते

भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

विद्युत संचार विकास प्रभाग

Power Communication Development Division

No.: CEA/PCD/PTCC/ASM-21/298-299

Date: 15.07.2020


Subject: PTCC proposal of 400 kV D/C (Twin Moose Conductor) transmission line from Imphal (Manipur) to New Mariani (Assam) via New Kohima (Nagaland) under System Strengthening Scheme-VI (NERSS-VI) of North Eastern region on Boom Basis-regd.

- Ref.: (i) KMTL Ref. No. KMTL/NER/GHY/2019-20/PTCC/1011/12C/191 Dated: 10.06.2019
(ii) BSNL Ref. No. DE/PTCC/EAS220720192224/2 Dated: 22.06.2020
(iii) Northeast Frontier Railway Ref. No. N/146/2/10Pt.VI(TC) Dated: 10.06.2020
(iv) Defense Ref. No. B/46937/Sigs 7(b)/1707 Dated: 31.07.2019

The PTCC proposal submitted vide ref. (i) has been examined. BSNL vide ref. (ii) above has informed that no BSNL's telecom equipment/circuits have been affected by the proposed power line and vide ref. (iii) above, Northeast Frontier Railway has intimated that no railway track/ railway communication line exists within 8 km on either side of the proposed power line. Therefore, IV calculation is not required for BSNL and Northeast Frontier Railway. Defense has accorded NOC vide ref. (iv) above for this line (a copy enclosed at Annex-I).

Taking above into consideration, necessary action regarding issue of PTCC route approval may be taken at your end.

Encl.: As above.


15.07.2020
(Upendra Kumar)
Chief Engineer

To,
DET (PTCC), Eastern Region,
Inspection & QA Circle, BSNL, Q.A. Bhawan
EP-GP Block, Sector-V, Salt Lake, Kolkata - 700091.

Copy to:-

Chief Executive Officer, Kohima-Mariani Transmission limited, C/o Bhabani Prasad Sarmah,
House No.-6, Chilarai Path, Ward No.-28, Survey, Beltola, Guwahati-781028.

(Annex-I)

Tele : 23019743

Directorate General of Signals
Signals 7
General Staff Branch
Integrated HQ of MoD. (Army)
GHQ PC, New Delhi - 110011


B/46937/Sigs 7(c)/1707/

Jul 2019

Chief Executive Officer
Kohima-Mariani Transmission Limited
C/o Shabani Prasad Samah,
House No.-6, Chilarai Path
Ward No. 28, Survey, Beltola
Guwahati, Assam-781 028

CONSTRUCTION OF 400KV D/C (TWIN MOOSE CONDUCTOR) TRANSMISSION LINE FROM
IMPHAL (MANIPUR) TO NEW MARIANI (ASSAM) VIA NEW KOHIMA (NAGALAND) UNDER
SYSTEM STRENGTHENING SCHEME-VI (NERSS-VI) OF NORTH EASTERN REGION ON
BOOM BASIS-SUBMISSION OF PROPOSAL FOR PTCC CLEARANCE

1. Ref your ref. No KMTL/NER/GHY/2019-20/PTCC/1011/12C/190 dt 10 Jun 2019 (copy att).
2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheet received under your letter mentioned above.
3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.


(Anurag Mishra)
Lt Col
GSO 1 (Comm)
for SO-in-C

Enclosures : As above

Copy to:

The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeeb Singh Marg
Kaiwaria Sarai, New Delhi - 110016

for information.