



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
केन्द्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
विद्युत संचार विकास प्रभाग  
Power Communication Development Division

Case No. : J&amp;K-54

dt. 09/04/21  
PTCC proposal of LILO of circuit-II of 400 kV D/C Kishanpur to New Wanpoh transmission line with Pot Head yard BHEP Stage-II ( 3.965 km)

## Reference:

S. No.	Reference No.	Dated
(i)	EE, 400 kV TLD BHEP: TLD/BHEP/549-50	02.01.2021
(ii)	BSNL: DET/PTCC/ND/DV-9816/JK-230/2020-2021	16.02.2021
(iii)	Northern Railway: 342-SIG/1/PTCC/2020-21/11/07	25.11.2020
(iv)	CE(Civil), Baglihar H.E. Project Chanderkote: CEC/BHEP/PGCIL/3880-87	19.03.2021

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide reference (ii) has intimated that there are no BSNL lines (copper cable and armored OFC) in the route of the proposed power line and has conveyed its NOC. Northern Railway vide reference (iii) has intimated that there is no railway line appearing/existing in the route of the proposed power line. Hence, IV calculation for BSNL and Northern Railway is not required.

Telecommunication details from Defense are pending and the power authority has shown urgency for charging the line vide above reference (iv). In view of this, necessary action regarding issuance of provisional PTCC route approval for LILO of circuit-II of 400 kV D/C Kishanpur to New Wanpoh transmission line with Pot Head yard BHEP Stage-II may be taken.

Encl.: As above.

Signature Not Verified  
Digitally signed by  
RAGHENDRA PRATAP SINGH  
Date: 2021.04.09 18:25:22 IST

To,

Director

m/c

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001.	
2.	EE, 400 kV TLD BHEP	Office of Executive Engineer, Baglihar H.E. Project Chanderkote (xenetldbhep@gmail.com)	Copy for information