



सत्यमेव जयते

भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

विद्युत संचार विकास प्रभाग

Power Communication Development Division



No.: CEA/PCD/ PTCC/RAJ-633 576-577

Date: 22.09.2020

Subject: PTCC proposal of Mahindra Susten 250 MW Solar Project at Bhiv Ji Gaon village, Bap Tehsil, Jodhpur- Bhadla 220 kV S/C line with AL59 Zebra Conductor -regd.

Ref.: (i) Mahindra Susten Pvt. Ltd Ref. No. PTCC/Mahindra/2020/1 Dated: 27.01.2020
(ii) BSNL Ref. No. DET/PTCC/ND/DV-9261/Raj-1277/2020-21 Dated: 15.09.2020
(iii) North Western Railway Ref. No. SG/158/NWR/PTCC/764 Dated: 14.02.2020
(iv) Defense Ref. No. B/46937/Sigs 7(b)/1980 Dated: 01.07.2020

The PTCC proposal submitted vide ref. (i) has been examined. BSNL vide ref (ii) has intimated that there are no U/G copper cable and armoured OFC cables within 8 km of the proposed power line. North Western Railway in ref (iii) has intimated that there is no railway track within the vicinity of 8 km from the proposed power line. Hence, IV calculation for telecom lines of BSNL and Block and telecommunication circuits of North Western Railway is not required. Defense has accorded NOC vide above ref. (iv) for this line (a copy enclosed at Annex-I).

Taking above into consideration, kindly take necessary action regarding issue of PTCC route approval.

Encl.: As above.

उपेन्द्र कुमार

22.09.2020

(Upendra Kumar)
Chief Engineer

To,
The DET (PTCC), BSNL, Northern Zone,
O/o PGM (N), QA & Inspection Circle,
D-Tax Building, Eastern Court
Janpath, New Delhi 110001.

Copy to:-

Mahindra Susten Private Limited, 6th Floor, AFL House, Lok Bharati Complex, Marol Maroshi Road, Andheri(East), Mumbai-400059.

एन आर पी सी परिसर, कटवारिया सराय, नई दिल्ली-110016 टेलीफैक्स: 011-26565214 ईमेल: celdntcea@gmail.com वेबसाइट www.cea.nic.in
NRPC Complex, Katwaria Sarai, New Delhi-110016 Telefax: 011-26565214 Email: celdntcea@gmail.com Website: www.cea.nic.in

M/K