



भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

विद्युत संचार विकास प्रभाग

Power Communication Development Division

Case No.: RAJ-647

21-07-21

PTCC proposal of 220 kV S/C transmission line from Eden 300 MW Plant to PGCIL 765/400/220 kV Fatehgarh II PS (New), Jaisalmer (13.34 km)

Reference:

S. No.	Reference No.	Dated
(i)	M/s Eden Renewable Cite Private Limited: ERCPL/PTCC/COM-149	01.09.2020
(ii)	BSNL: DET/PTCC/ND/DV-9767/Raj-1281/2020-2021	14.10.2020
(iii)	North Western Railway: SG/158/NWR/PTCC/786	24.09.2020
(iv)	Defense: B/46937/ Sigs 7(b)/2164	04.12.2020

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide reference (ii) has intimated that there are no BSNL lines (copper cable and armored OFC) in the route of the proposed power line and has conveyed its NOC. North Western Railway vide reference (iii) has intimated that there is no railway track within the vicinity of 8 km from the proposed power line and given their consent for PTCC route approval for the proposed power line. The Defense Authority have accorded NOC vide above reference (iv) for this line.

Taking above into consideration, necessary action regarding issuance of PTCC route approval may be taken.

Digitally signed by RAJESH KUMAR PRATAP SINGH
Date: 2021.04.07 19:11:53 +05'30'

Director

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi-110001.	
2.	M/s Eden Renewable Cite Private Limited	Unit No. 236 B&C, 1 st Floor, DLF South Court, Saket, New Delhi-110017.	Copy for information