

1/14365/2021



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

Case No.: RAJ-656	dt. 04.03.21
PTCC proposal of 220 kV S/C transmission line from 220/33 kV PSS Azure Power India Pvt. Ltd. to 765/400/220 kV GSS PGCIL Bhadla, Jodhpur.	

Reference:		
S. No.	Reference No.	Dated
(i)	Azure Power India Pvt. Ltd. : AZI/AZS72/PTCC/TL/02/DN-027	16.09.2020
	BSNL: DET/PTCC/ND/DV-9837/Raj-1301/2020-2021	05.02.2021
(iii)	North Western Railway: SG/158/NWR/PTCC/790	03.11.2020
(iv)	Defense: 4937/ Sigs 7(b)/2183	04.12.2020

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide reference (ii) has intimated that there are no BSNL lines (copper cable and armored OFC) in the route of the proposed power line and has conveyed its NOC. North Western Railway vide reference (iii) has intimated that there is no railway track within the vicinity of 8 km from the proposed power line. Therefore, Induced Voltage calculation for the proposed line is not required. The Defense Authority have accorded NOC vide above reference (iv) for this line.

Taking above into consideration, necessary action regarding issuance of PTCC route approval may be taken.

Digitally Signed by RAGHVENDRA PRATAP SINGH
Date: 2021.03.04 14:47:33G+

Director

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi-110001	
2.	M/s Azure Power India Pvt. Ltd.	5 th Floor, Southern Park, D-II, Saket Place, Saket, New Delhi-110017	Copy for information