



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

Case No.: RAJ-657

Date: 27.01.2021

Subject: PTCC proposal of 220 kV S/C line on D/C tower from 110 MW solar plant of Renew Solar Energy (Jharkhand Five) Pvt Ltd to 400/220 kV GSS Jaisalmer-2 (RVPN) -regd.

Ref.: (i) M/s Renew Solar Energy (Jharkhand Five) Pvt Ltd Ref. no. Renew/2020-21/PTCC/3/d dated 12.09.2020
(ii) BSNL Ref. no. DET/PTCC/ND/DV-9815/Raj-1291/2020-21 dated 21.01.2021
(iii) North Western Railway Ref. no. SG/158/NWR/PTCC/794 dated 17.11.2020
(iv) Defense Ref. no. B/46937/Sigs 7(b)/2213 dated 08.01.2021

The PTCC proposal submitted vide ref. (i) has been examined. BSNL vide ref (ii) has intimated that there are no BSNL lines (copper cable and armored OFC) in the route of the proposed power line and has conveyed its NOC. North Western Railway in ref (iii) has intimated that there is no railway track within the vicinity of 8 km from the proposed power line. Defense has accorded NOC vide above ref. (iv) for this line. Therefore, Induced Voltage calculation for the proposed line is not required.

Taking above into consideration, kindly take necessary action regarding issue of PTCC route approval.

Signature Not Verified
Digitally signed by UPENDRA KUMAR
Date: 2021.01.27 18:47:55 IST

(Upendra Kumar)
Chief Engineer

To,
The DET (PTCC), BSNL, Northern Zone,
O/o PGM (N), QA & Inspection Circle,
D-Tax Building, Eastern Court
Janpath, New Delhi 110001

Copy to:-

M/s Renew Solar Energy (Jharkhand Five) Pvt Ltd, Renew Hub, Commercial Block-1, Zone 6,
Golf Course Road, DLF City Phase-V, Gurugram, Haryana - 122009