

I/13679/2021



सत्यमेव जयते

**भारत सरकार**  
**Government of India**  
**विद्युत मंत्रालय**  
**Ministry of Power**  
**केन्द्रीय विद्युत प्राधिकरण**  
**Central Electricity Authority**  
**विद्युत संचार विकास प्रभाग**  
**Power Communication Development Division**

Case No. : RAJ-658:	21.04.02.21
PTCC proposal of 220 kV SC transmission line on DC tower from 250 MW Fortum Solar Plus Pvt. Ltd to 400/220 kV GSS Jaisalmer-2 (RVPN).	

Reference:		
S. No.	Reference No.	Dated
(i)	M/s Fortum Solar Plus Private Limited : FSPPL/GEN/2020-21/220 KV TL/07012021	07.01.2021
(ii)	BSNL: DET/PTCC/ND/DV-9814/Raj-1290/2020-21	21.01.2021
(iii)	North Western Railway: SG/158/NWR/PTCC/795	19.11.2020
(iv)	Defense: B/46937/Sigs 7(b)/2212	08.01.2021

The PTCC proposal submitted vide ref. (i) has been examined. BSNL vide ref (ii) has intimated that there are no BSNL lines (copper cable and armored OFC) in the route of the proposed power line and has conveyed its NOC. North Western Railway in ref (iii) has intimated that there is no railway track within the vicinity of 8 km from the proposed power line. Defense has accorded NOC vide above ref. (iv) for this line. Therefore, Induced Voltage calculation for the proposed line is not required.

Taking above into consideration, kindly take necessary action regarding issue of PTCC route approval.

Signature Not Verified  
 Digitally signed by RAGHUVINDRA PRATAP SINGH  
 Date: 2021.02.04 16:24:58 IST

Director

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001	
2.	M/s Fortum Solar Plus Private Limited	1A Vandana Building, 11 Tolstoy Marg, New Delhi-110001	Copy for information

MIC