

I/14076/2021



भारत सरकार
 Government of India
 विद्युत मंत्रालय
 Ministry of Power
 केन्द्रीय विद्युत प्राधिकरण
 Central Electricity Authority
 विद्युत संचार विकास प्रभाग
 Power Communication Development Division

Case No.: TRI-02 :	27.19.02.21
PTCC proposal of 400 kV D/C transmission line (from existing tower LOC No. 363) of Silchar-P.K. Bari Transmission line to new 400/132 kV P.K. Bari Substation, Jinajini, Tripura.	

Reference:		
S. No.	Reference No.	Dated
(i)	PGCIL: NEKGT/TL/Cons/PTCC/2020-21/294	29.08.2020
(ii)	BSNL: DE/PTCC/EML290920202811/2	04.01.2021
(iii)	Northeast Frontier Railway: N/146/2/10/Pt. V(TC)	29.12.2020
(iv)	PGCIL: NEKGT/TL/Cons/PTCC/2020-21/695	11.02.2021

The PTCC proposal submitted vide ref. (i) has been examined. BSNL vide ref. (ii) has conveyed NOC as no parallel UG cables lies within 8 km of the proposed power line. Northeast Frontier Railway vide above ref.(iii) has issued No objection as no crossing/parallelism with Railway Communication line within 8 km on either side of the proposed power line. . Hence, IV calculation for BSNL and Northeast Frontier Railway is not required.

Telecommunication details from Defense are pending. Vide ref. (iv) above, the power authority has shown urgency for the charging of the proposed power line. Taking above into consideration, necessary action regarding issuance of **provisional PTCC route approval for 400 kV D/C transmission line (from existing tower LOC No. 363) of Silchar-P.K. Bari Transmission line to new 400/132 kV P.K. Bari Substation, Jinajini, Tripura** may be taken.

Signature Not Verified
 Digitally signed by RACHWENDRA PRATAP SINGH
 Date: 2021.02.19 18:04:27 IST

Director

To,

1.	Divisional Engineer (PTCC), Eastern Region, Inspection & QA	BSNL, Q.A. Bhawan, EP-GP Block, Sector-V, Salt Lake, Kolkata – 700091	
2.	DGM(Const)	PGCIL, 132 kV Kumarghat Substation, Vill.-Ratiabari, P.O.-Kumarghat, Dist.-Unakoti, Tripura-799264	Copy for information

M/C