



सत्यमेव जयते

भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
केन्द्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
विद्युत संचार विकास प्रभाग  
Power Communication Development Division

No.: CEA/PCD/ PTCC/UP-505/ 287

Date: 14.07.2020

**Subject:** PTCC proposal for LILO of 220 kV SC Gonda (220 kV)-Basti (220 kV) at 400 kV Bhaukhari Basti S/S Transmission line.

Ref. :	(i)	UPPTCL Ref. No.1174/ETD-I (B)/PTCC	Dated: 17.07.2019
	(ii)	BSNL Ref. No. DET/PTCC/ND/DV-9552/UP-766/2019-2020	Dated: 27.08.2019
	(iii)	North Eastern Railway Ref. No. N/242 / 0(Tele)(PTCC)-Pt.-II/ 573	Dated: 22.08.2019
	(iv)	Defense Ref. No. B/46937/Sigs 7(b)/1769	Dated: 11.11.2019

The PTCC proposal submitted vide above ref. (i) has been examined. BSNL vide ref. (ii) above, has intimated that there are no U/G cable and no armoured OFC within 08 kms of the proposed power line and hence, issued No Objection Certificate (NOC). Vide ref. (iii) above, North Eastern Railway have intimated that there are no any signaling and telecom circuits within the corridor of 8 km of the proposed transmission line and issued NOC. Defense has also, accorded NOC vide above ref. (iv) for this line (a copy enclosed at Annex-I).

Taking above into consideration, kindly take necessary action regarding issue of PTCC route approval.

Encl.: As above.

*Upendra Kumar*  
14.07.2020

(Upendra Kumar)  
Chief Engineer

To,  
The Divisional Engineer (Telecom), BSNL  
PTCC O/o GM (North), Inspection Circle (T & D),  
CTS Compound, Netaji Nagar,  
Africa Avenue, New Delhi - 110023

*MIC*

Copy to:

Executive Engineer, Electricity Transmission Division, UPPTCL, 220 kV Sub-Station, Gidahi-Basti, Uttar Pradesh.

*OTC received 14.7.2020*