



सत्यमेव जयते

भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

विद्युत संचार विकास प्रभाग

Power Communication Development Division

\*\*\*\*\*

No.: CEA/PCD/ PTCC/UP -526 /762-63

Date: 02.12.2020


**Subject:** PTCC proposal of 400 kV DC Quad Moose Tanda (NTPC) Extension – Bhaukhari (Basti) transmission line -regd.

**Ref.:** (i) BSNL Ref. No. DET/PTCC/ND/DV-9683/UP-851/2019-2020 Dated: 25.02.2020  
(ii) North Eastern Railway Ref. No. N/242/0(Tele) PTCC Pt. II/1021 Dated: 26.02.2020  
(iii) Defense Ref. No. B/46937/Sigs 7(b)/1937 Dated: 09.03.2020

The PTCC proposal received by email dated 24.11.2020 has been examined. BSNL vide ref (i) has intimated that there are no U/G copper cable and armoured OFC cables within 8 km of the proposed power line. North Eastern Railway in ref (ii) has intimated that there is no railway track within the vicinity of 8 km from the proposed power line. Hence, IV calculation for telecom lines of BSNL and Block and telecommunication circuits of North Eastern Railway is not required. Defense has accorded NOC vide above ref. (iii) for this line (a copy enclosed at Annex-I).

Taking above into consideration, kindly take necessary action regarding issue of PTCC route approval.

Encl.: As above.

  
02.12.20  
(Upendra Kumar)  
Chief Engineer

To,  
The DET (PTCC), BSNL, Northern Zone,  
O/o PGM (N), QA & Inspection Circle,  
D-Tax Building, Eastern Court  
Janpath, New Delhi 110001.

M/C

Copy to:-

Executive Engineer, Electricity Transmission Division, U.P. Power Transmission Corporation Limited, 220 KV substation, Gidahi- Basti-272002.

Tele : 23019746

UP-526

Directorate General of Signals  
Signals 7

General Staff Branch  
Integrated HQ of MoD, (Army)  
DHQ PO, New Delhi - 110011

(Annex-I)


B/46937/Sigs 7(b)/1937/

09 Mar 2020

Office of the Executive Engineer  
Electricity Transmission Division  
U.P. Power Transmission Corporation Limited  
220KV Sub-Station, Gidahi-Basti-272 002

**PROPOSAL FOR PTCC CLEARANCE FOR 400KV QUAD MOOSE NTPC TANDA BHAIKHARI TRANSMISSION LINE**

1. Ref your letter No 1988/ETD-I(B)/PTCC/Quad Moose Tr. Line dt 17 Dec 2019. (copy att).
2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheet received under your letter mentioned above.
3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

  
(A Rawat)  
Maj  
GSO 1 (Comn)  
for SO-in-C

Enclosures : (As above)

Copy to :-

The Director (PTCC), CEA  
Power Communication Development Division  
NRPC Complex, 18-A Shaheed Jeet Singh Marg  
Katwaria Sarai, New Delhi - 110016

Divisional Engineer Telegraph (PTCC)  
O/o GM (North); BSNL, QA & Inspection Circle,  
CTS Compound, Africa Avenue Road,  
Netaji Nagar, New Delhi-110023

for information