



सत्यमेव जयते

भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

विद्युत संचार विकास प्रभाग

Power Communication Development Division

No.: CEA/PCD/ PTCC/UP -527/764-65

Date: 02.12.2020

Subject: PTCC proposal of LILO of circuit IV of 400 kV Gorakhpur- Lucknow transmission line at 400 kV Bhaukhari substation -regd.


Ref.:

- | | | |
|-------|---------------------------------------------------------------|-------------------|
| (i) | BSNL Ref. No. DET/PTCC/ND/DV-9682/UP-850/2019-2020 | Dated: 25.02.2020 |
| (ii) | North Eastern Railway Ref. No. N/242/0(Tele) PTCC Pt. II/1016 | Dated: 26.02.2020 |
| (iii) | Defense Ref. No. B/46937/Sigs 7(b)/1939 | Dated: 09.03.2020 |

The PTCC proposal received by email dated 24.11.2020 has been examined. BSNL vide ref (i) has intimated that there are no U/G copper cable and armoured OFC cables within 8 km of the proposed power line. North Eastern Railway in ref (ii) has intimated that there is no railway track within the vicinity of 8 km from the proposed power line. Hence, IV calculation for telecom lines of BSNL and Block and telecommunication circuits of North Eastern Railway is not required. Defense has accorded NOC vide above ref. (iii) for this line (a copy enclosed at Annex-I).

Taking above into consideration, kindly take necessary action regarding issue of PTCC route approval.

Encl.: As above.


2.12.20
(Upendra Kumar)
Chief Engineer

To,
The DET (PTCC), BSNL, Northern Zone,
O/o PGM (N), QA & Inspection Circle,
D-Tax Building, Eastern Court
Janpath, New Delhi 110001.

M/c

Copy to:-

Executive Engineer, Electricity Transmission Division, U.P. Power Transmission Corporation Limited, 220 KV substation, Gidahi- Basti-272002.

Tele : 23019746

UP-527

(Annex-I)

Directorate General of Signals
Signals 7
General Staff Branch
Integrated HQ of MoD, (Army)
DHQ PO, New Delhi - 110011

B/46937/Sigs 7(b)/1939/

09 Mar 2020

Office of the Executive Engineer
Electricity Transmission Division
U.P. Power Transmission Corporation Limited
220KV Sub-Station, Gidahi-Basti-272 002

**PROPOSAL OF PTCC CLEARANCE FOR 400KV LILO OF CKT-IV GORAKHPUR-LUCKNOW-
PGCIL TR. LINE @ 400KV BHAIKHARI SUB-STATION**

1. Ref your letter No 1986/ETD-I(B)/PTCC/LILO Line-IV dt 17 Dec 2019. (copy att).
2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheet received under your letter mentioned above.
3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(A Rawat)
Maj
GSO 1 (Comn)
for SO-in-C

Enclosures : (As above)

Copy to :-

✓ The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi - 110016

Divisional Engineer Telegraph (PTCC)
O/o GM (North); BSNL, QA & Inspection Circle,
CTS Compound, Africa Avenue Road,
Netaji Nagar, New Delhi-110023

- for information