



सत्यमेव जयते

भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

विद्युत संचार विकास प्रभाग

Power Communication Development Division

\*\*\*\*\*



No.: CEA/PCD/ PTCC/UP-529 / 273-75

Date: 03.07.2020


**Subject:** PTCC proposal for 2<sup>nd</sup> circuit of 220 kV Baghpat -Baghpat transmission Line -regd.

**Ref.:** (i) UPPTCL Ref. No.768/ETD/BRT/220 kV Dated: 03.06.2020  
(ii) BSNL Ref. No. DET/PTCC/ND/DV-9707/UP-856/2019-2020 Dated: 01.07.2020  
(iii) Northern Railway Ref. No.342-SIG/1/PTCC/2020-21/05/02 Dated:09.06.2020

The PTCC proposal submitted vide ref. (i) has been examined. The LF induction on telecom cables of BSNL and Block & Telecom circuits of Northern Railway with respect to details furnished vide above references (ii) and (iii) respectively has been computed. The Soil Resistivity (SR) value has been taken as 20,000 Ohm-cm. The voltages likely to be induced on paralleling telecom cables of BSNL and Block & Telecom circuits of Northern Railway under Single Line to Ground fault condition are enclosed at Annex-I and Annex-II respectively. The screening factors, as applicable, have been considered.

Telecommunication details from Defense are pending and the power authority has shown urgency for the charging of the line. In view of this kindly take necessary action regarding issuance of provisional PTCC route approval for 2<sup>nd</sup> circuit of 220 kV Baghpat -Baghpat transmission Line.

**Encl.:** As above.

  
03.07.2020  
(Upendra Kumar)  
Chief Engineer

To,  
The Divisional Engineer (Telecom), BSNL  
PTCC O/o GM (North), Inspection Circle (T & D),  
CTS Compound, Netaji Nagar, Africa Avenue, New Delhi – 110023.

**Copy to:**

1. General Manager/S&T, Northern Railway, Headquarter Office, Baroda House, New-Delhi-110001. (Annex-I only)
2. Executive Engineer, UPPTCL, 132 kV S/S Delhi Road, Baraut-250611

Case No. : UP-529

**Annexure I**

Name of the Power Line: 2nd CKT of 220 KV ( 400 KV PGCIL)  
Baghpat-Baghpat ( 220 KV, UPPTCL) Line

Toposheet Scale : 1cm=500mts  
Total Length : 23.966 Kms  
S.R Value : Ohm-cm

Sl. No.	Name of Telecom Line	LOP in Kms	MC in Ohms	Fault Current (Amps)	IV
---------	----------------------	------------	------------	----------------------	----

**BSNL**

Reference No.

Date

Sl. No.	Name of Telecom Line	LOP in Kms	MC in Ohms	Fault Current (Amps)	IV
BSNL Details					
1	Baghpat TE to Canara bank 100 Pair ( 1.5 KM)				IV less than 430 V
2	Baghpat TE to Rashtra vandana Chowk 400 pair ( 1.3 KM)				
3	Baghpat Te to PWD Guest House 100 Pair ( 2.5 KM)				
4	Rashtra vandana Chowk to Shiv mandir Chowk 50 pair ( 0.8 KM)				
5	Rashtra vandana Chowk to Mahila Thana Baghpat 20 pair ( 1.1 KM)				
6	Rashtra vandana Chowk to Sugar mill Baghpat 100 pair ( 1.4 KM)				
7	Sugar mill baghpat to Baghu Road 20 pair ( 1 KM)				
8	New DM Office Collectorate baghpat 100 pair ( 1.5 KM)				
9	Taitiri TE to Mandi gate Taitiri 200 pair ( 1.3 KM)				
10	Mandi gate Taitiri to Sarvodaya Hospital Taitiri 50 KM ( 1.1 KM)				

VK  
03.07.20

मुख्य अभियंता / Chief Engineer  
केंद्रीय विद्युत प्राधिकरण / Central Board of Secondary Education  
विद्युत मंत्रालय / Ministry of Power  
भारत सरकार / Govt. of India  
नई दिल्ली / New Delhi

**ANNEXURE - II**

<b>Case No.: UP-529</b>		Map Scale : 1 cm = 500 m. Route Length : 23.566 km Soil Resistivity : 20,000 Ohm-cm			
<b>Name of the Power Line: 2<sup>nd</sup> circuit of 220 kV Baghpat - Baghpat transmission Line.</b>					
S.No.	Telecom Details	Length of Parallelism (in km)	Mutual Coupling (Ohms)	Fault Current (Amps)	Induced Voltage (Volts)

<b>NORTHERN RAILWAY</b>					
Ref. No: 342-SIG/1/PTCC/2020-21/05/02				DATED: 09.06.2020	
<b>Affected Blocks &amp; Telecom Circuits Details</b>					
1	Khekra R/S-Baghpat Road R/S	14.5	0.0103	6041	63
2	Baghpat R/S- Baraut R/S	2.8	0.0011	8297	10

UK  
03.07.20

मुख्य अभियंता/Chief Engineer  
केन्द्रीय विद्युत प्राधिकरण/C.E.A.  
विद्युत मंत्रालय/Ministry of Power  
भारत सरकार/Govt. of India  
नई दिल्ली/New Delhi