



सत्यमेव जयते

भारत सरकार

Government of India

विद्युत मंत्रालय

Ministry of Power

केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

विद्युतसंचारविकासप्रभाग

Power Communication Development Division

No.: CEA/PCD/ PTCC/UTR-25 / 752-53

Date: 26.11.2020

Subject: PTCC proposal of LILO of 400 kV D/C Dhauliganga to Bareilly transmission line at Jauljibi S/S -regd.

Ref: (i) PGCIL Ref. No. NR3/JJB/TL-KPTL/301/2018-19 Dated: 07.06.2019
(ii) BSNL Ref. No. DET/PTCC/ND/DV-9473/UTR-34/2019-2020 Dated: 01.07.2019
(iii) North Eastern Railway Ref. No. N/242/0(Tele) PTCC Pt-II/958 Dated: 29.01.2020
(iv) Defense Ref. No. B/46937/Sigs 7(b)/2168 Dated: 05.11.2020

The PTCC proposal submitted vide ref. (i) has been examined. BSNL vide ref (ii) has intimated that there are no U/G copper cable and armoured OFC cables within 8 km of the proposed power line. North Eastern Railway in ref (iii) has intimated that there is no railway track within the vicinity of 8 km from the proposed power line. Hence, IV calculation for telecom lines of BSNL and Block and telecommunication circuits of North Eastern Railway is not required. Defense has accorded NOC vide above ref. (iv) for this line (a copy enclosed at Annex-I).

Taking above into consideration, kindly take necessary action regarding issue of PTCC route approval.

Encl.: As above.

Sh. Tansu
PPS

उपेन्द्र कुमार
26.11.2020
(Upendra Kumar)
Chief Engineer

To,
The DET (PTCC), BSNL, Northern Zone,
O/o PGM (N), QA & Inspection Circle,
D-Tax Building, Eastern Court
Janpath, New Delhi 110001.

MIC

Copy to:

1. Asst. Manager, Jauljibi, 400/220 kV GIS Bagrihat, P.O. Jauljibi, Dist. Pithoragarh-262544.

* Tele : 23019746

UTR-2

(Annex-2)

Directorate General of Signals
Signals 7
General Staff Branch
Integrated HQ of MoD, (Army)
DHQ PO, New Delhi - 110011

B/46937/Sigs 7(b)/2168/

Nov 2020

Chief Manager
Power Grid Corporation of India Limited
400/220kV G.I.S., Village & Post Bagrihat,
Jauljibi, Pithorgarh-262543

PTCC CLEARANCE FOR CONSTRUCTION OF LILO OF 400KV D/C DHAULIGANGA-
BAREILLY TRANSMISSION LINE AT GIS JAULJIBI

1. Ref your letter No JJB/1065 dt 16 Sep 2020. (copy att).
2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheet received under your letter mentioned above.
3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.



(A Rawat)
Maj
GSO 1 (Comn)
for SO-in-C

Enclosures : As above

Copy to :-

✓ The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi - 110016

The DET(PTCC), Northern Zone
O/o PGM (North), QA & Inspection Circle,
D-Tax Building, Janpath
New Delhi-110001

for information