



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

Case No. : HP-69

PTCC proposal of 220 kV D/C transmission line from Bajoli - Holi HEP to 33/220/400 kV GIS Sub-station Lahal at Bharmour in District Champa. (18 km)

Reference:

S. No.	Reference No.	Dated
(i)	HPPTCL:HPPTCL/DGM/PTCC-Approval/2020-21-9603-09	19.03.2021
(ii)	BSNL: DET/PTCC/ND/DV-9890/HP-251/2021-2022	01.07.2021
(iii)	Northern Railway: 342-SIG/1/PTCC/2020-21/03/17	25.03.2021
(iv)	Defense: B/46937/ Sigs 7(b)/2386	20.05.2021

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide reference (ii) has intimated that there are no BSNL lines (copper cable and armored OFC) in the route of the proposed power line and has conveyed its NOC. Northern Railway vide reference (iii) has intimated that there is no railway line appearing/existing in the route of the proposed power line. Hence, IV calculation for BSNL and Northern Railway is not required. The Defense Authority have accorded NOC vide above reference (iv) for this line.

Taking above into consideration, necessary action regarding issuance of PTCC route approval may be taken.

Signature Not Verified
Digitally signed by
RAGHVENDRA PRATAP SINGH
Date: 2021.09.16 16:06:34 IST

Director

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001.	
2.	DGM & Head Trans Designs	HPPTCL O/o DGM & Head Trans Designs, Anu, Hamirpur.	Copy for information