

I/15963/2021



**भारत सरकार**  
**Government of India**  
**विद्युत मंत्रालय**  
**Ministry of Power**  
**केन्द्रीय विद्युत प्राधिकरण**  
**Central Electricity Authority**  
**विद्युत संचार विकास प्रभाग**  
**Power Communication Development Division**

<b>Case No.: HRA-240</b>
<b>PTCC proposal for LILO of 220 kV D/C Fatehabad – Chormar line at 220 kV SS Hukamawali (Loop In) (20.333 km)</b>

Reference:		
S. No.	Reference No.	Dated
(i)	HVPNL: Ch. 156/WBH-17/Vol-IV	23.02.2021
(ii)	BSNL: DET/PTCC/ND/DV-9870/HR-867/2021-22	24.05.2021
(iii)	North Western Railway: SG/158/NWR/PTCC/818	16.03.2021

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide above reference (ii) has intimated that there are no BSNL lines (copper cable and armoured OFC) in the route of the proposed power line and has conveyed its NOC. North Western Railway vide above reference (iii) has intimated that there is no railway track within the vicinity of 8 km from the proposed power line and given their consent for PTCC route approval for the proposed power line.

Telecommunication details from Defense are pending and the power authority has shown urgency for the charging of the line. In view of this take necessary action regarding issuance of **Provisional PTCC approval for LILO of 220 kV D/C Fatehabad – Chormar line at 220 kV SS Hukamawali (Loop In).**

Signature Not Verified  
 Digitally signed by RAGHAVENDRA PRATAP SINGH  
 Date: 2021.08.14 15:40:01 IST

**Director**

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001.	
2.	Executive Engineer, TS Division	Haryana Vidyut Prasaran Nigam Ltd, Qtr No. 215-218, Type-4, V.N., Hisar-125005	Copy for information

*M/C*