



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

Case No.: MAN-02 :
PTCC proposal of 400 kV D/C Yurembam to Thoubal transmission line : 45.11 km

Reference:		
S. No.	Reference No.	Dated
(i)	MSPCL: 12/65(400)/GM(PD)/2015-MSPCL/353-57	04.06.2021
(ii)	BSNL: DE/PTCC/E050320212955/01	05.03.2021
(iii)	MSPCL: 12/65(400-L)/GM(PD)/2015-MSPCL/393-97	11.06.2021

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide reference (ii) has conveyed NOC from O/o GMTD, Manipur SSA, Imphal. Therefore, IV calculation is not required for BSNL telecom lines.

The Block & Telecom circuit's details from North East Frontier Railway and telecommunication details from Defense are pending. Vide reference (iii) above, the power authority has shown urgency for the charging of the proposed power line. Taking above into consideration, necessary action regarding issuance of **provisional PTCC route approval for 400 kV D/C Yurembam to Thoubal transmission line** may be taken.

Signature Not Verified
 Digitally signed by RAGHVENDRA
 PRATAP SINGH
 Date: 2021.06.25 17:02:59 IST

Director

To,

1.	Divisional Engineer (PTCC), Eastern Region, Inspection & QA	BSNL, Q.A. Bhawan, EP-GP Block, Sector-V, Salt Lake, Kolkata – 700091.	
2.	Deputy General Manager	Manipur State Power Company Limited, Electricity Complex, Patta No. 1293 under 87(2), Khwai Bazar, Keishampat, Imphal-795001, Manipur.	Copy for information

MIC