

भारत सरकार Government of India

विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण

Central Electricity Authority

विद्युत संचार विकास प्रभाग Power Communication Development Division

PTCC proposal for LILO of one circuit of 400 kV Satna (PGCIL) to Bina (PGCIL) Case No.: MP-449 line at proposed 400 kV Substation Sagar (MPPTCL): 24.799 km

L			
			Dated
	Reference	No	14.11.2018
	S. No.	Reference No. MPPTCL: 04-01/PTCC/2481/TR-I/8848 MPPTCL: 04-01/PTCC/2481/TR-I/8848	18.01.2020
((i)	MPPTCL: 04-01/PTCC/MP-598 (revd. on 22.01.2021)	28.02.2019
	(ii)	BSNL: IC/MBI/PTCC/MP-598 (rcvd. on 22.01.2021) West Central Railway: WCR/N-HQ/120/PTCC/CORR/T-50/	20.02.201
	(11)	West Central Railway: WCIVIVII	125 12 2018
	()	- TTY Cond no /43	25.12.2018
		Defense: B/46937/ Sigs /(D)/1338	
	(iv)	170104	inad The LF

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on telecom cables of BSNL and Block & Telecom circuits of West Central Railway with respect to details furnished vide above references (ii) and (iii) respectively has been computed. The voltages likely to be induced on paralleling telecom cables of BSNL and Block & Telecom circuits of West Central Railway under Single Line to Ground fault condition are enclosed at Annexure-I and Annexure-II respectively. The screening factors, as applicable, have been considered. The Defense Authority have accorded NOC vide above reference (iv) for the proposed power line. (a copy enclosed at Annexure-III)

Taking above into consideration, necessary action regarding issuance of Signature Not Verified PTCC route approval may be taken.

Encl.: As above.

Signature Not Ventiled
Digitally signed by RAGEVENDRA PRATAP
SINGH
Date: 2021.07.06 17:16/24 IST

Director

To,	Divisional Engineer (PTCC), Western Zone	Bharat Sanchar Nigam Limited (BSNL), Inspection Circle, 3 rd floor, D-Wing, BSNL Admin Building, Juhu Tara Road, Santacruz (West), Mumbai-400054.	Annexure- I & Annexure-III only
2.	AESTE/Tele/HQ	West Central Railway: O/o GM (S&T), 1st floor, Annex II building, Jabalpur-482001	Annexure-II only
3.	Chief Engineer (Procurement)	MPPTCL: Block No. 3, Shakti Bhawan, Rampur, Jabalpur-482008.	Copy for information

CEA (Office Case No.: MP-449			Ma	Scale:	1:50,0	00		•
DET (PTCC) Office Case No.: IC/MBI/PTCC/MP-598			Rot	ite Leng	gth: 24.	799 Kms		-
Railw	ay Office Case No.:			Ave	ra ge SI	R Value	: 75, <i>0</i> 0	Ohm cms	
Name	of Power Line LILO of one circuit of 400K	VS	atna (<u> </u> PGC	IL) –	Bina (1	PGCIL) lin	ie at	
S. No.	proposed 400KV S/s Sagar.		ength o				,	-! 	
	Para		ralleli		Mutual Coupling		Fault Current	Induce Voltage in	in
	SAGAR SSA	LEE	Kms.		in Ol	ıms	in Amps	Volts	
	SDOT Sagar	1		-					
(1)	Pathariya T/Exchange	\							
	Exch to Location (A) - 100, 50, 20 & 10 Pair	1							
(2)	University T/Exchange								-
	Exch to Location (A) -200, 100, 50, 20 & 10 Pair			پروان	-			-	Li
(3),	Parsoriya T/Exchange		-	<u> </u>	6		140	2 /	
-	Exch to Location (A) - 100, 50, 20 & 10 Pair			- V ·	C55	-7 19 c	M. 750		
(4)	Makronia T/Exchange	 	<u> </u>	· · · · ·		·	-]	
	Exch to Location (A) -800 Pair	<u> </u>	\mathcal{T}						
	Exch to Location (B) -400 Pair		 						
	Exch to Location (C) -200 Pair		1		-				
	Exch to Location (D) -100 & 50 Pair								
(5)	Sidguwan T/Exchange	<u> </u>	<u> </u>						
	Exch to Location (A) -100, 50, 20, 10 & 5 Pair		,					,	
(6)	Karrapur T/Exchange			-		·			
	Exch to Location (A) - 100, 50, 20, 10 & 5 Pair					0			
(7)	Banda T/Exchange			6	Jan				
:	Exch to Location (A) -400 Pair	1			1			<u> -</u>	
	Exch to Location (B) - 200 & 100 Pair	/			35			<u> </u>	· <u> </u>
		ř		सहा					
	Exch to Location (B) - 200 & 100 Pair Exch to Location (B) - 50 & 20 Pair			-	हराज मिन्नाव ह य विज्ञा	٠, -		\$5.1 (1.5.0F-1)	S 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1

के तथ के का प्राधिकरणां/ शिकुत सत्रालय/Ministry commer भारत सरकार/Govt. of maia सई दिल्ली/New Delhi-66

ANNEXURE - H

Case No Name of (PGCIL) Sagar (N	*: MP-449 If the Power line: LILO of one circuit of 4) to Bina (PGCIL) line at proposed 400 kV IPPTCL).	00 kV Satna Substation		: 1 cm=500 r : 24.799 km : 7,500 ohm	i.
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.

	Affected Blocks & Telecom Circuits I	Details		1	
1	Saugar to Makronia	Out of Parallelism			
2	Makronia to Lidhorakhurd	4.6	0.0014	11876	17
3	Lidhorakhurd to Girwar	0.3	0.0001	10253	01

तन्त्र/TANUJ सर्गार निश्वेत् II./Assit Directoriji र आय देवृत प्राधिकरणं/C.E.A. यित्त स्त्रान्य/Ministry:of Hower भारत नरकार/Govt. of India नह दिल्ली/New Date-56

Tele: 23019746

Armexure-III

TMP-4491

Directorate General of Signals Signals 7 General Staff Branch Integrated HQ of MoD, (Army) DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/1358/

2 Dec 2018

Chief Engineer (Procurement)
Madhya Pradesh PowerTransmission Co. Ltd.
Block No. 3, Shakti Bhawan, Rampur,
Jabalptir(M.P.)482008

PTCC ROUTE APPROVAL FOR CONSTRUCTION OF LILO OF ONE CIRCUIT OF 400KV SATNA (PGCIL)-BIN(PGCIL) LINE AT PROPOSED 400KV SUB-STATION SAGAR (MPPTCL)

- 1. Ref your letter No 04-01/ PTCC/2481/TR-I/8848 dt 14 Nov 2018. (copy att).
- 2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheet received under your letter mentioned above.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

Rawat

Мај

GSO 1 (Comin)

for SO-in-C

Enclosures: As above

Copy to :-

The Director (PTCC), CEA

Power Communication Development Division NRPC Complex, 18-A Shaheed Jeet Singh Marg Katwaria Sarai, New Delhi - 110016 for information.