



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

Case No. : MRA-1131: 4/16.06-21
PTCC proposal of LILO of both circuits of existing 220 kV D/C Waluj to Jalna line
at 400 kV Thaptitanada S/S : 7.689 km

Reference:		Dated
S. No.	Reference No.	
(i)	MSETCL: MSETCL/CO/PS/PTCC/No.06582	03.09.2019
(ii)	BSNL: IC/MBI/PTCC/MRA-2385/05	23.03.2021
(iii)	South Central Railway:SG.85/4/3/PTCC/SCRMH 201805 RC	30.07.2018
(iv)	Defense: B/46937/ Sigs 7(b)/587	06.07.2017

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide reference (ii) has intimated that there are no BSNL lines in the route of the proposed power line. South Central Railway vide reference (iii) has intimated that no railway line exists within 8 km vicinity of the proposed power line and given their consent for PTCC route approval for the proposed power line. The Defense Authority have accorded NOC vide above reference (iv) for this line. (A copy enclosed at Annexure) .

Taking above into consideration, necessary action regarding issuance of PTCC route approval may be taken.

Encl.: As above.

Signature Not Verified
Digitally signed by
RAGHENDRA PRATAP SINGH
Date: 2021.06.16 15:44:50 IST

Director

To,

1.	Divisional Engineer (PTCC), Western Zone	BSNL; Inspection Circle, 3 rd Floor, D-Wing, BSNL Admin Building, Juhu Tara Road, Santacruz (West), Mumbai-400054.	
2.	Chief Engineer (I/C), Project Schemes	MSETCL; Office of Chief Engineer (Projects Schemes Department), C.O., 'Prakashganga', P. No. C19, # E, BKC, Bandra (East), Mumbai-400051.	Copy for information

Mk

MPA - 1131

Annexure

Tele : 23019746

Directorate General of Signals
Signals - 7
General Staff Branch
Integrated HQ of MoD, (Army)
DHQ PO, New Delhi - 110011

B/46937/Sigs 7(b)/587/

06 Jul 2017

Superintending Engineer (Schemes - II)
"Prakashganga". Plot No. C-19,
'E' Block, Bandra Kurla Complex.
Bandra (East), Mumbai - 400051

**PTCC PROPOSAL FOR LILO ON BOTH CIRCUITS OF 220 KV WALUJ - JALNA LINE
AT 400 KV THAPTITANDA S/S, LENGTH = 7.689 KM**

1. Ref your letter No MSETCL/Tr.Pr/S-II/PTCC/B-548/5533 dt 25 May 2017.
2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheets received under your letter mentioned above.
3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(Bikram Kunwar)
Lt Col
GSO 1 (Comn)
for SO-in-C

Encls : (As above)

Copy to :-

✓ The Director (PTCC), CEA
Power Communication Development Division
NREB Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi - 110016

- for information.