



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

Case No. : RAJ-640:
PTCC proposal for LILO of both circuits of 765 kV D/C Fatehgarh (TBCB)- Bhadla (PG) line at Fatehgarh-2 Pooling Station (78.276 km)

Reference:		
S. No.	Reference No.	Dated
(i)	PGCIL : NR-I/FTH-I/LILO/PTCC/244	07.07.2020
(ii)	BSNL : DET/PTCC/ND/DV-9757/Raj-1275/2020-21	05.10.2020
(iii)	North Western Railway : SG/158/NWR/PTCC/779	28.07.2020
(iv)	Defense : B/46937/Sigs 7(b)/2099	21.10.2020

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide reference (ii) has intimated that there are no BSNL lines (copper cable and armored OFC) in the route of the proposed power line and has conveyed its NOC. North Western Railway in reference (iii) has intimated that there is no railway track within the vicinity of 8 km from the proposed power line and given their consent for PTCC route approval for the proposed power line. Defense has accorded NOC vide above reference (iv) for this line. Therefore, Induced Voltage calculation for the proposed line is not required.

Taking above into consideration, kindly take necessary action regarding issuance of PTCC route approval.

Digitally signed by RAGHUPENDRA PRATAP SINGH
Date: 2021.06.04 16:58:18 +05'30'

To,

Director

M/C

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001.	
2.	Power Grid Corporation of India Ltd.	765/400 kV Substation Construction Office, House No. 451, Achalvanshi Colony, Jaisalmer-345001.	Copy for information