



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

Case No.: RAJ-666:

PTCC proposal of 220 kV S/C Transmission Line from ReNew Sun Waves (Jaisalmer-I) 300 MW Solar Plant to PGCIL 765/400/220 kV Fatehgarh-II PS -regd

Reference:

Sl. No.	Reference No	Dated
(i)	M/s Renew Sun Waves Pvt Ltd: CEA/PTCC/RSWPL-300MW/01/01/2021	11.01.2021
(ii)	BSNL: DET/PTCC/ND/Raj-666/Renew/2021-2022	02.06.2021
(iii)	North Western Railway: SG/158/NWR/PTCC/809	01.02.2021
(iv)	Defense: B/46937/Sigs 7(b)/2312	16.03.2021

The PTCC proposal submitted vide ref. (i) has been examined. BSNL vide reference (ii) has intimated that there are no BSNL lines (copper cable and armored OFC) in the route of the proposed power line and has conveyed its NOC. North Western Railway vide reference (iii) has intimated that there is no railway track within the vicinity of 8 km from the proposed power line and given their consent for PTCC route approval for the proposed power line. Defense has accorded NOC vide above reference (iv) for this line. Therefore, Induced Voltage calculation for the proposed line is not required.

Taking above into consideration, kindly take necessary action for issuance of PTCC route approval.

Signature Not Verified
Digitally signed by
RAGHVENDRA PRATAP SINGH
Date: 2021.06.04 20:04:33 IST
Director

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001.	
2.	Vice President	Renew Sun Waves Pvt Ltd, Renew Hub, Commercial Block 1, Zone 6, Golf Course Road, DLF City Phase V, Gurugram - 122009	