



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
केन्द्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
विद्युत संचार विकास प्रभाग  
Power Communication Development Division

Case No.: RAJ-674 / 457-58	10.09.2021
PTCC proposal of 220 kV S/C transmission line from ReNew Sun Bright (Jaisalmer-II) 300 MW Solar Plant to PGCIL 765/400/220 kV Fatehgarh II PS, Jaisalmer (16.6 km)	

Reference:		
S. No.	Reference No.	Dated
(i)	M/s Renew Sun Bright Pvt Ltd: CEA/PTCC/RSBPL-300MW/01/07/2021	01.07.2021
(ii)	BSNL: DET/PTCC/ND/DV-9917/Raj-1323/2021-2022	22.07.2021
(iii)	North Western Railway: SG/158/NWR/PTCC/832	19.07.2021

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide above reference (ii) has intimated that there are no BSNL lines (copper cable and armoured OFC) in the route of the proposed power line and has conveyed its NOC. North Western Railway vide above reference (iii) has intimated that there is no railway track within the vicinity of the proposed power line and given its consent for PTCC route approval for the proposed power line.

Telecommunication details from Defense are pending and the power authority has shown urgency for the charging of the line. In view of this take necessary action regarding issuance of **Provisional PTCC approval for 220 kV S/C transmission line from ReNew Sun Bright (Jaisalmer-II) 300 MW Solar Plant to PGCIL 765/400/220 kV Fatehgarh II PS, Jaisalmer**

Signature Not Verified  
Digitally signed by RAGHUVENDRA PRATAP SINGH  
Date: 2021.09.10 17:50:27 IST

M/K

Director

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001.	
2.	Senior Engineer	M/s Renew Sun Brigh Pvt Ltd, 138, Ansal Chambers II, Bhikaji Cama Place, Delhi - 110066	Copy for information