

भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विदयत प्राधिकरण **Central Electricity Authority** विद्युत संचार विकास प्रभाग **Power Communication Development Division**

Case No.: TNG-105:

16.09.2021

PTCC proposal for LILO of 220 kV Gachibowli to Shapurnagar transmission line at proposed 400/220/132 kV Rayadurg GIS: 4.575 km

Reference:					
S. No.	Reference No.	Dated			
(i)	TSTRANSCO:CE/400kV/SE-II/400kV/D1-A4/F.e-EHVT-01/18/D.No. 728/20	15.10.2020			
(ii)	BSNL: SR-PTCC/STS-2865/05	28.07.2021			
(iii)	South Central Railway: SG.85/4/3/PTCC/SCRTS202115 RTD	31.03.2021			
(iv)	Defense: B/46937/Sigs 7(b)/2279	10.02.2021			

The PTCC proposal submitted vide reference (i) has been examined. The low frequency induction on telecom cables of BSNL and Block & Telecom circuits of South Central Railway with respect to details furnished vide above references (ii) and (iii) respectively has been computed. The voltages likely to be induced on paralleling telecom cables of BSNL and Block & Telecom circuits of South Central Railway under Single Line to Ground fault condition are enclosed at Annexure-I and Annexure-II respectively. The screening factors, as applicable, have been considered. Vide above reference (iv), Defence Authority have issued No Objection Certificate (NOC) (a copy enclosed as Annexure-III).

Taking above into consideration, necessary action for issuance of PTCC route approval may be taken.

Encl.: As above.

To,

Digitally signed by RAGHYENDRA PRATAP SINGH te: 2021.09.16 17:25:31 IST

Director

1.	Divisional Engineer (PTCC), Southern Zone	BSNL, Inspection Circle, 1st Floor, Raj Bavan Exchange No. 26, Sardar Patel Road, Guindy, Chennai-600032.	Annexure-I & Annexure-III
2.	SSTE/TELE/HQ	SCR, Head Quarters Office, Signal & Telcomm Branch, Rail Nilayam, Secunderabad-500025.	Annexure-II
3.	Chief Engineer/400 kV	TSTRANSCO, Vidyut Soudha,	Copy for

information

Hyderabad-500082.

Annexuse - I SSA: HYDERABAD TNG-105 Case No STS 2865 Name of the power line: Erection of LILO of 220 KV Gachibowli – Shapurnagar Line to the Proposed 400/220/132 KV Rayadurg GIS for 4.575 Kms with XLPE UG Cable (1000 sqmm). 4.575 Kms Length: Type of BSNL cable: PIJF Average SR value: 280:41 ohm -ms 30,000-20. LOP in MC in KIVIs Ohms FC in Amps IV in Volts SI.No. Name of Telecom line 1 (A) HYDGCB Exchange (Gachibowli) Exchange to Pillar 22 at Telecom Nagar (A-A1) 1 2 Exchange to Pillar 37 at Police Comm Offfice (A-A2) 3 Exchange to Pillar 38 at Jannardhan Hills (A-A3) 4 Exchange to Pillar 23 at Gachibowli X Road (A-A4) 5 Exchange to Pillar 25 at GPRA Campus (A-A5) 6 Exchange to Pillar 29 at Opp ILIT NR TCS Gate (A-A6) II (B) HYDSRT Exchnage (L&T infocity) Exchange to Pillar 00 Inner Zone (B-81) Exchange to Pillar 21 at Urdu University (B-B2) Exchange to Pillar 22 Opp SRT gate (B-B3) III (C) HYDKEV Exchange (Kendriya Vihar) Exchange to Pillar 00 Inner Zone (C-C1) 2 Exchange to Pillar 21 at NR Aditya DSR Gate (C-C2) Exchange to Pillar 22 at DLF Cyber 2 Gate (C-C3) HYDWTD Exchange (White Field) IV (D) Exchange to Pillar 00 Inner Zone (D-D1) Exchange to Pillar 37 Opp Jaya Residency (D-D2) 2 Exchange to Pillar 37A Opp Venkat Enclave (D-D3) 3 HYDAPS Exchange (APSP) V(E) Exchange to Pillar 28 at Police Betallion Main Gate (E-1 HYDMYP (Miyapur) Exchange
Exchange to Pillar No HYDMYP23 beside Miyapur Bus VI (F) 1 stop (E-E1) Exchange to Pillar No HYDMYP28 Allwyn Colony 2 entrance (E-E2) Exchange to Pillar No HYDMYP29 Allwyn Colony near 3 Udipi (E-E3) Exchange to Pillar No HYDMYP30 Mythrinagar kamaan 4 (E-E4) Exchange to Piliar No HYDMYP31 BHEL HIG Entrance (E-5 Exchange to Pillar No HYDMYP32 Madinaguda Main 6 Road (E-E6) Exchange to Pillar No HYDMYP38 Pragati Encl Classic 7 Avenue (E-E7) Exchange to Pillar No HYDMYP38A Friends colony 8 Entrance (E-E8) Exchange to Pillar No HYDMYP39 Opp. Bliss Bakers, 9 Mypr X Rds (E-E9) Exchange to Pillar No HYDMYP40 Near Sankranthi Hotel 10 Exchange to Pillar No HYDMYP41 JPN Nagar Nr X-Rd (E-11 Exchange to Pillar No HYDMYP42 JPN Nagar Main gate 12 (E-E12) 13 Exchange to Pillar No HYDMYP44 Mayuri Nagar (E-E13) 14 Exchange to Pillar No HYDMYP45 BK Enclave (E-E14) Exchange to Pillar No HYDMYP46 Coco Cola X-Rds (E-15 16 Exchange to Pillar No HYDMYP49 Kendriya Vihar (E-E16) Exchange to Pillar No HYDMYP50 SMR Metropolis Apts, 17 Mypr (E-E17) 4 Exchange to Pillar No HYDMYP56 Janapriya Apts Ph-V (E-18

Exchange to Pillar No HYDMYP61 Hemadurga Towers BL-

Exchange to Pillar No HYDMYP62 Hemadurga Towers BL-

19

C (E-E19)

C (E-E20)

120,000

EMPHILATO

4784

gran & A

the state of the state of

ANNEXURE -II

CEA Case No.: TNG-105

Name of the Power line: LILO of 220 kV Gachibowli to Shapurnagar transmission line at proposed 400/220/132 kV

Rayadurg GIS.

Map Scale : 1 cm=500 m Total Length : 4.575 km Soil Resistivity : 30,000 ohm-cm

S.No. Telecom. Details Pa	ength of mutual rallelism Coupling in Ohms in Ampe	LV in Volt
---------------------------	--	------------------

	South Central Railway letter no:- SG.85/4/3/PTCC	C/SCRTS20211	5 RTD Date	ed:31.03.202	21		
S.No	Affected Blocks & Telecom Circuits Details						
1.	Telapur to Ramachandrapuram TS	Outside IV Consideration Zone			00		
2	Telapur to Lingampalli	0.7	0.00001	8312	01		
3	Lingampalli to Hafizpet	Out of Parallelism		00			
4	Hafizpet to Santhnagar	1.9	0.00012	8678	01		
5	Santhnagar to Hussain Sagar Jn.	Out of Parallelism			00		
6	Santhnagar to Ammuguda	Out of Parallelism			00		

Tanny

The second of the secon

Tele : 23019746

Annexure - III
TNG-105 Sig

Directorate General of Signals

Signals - 7

General Staff Branch

Integrated HQ of MoD, (Army) DHQ PO, New Delhi – 110011

B/46937/Sigs 7(b)/2279

^{↑O} Feb 2021

Chief Engineer, (400kV)
TSTRANSCO
Transmission Corporation of Telangana Limited
Vidyut Soudha,
Hyderabad – 500 082

ERECTION OF RAYADURG SYSTEM IMPROVEMENT SCHEME-SUPPLY, ERECTION, TESTING AND COMMISSIONING OF 400/220/132KV GIS AT RAYADURG AND CONNECTED NETWORK ON TURNKEY BASIS-LILO OF 220KV GACHIBOWLI-SHAPURNAGAR LINE TO PROPOSED 400/220/132KV RAYADURG GIS WITH 220KV 1000SQMM XLPE UG CABLE FOR A LENGTH OF 4.575KMS-PTCC PROPOSALS-FORWARDED-REG.

- 1. Refer your letter No Lr. No. CE/400kV/SE-II/400kV/D1-A4/F.e-EHVT-01/18/D.No. 728/20 dt 15 Oct 2020 (copy att).
- 2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheets received under your above mentioned letter.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(A Rawat) Maj GSO 1 (Comn) for SO-in-C

Enclosures : (As above)

Copy to :-

The Director (PTCC), CEA

Power Communication Development Division

NRPC Complex, 18-A Shaheed Jeet Singh Marg

Katwaria Sarai, New Delhi – 110016

The DET(PTCC), Northern Zone
O/o PGM (North), QA & Inspection Circle,
D-Tax-Building, Eastern Court, Janpath
New Delhi-110001

for information

145°

25/2 25/2

विश्वत प्राप्त के अपने के अपन