



भारत सरकार
Government of India
 विद्युत मंत्रालय
Ministry of Power
 केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
 विद्युत संचार विकास प्रभाग
Power Communication Development Division

Case No.: UTR-24	07/09/21
PTCC proposal for 220 kV D/C Pithoragarh to Jauljibi transmission line: 24.01 km	

Reference:		
S. No.	Reference No.	Dated
(i)	PGCIL:NR3/JJB/TL-KPTL/301/2018-19	07.06.2019
(ii)	BSNL : DET/PTCC/ND/DV-9473/UTR-34/2019-2020	01.07.2019
(iii)	North Eastern Railway : N/242/0(Tele) PTCC Pt-II/958	29.01.2020
(iv)	Defense : B/46937/Sigs 7(b)/2167	04.12.2020
(v)	CM, PGCIL 400/220 kV GIS Jauljibi, Pithoragarh mail dated 02.09.2021	

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide reference (ii) has intimated that there are no BSNL lines (copper cable and armored OFC) in the route of the proposed power line and has conveyed its NOC. North Eastern Railway vide reference (iii) has intimated that there is no railway line appearing/existing in the route of the proposed power line. Hence, IV calculation for BSNL and North Eastern Railway is not required. The Defense Authority vide reference (iv) intimated that Defense telecommunication cables is falling within 8 km of the proposed power line but does not provide duly marked telecom details in topo-map. However, power authority shown urgency for charging of the proposed power line vide reference (v).

In view of this, necessary action regarding issuance of **provisional PTCC route approval for 220 kV D/C Pithoragarh to Jauljibi transmission line** may be taken.

Digitally signed by RAJESH KUMAR TIKTAP SINGH
Date: 2021.09.07 12:22:45 IST

Director

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001.	
2.	Maj GSO I(Comn)	Directorate General of Signals, Signals 7, General Staff Branch, Integrated HQ of MoD, (Army), DHQ PO, New Delhi-110011	To provide marked telecom details on topo-map for IV calculation.
3.	Asst. Manager	PGCIL, Jauljibi, 400/220 kV GIS Bagrihat, P.O. Jauljibi, Dist.-Pithoragarh-262544.	With an instruction to follow-up for Defense telecom details.

MIC