



सत्यमेव जयते

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

CEA Case No.: MRA-1164 / 510 - 512
PTCC proposal for 220 kV D/C Umred to Nagbhid transmission line: 51.255 km

Reference:		
S. No.	Reference No.	Dated
(i)	MSETCL: MSETCL/CO/PS/PTCC/220kV/LD/B-570/No.2356	01.07.2020
(ii)	BSNL: IC/MBI/PTCC/MRA-2464	13.08.2021
(iii)	South East Central Railway: SECR/S&T/PTCC/TD/1022	04.01.2021
(iv)	Defense: B/46937/Sigs 7(b)/2153	21.10.2020

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on telecom cables of BSNL and Block & Telecom circuits of South East Central Railway with respect to details furnished vide above references (ii) and (iii) respectively has been computed. The voltages likely to be induced on paralleling telecom cables of BSNL and Block & Telecom circuits of South East Central Railway under Single Line to Ground fault condition are enclosed at Annexure-I and Annexure-II respectively. The screening factors, as applicable, have been considered. The Defense Authority have accorded NOC vide above reference (iv) for the proposed power line. (a copy enclosed at Annexure-III)

Taking above into consideration, necessary action regarding issuance of PTCC route approval may be taken.

Encl.: As above.

Signature Not Verified
Digitally signed by RAGHUVENDRA PRATAP SINGH
Date: 2021.10.25 12:30:16 IST

Director

To,

1.	Divisional Engineer (PTCC), Western Zone	BSNL; Inspection Circle, 3 rd Floor, D-Wing, BSNL Admin Building, Juhu Tara Road, Santacruz (West), Mumbai-400054.	Annexure-I & Annexure-III only
2.	Dy.CSTE/Telecom	South East Central Railway; O/o Principal Chief Signal & Telecom Engineer, 2 nd floor, SECR Zonal Hq Building, Bilaspur-495004.	Annexure-II only
3.	Chief Engineer (Projects Schemes)	MSETCL; O/o Chief Engineer, Projects Schemes Department, "Prakashganga", Plot No. C-19, E Block, Bandra-Kurla Complex, Bandra (East), Mumbai-400051.	Copy for information

MIC

CEA office case No.: MRA-1164

Map scale : 1:50000

(Annexure-I)

DFT (PTCC) office case No:

Route length : 51.25kms

Railway office case No.:

Soil resistivity : 7,500 Ω cm

Name of the power line:

220 KV Umred-Nagbhid D/C line, length=51.25 kms

Sr. No.	Name of the Telecom Line / cable	Length of Parallelism in Kms.	Mutual Coupling in Ohms	Fault Current in Amps	Induced Voltage in Volts
1	Umred to Bhinwapur				
2	24 pr OFC UG WTR N/W	Point of crossing at Road side	} IV less than 430 V		
3	Umred Telephone Exge	4.37 kms			
4	Nagbhid OFC cable - along roadside				
5	Nagbhid Tel. exchange - (copper cable)	3.0 kms from Nagbhid exch. toward west direction			
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					

ANNEXURE-II

Case No.: MRA - 1164

Name of the Power line: 220 kV D/C Umred to Nagbhid transmission line.


Map Scale : 1 cm=500 m
 Total Length : 51.255 km
 S.R. Value : 7,500 ohm-cm

S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
-------	------------------	------------------------------	--------------------------	----------------------------------	---------------

South East Central Railway Ref. No: SECR/S&T/PTCC/TD/1022 Dated: 04.01.2021

Affected Blocks & Telecom Circuits Details

1	Kuhi to Umrer	1.1	0.0014	9803	14
2	Umrer to Bhiwapur	11.8	0.0021	8039	17
3	Bhiwapur to Nagbhir	18.8	0.0067	8822	59
4	Brahmapuri to Nagbhir	Out of Parallelism			00
5	Nagbhir to Talodhi Road	Out of Parallelism			00



संस्था/TA/11
 सहायक नि.स.डी/अस. नि.स.डी
 राज्य स.स. नि.स.डी
 नि.स.डी/Ministry of
 भारत सरकार/Govt. of India
 नई दिल्ली/New Delhi-60

Tele : 23019746

(Annexure-III)

MRA-1164

Directorate General of Signals
Signals 7
General Staff Branch
Integrated HQ of MoD (Army)
DHQ PO, New Delhi - 110011

B/46937/Sigs 7(b)/2153/

Office of the Superintending Engineer,
Projects Schemes Department
Maharashtra State Electricity Transmission Company Ltd
"Prakashganga", Plot No C-19, 'E' Block,
Bandra - Kurla Complex, Bandra (East),
Mumbai-400051

21 Oct 2020

PTCC PROPOSAL FOR 220KV UMRED-NAGBHID DC LINE,LENGTH=51.25KMS

1. Ref your letter No MSETCL/CO/PS/PTCC/220kV/LD/B-570/No 2356 dt 01 Jul 2020 (copy att).
2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheets received under your letter mentioned above.
3. Documents alongwith map sheets (in original) are forwarded herewith for your further action.



(A-Rawat)
Maj
GSO 1 (Comn)
for SO-in-C

Enclosures : As above

Copy to :-

✓ The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi - 110016

✓ The DET (PTCC), Northern Zone
O/o PGM (North), QA & Inspection Circle,
D-Tax Building, Janpath
New Delhi-110001

for information