

भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण **Central Electricity Authority** विद्युत संचार विकास प्रभाग Power Communication Development Division

CEA Case No.: UP-552 5 0 5 - 507 PTCC proposal of 220 kV D/C Gorakhpur (PG) - Maharajganj transmission line (83.376 km)

Reference:		Dated	
S. No.	Reference No.	22.01.2021	
(i)	UPPTCL: 201/ETD-II(G)/	06.09.2021	
	BSNL: DET/PTCC/ND/DV-9946/UP-989/2021-2022		
(ii)_	North Eastern Railway: NER-HQ0SndT(TELE)/31/2020-	25.02.2021	
(iii)	O/O PCSTE/HQ/NER	12.01.0001	
	D/46037/Sign 7(h)/2336	13.04.202	
(iv)	Defense: B/46937/Sigs 7(b)/2336		

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide above reference (ii) has intimated that there are no BSNL lines (copper cable and armoured OFC) in the route of the proposed power line and has conveyed its NOC. The low frequency induction on block & telecom circuits of North Eastern Railway as per details furnished vide reference (iii) has been examined. Voltages likely to be induced on paralleling block & telecom circuits of North Eastern Railway under single line to ground fault condition are enclosed at Annexure-I. The screening factors as applicable have been considered. Vide ref. (iv) above, Defense have conveyed No Objection Certificate (a copy enclosed as Annexure-II).

Taking above into consideration, take necessary action for issuance of PTCC route approval.

Encl.: As above.

Signature Not Verified

Digitally signed by RAGHVPNDRA PRATAP SINGH Date: 2021, 10, 25 13:27:54 IST

Director

To 1.	_ .	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001.	Only
2	Dy. CSTE/ Tele	North Eastern Railway, Office of the General Manager (S&T), Gorakhpur	Annexure -I
3	. Executive Engineer	UPPTCL, Electricity Transmission Division-II, Balli Plant, Mohaddipur, Gorakhpur	Copy for informati on

ANNEXURE – I

CEA Case No.: UP-552

Name of the Power Line: 220 kV D/C Gorakhpur (PG) –

Maharajganj transmission line

Map Scale : 1 cm = 500 m. Route Length: 83.376 km

Soil Resistivity: 20,000 Ohm-cm

S.No.	Telecom Details	Length of Parallelism (in km)	Mutual Coupling (Ohms)	Fault Current (Amps)	Induce d Voltage (Volts)	
Ĭ]	<u> </u>	<u>-</u>		

	NORTH EASTERN RAILWAY Ref. No: NER-HQ0SndT(TELE)/31/2020-O/O PC	STE/HQ/N	ER dated 25.02	2.2021	
	Affected Blocks & Telecom Circuits Details				
	Sahjanwa Rly Station to Khalilabad Rly Station	4.5	0.0056	8800	49
$-\frac{1}{2}$	Nakha Jungle Rly Station to Campierganj Rly	8.3	0.0093	7100	66
_	Station				

明何 前門では、PRATEEK SENASTAWA 明何時 前門では、JASSAL Corector-II 市場は 下記です。対応がかって、E.A. 市場は 特別で、AMINISTRY of Power 年間で、特別では、AMINISTRY of Power 事情で、特別では、AMINISTRY of India 事情で、特別では、AMINISTRY of India 事情で、特別で、AMINISTRY of India

Directorate General of Signals
Signals 7
General Staff Branch
Integrated HQ of MoD, (Army)
DHQ PO, New Delhi – 110011

8/46937/Sigs 7(b)/2336/

(3 Apr 2021

Office of the Executive Engineer Electricity Transmission Division-II U.P. Power Transmission Corporation Limited Balli Plant, Mohaddipur, Gerakhpur-273008

PROPOSAL FOR PTCC CLEARANCE FOR 220KV D/C PG GORAKHPUR-MAHRAJGANJ TRANSMISSION LINE

- Refer your letter No 200 ETO-II(S)/ dt 22 Jan 2021. (copy att).
- No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheet received under your letter mantioned above
- Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(A Rawat) Lt Col GSO 1 (Gomn) for SO-in-C

Enclosures : As above

Copy to :-

Tric Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeat Singh Marg
Katwaria Sarai, New Delhi - 110016

The DET(PTCC), Northern Zone O/o PGM (North), QA & Inspection Circle, D-I ax Building, Eastern Court, Janpath New Delhi-110001 for information