



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
केन्द्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
विद्युत संचार विकास प्रभाग  
Power Communication Development Division

CEA Case No.: UP-563 / 508-09  
PTCC proposal of 220 kV DC Hardoi Road (220 kV) – Hardoi Road (400 kV)  
transmission line (9.911 km)

Reference:		
S. No.	Reference No.	Dated
(i)	UPPTCL: 1142/ETD(I)/L/220 KV line	06.07.2021
(ii)	BSNL: DET/PTCC/ND/DV-9942/UP-986/2021-2022	06.09.2021
(iii)	North Eastern Railway: NER-HQ0SndT(TELE)/31/2020- O/O PCSTE/HQ/NER	11.10.2021
(iv)	Defense: B/46937/Sigs 7(b)/2502	26.08.2021

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide above reference (ii) has intimated that there are no BSNL lines (copper cable and armoured OFC) in the route of the proposed power line and has conveyed its NOC. Vide ref. (iii) above, North Eastern Railway has intimated that there are no railway signaling and telecom circuits within the corridor of 8 kms of the proposed transmission line and has conveyed its NOC. Vide ref. (iv) above, Defense have conveyed No Objection Certificate.  
Taking above into consideration, take necessary action for issuance of PTCC route approval.

Signature Not Verified  
Digitally signed by RAGHUVENDRA PRATAP  
SINGH  
Date: 2021.10.25 13:29:48 IST

Director

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D- Tax Building, Eastern Court, Janpath, New Delhi 110001.	
2.	Executive Engineer	UPPTCL, Electricity Transmission Division-I, Room no. 115-120, Paresan Bhawan, Vibhuti Khand-II, Near Mantri Awas, Gomti Nagar, Lucknow – 226010	Copy for informati on