



भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
केन्द्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
विद्युत संचार विकास प्रभाग  
Power Communication Development Division

CEA Case No.: GUJ-807
PTCC proposal of 220 kV S/C line from existing 400 kV Charanka S/S to M/s Renew Solar Pvt Ltd (Eval) Solar Plant line (12.400 km)

Reference:		
S. No.	Reference No.	Dated
(i)	GETCO: CE(Project)/SE(Planning)/5320	16.12.2020
(ii)	BSNL: IC/MBI/PTCC/GJ-2849	12.03.2021
(iii)	Western Railway: SG 158/28/12/1142	02.02.2021
(iv)	Defense: B/46937/Sigs 7(b)/2268	10.02.2021

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide above reference (ii) has intimated that there are no BSNL telecom lines or telephone exchanges within the 8 km corridor of the proposed power line. Vide ref. (iii) above, Western Railway has intimated that Western Railway lines are out of 8 km area of proposed power line and has conveyed its clearance from S&T point of view. Vide ref. (iv) above, Defense have conveyed No Objection Certificate (enclosed as Annexure).

Taking above into consideration, take necessary action for issuance of PTCC route approval.

Encl.: As above.

Digitally signed by RAGHENDRA PRATAP SINGH  
Date: 2021.12.06 15:39:53 IST

Director

To,

1.	Divisional Engineer (PTCC), Western Zone	Bharat Sanchar Nigam Limited (BSNL), 1 <sup>st</sup> Floor, D-Wing, BSNL Admin Building, Juhu Tara Road, Santacruz (West), Mumbai-400054	
2.	Chief Engineer (Project)	GETCO, Sardar Patel Vidyut Bhavan, Race Course, Vadodara - 390007	Copy for information

MIC

Tele : 23019746

GUT-807 (Annexure)

Directorate General of Signals  
Signals 7  
General Staff Branch  
Integrated HQ of MoD, (Army)  
DHQ PO, New Delhi - 110011

B/46937/Sigs 7(b)/2268/

10 Feb 2021

Chief Engineer (Project)  
Gujarat Energy Transmission Corporation Ltd  
Sardar Patel Vidyut Bhawan  
Race Course, Vadodara - 390 007

SUBMISSION OF PROPOSAL FOR HV/EHV TRANSMISSION LINE OF GETCO  
FOR PTCC APPROVAL OF 220KV S/C LINE FROM 400KV CHARANKA S/S TO  
M/S RENEW SOLAR PVT LTD (EVAL) SOLAR PLANT LINE

1. Refer your letter No CE(Project)/SE(Planning)/5320 dt 16 Dec 2020 (copy att).
2. No Objection Certificate (NOC) is accorded based on inputs provided vide Map sheets received under your letter mentioned above.
3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(A Rawat)  
Maj  
GSO 1 (Comn)  
for SO-in-C


Enclosures : As above

Copy to :-

The Director (PTCC), CEA  
Power Communication Development Division  
NRPC Complex, 18-A Shaheed Jeet Singh Marg  
Katwaria Sarai, New Delhi - 110016

The DET(PTCC), Northern Zone  
O/o PGM (North), QA & Inspection Circle  
D-Tax-Building, Eastern Court, Janpath  
New Delhi-110001

for information



1-2268  
DATE 18/2/21  
20/2/21