



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

CEA Case No. : MRA-1181 / 310-312
PTCC proposal of 400 kV D/C LILO on Talegaon - Kalwa line at 400 kV Vikhroli GIS substation (12.103 km)

Reference:		
S. No.	Reference No.	Dated
(i)	M/s Kharghar Vikhroli Transmission Pvt Ltd.: KVTPL/21-22/290621-01	29.06.2021
(ii)	BSNL: IC/MBI/PTCC/MRA-2510	31.01.2022
(iii)	Central Railway: N.153/PTCC/220kV/MAH-780	26.08.2021
(iv)	Defense: B/46937/ Sigs 7(b)/2465	04.08.2021

The PTCC proposal submitted vide reference (i) has been examined. The LF induction on telecom cables of BSNL and block & telecom circuits of Central Railway with respect to details furnished vide above reference (ii) & (iii) respectively has been computed. The voltages likely to be induced on paralleling telecom cables of BSNL and block & telecom circuits of Central Railway under Single Line to Ground fault condition are enclosed at Annexure-I & II respectively. The screening factors, as applicable, have been considered. Vide reference (iv) above, The Defence Authority have issued No Objection Certificate (NOC) (a copy enclosed as Annex-III).

Taking above into consideration, necessary action regarding issuance of PTCC route approval may be taken.

Encl.: As above.

अधिवेन्द प्रताप सिंह
Director 28.03.22

To,		
1.	Divisional Engineer (PTCC), Western Zone	BSNL; Inspection Circle, 3 rd Floor, D-Wing, BSNL Admin Building, Juhu Tara Road, Santacruz (West), Mumbai-400054.
2.	GM(S&T)	Central Railway, O/o Principal Chief Signal and Telecom Engineer, 3 rd Floor, Annex Building, CSMT Mumbai - 400001
3.	M/s Kharghar Vikhroli Transmission Pvt Ltd	AEMI, Opp SEEPZ Gate No. 3, JVLR, Goregaon (East), Mumbai - 400065

File No.CEA-PS-17-11/1/2022-PCD Division



75
आजादी का
अमृत महोत्सव

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

के.वि.प्रा. केस सं. : MRA-1181 / 310-312
पी.टी.सी.सी. प्रस्ताव 400 kV D/C LILO on Talegaon – Kalwa line at 400 kV Vikhroli GIS substation (12.103 km)

क्रमांक	सन्दर्भ सं.	दिनांक
(i)	M/s Kharghar Vikhroli Transmission Pvt Ltd.: KVTPL/21-22/290621-01	29.06.2021
(ii)	BSNL: IC/MBI/PTCC/MRA-2510	31.01.2022
(iii)	Central Railway: N.153/PTCC/220kV/MAH-780	26.08.2021
(iv)	Defense: B/46937/ Sigs 7(b)/2465	04.08.2021

संदर्भ (i) द्वारा प्रस्तुत पीटीसीसी प्रस्ताव की जांच की गई है। बीएसएनएल के टेलिकॉम केबलों एवं मध्य रेल के क्लॉक एवं टेलिकॉम सर्किटों पर निम्न आवृत्ति प्रेरण गणना क्रमशः उपरोक्त संदर्भ (ii) एवं (iii) में दिए गए विवरणों के संबंध में की गई है। सिंगल लाइन टू ग्राउंड फाल्ट अवस्था में समानांतर बीएसएनएल के टेलिकॉम केबलों एवं मध्य रेल के क्लॉक एवं टेलिकॉम सर्किटों पर प्रेरित वोल्टेज क्रमशः अनुलग्नक -I एवं II में संलग्न है। स्क्रीनिंग कारक का मान यथानुरूप लिया गया है। रक्षा प्राधिकरण ने उपरोक्त संदर्भ (iv) के द्वारा अनापत्ति प्रमाण पत्र जारी किया है (अनुलग्नक- III में संलग्न)।

उपरोक्त को ध्यान में रखते हुए, पीटीसीसी मार्ग अनुमोदन जारी करने के संबंध में आवश्यक कार्रवाई की जाए।

संलग्न: उपरोक्त अनुसार

राधेन्द्र गुप्ता सिंह
28.03.22
निदेशक

To,

1.	Divisional Engineer (PTCC), Western Zone	BSNL; Inspection Circle, 3 rd Floor, D-Wing, BSNL Admin Building, Juhu Tara Road, Santacruz (West), Mumbai-400054.	
2.	GM(S&T)	Central Railway, O/o Principal Chief Signal and Telecom Engineer, 3 rd Floor, Annex Building, CSMT Mumbai – 400001	Annex-II only
3.	M/s Kharghar Vikhroli Transmission Pvt Ltd	AEMI, Opp SEEPZ Gate No. 3, JVLR, Goregaon (East), Mumbai – 400065	Copy for info

CFA Case No. MRA-1181

400 KV O/LICO on Talegaon - Kalasa line at Talegaon

GR: 30,000 A-cm
 length: 12.03 km
 length of 400KV VIKRANTU CIS SL

Annex-I

MTNL Cable Details - Ashish RSU to Talegaon - Kalasa line (21.6 km)

Sr. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/Stretch	No of Pillars affected
Z-2	AM(SION/WDL)	SION	Primary	1	1200	1500	pratekha nager Stion, 914, 918	2	
Z-2	AM(SION/WDL)	SION	Primary	1	1200	1500	Blk-08, N S Mankikar marg	4	
Z-2	AM(SION/WDL)	SION	Primary	1	1200	1000	Blk-09, 906, 905	2	
Z-2	AM(SION/WDL)	SION	Primary	1	2400	1500	Blk-09, 903, 909, 910	3	
Z-2	AM(SION/WDL)	SION	Primary	1	2000	1000	Blk-09, 911, 912	2	
Z-2	AM(SION/WDL)	SION	Primary	1	2000	1500	Blk-09, 911, 913, 912	3	
Z-2	AM(MKCD-CHM)	MANKHURD	Primary	2	2000	2500	Blk-10	4	
Z-2	AM(MKCD-CHM)	MANKHURD	Primary	2	2000	4000	MANKHURD EXCH-TATA NAGAR-DEONAR MUNGIPAL COLONY	2	
Z-2	AM(MKCD-CHM)	MANKHURD	Primary	2	2000	5000	MANKHURD EXCH-TELECOM FACTORY- PANJRAPOLE- DUKES COMPANY- GOVANDI RLY BRIDGE-BMC ABBATOR- BMC M EAST WARD-SHIVAJI RSU	6	
Z-2	AM(MKCD-CHM)	MANKHURD	Primary	1	2000	5000	MANKHURD EXCH-TELECOM FACTORY-BARC FLY OVER-RLY BRIDGE-PMGP COLONY	2	
Z-2	AM(MKCD-CHM)	ASHISH RSU	Primary	1	2000	2000	ASHISH TO DONGRI PARK-GAT NO3		
Z-2	AM(MKCD-CHM)	ASHISH RSU	Primary	1	2000	3000	ASHISH TO TOLARAM COLLECTOR COLONY		
Z-2	AM(MKCD-CHM)	ASHISH RSU	Primary	1	1200	2000	ASHISH TO MYSORE COLONY		

IV less than 480V

Proteck

ಶಿಲ್ಪಾ ಶರಣ್/Pranika Shrivastava
 Manager/Pratt-2/Asstt. Director-II
 ಸಹಾಯಕ ನಿರ್ದೇಶಕರು/ಸಹಾಯಕ ನಿರ್ದೇಶಕರು/C.E.A.
 ಪುಣೆ ಪ್ರಾಂತ್ಯ/Ministry of Power
 ಸರ್ಕಾರ/GOVT. of India
 ಪುಣೆ, ಮಹಾರಾಷ್ಟ್ರ

Sr. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/Stretch	No of Pillars effected
Z-2	AM(MKD-CHM)	ASHISH RSU	Primary	1	800	1500	ASHISH TO MYSORE CONONY	32	
Z-2	AM(MKD-CHM)	CHBT RSU	Primary	2	2000	1500	CHUNABHATTI - HANUMAN MANDIR - QURESHI NAGAR		
Z-2	AM(MKD-CHM)	CHBT RSU	Primary	2	2000	1500	CHUNABHATTI - HANUMAN MANDIR - AMBIKA NAGAR		
Z-2	AM(MKD-CHM)	CHBT RSU	Primary	2	2000	1500	CHUNABHATTI - HANUMAN MANDIR - LABOUR COURT		
Z-2	AM(MKD-CHM)	ASNR RSU	Primary	2	2000	500	ANUSHAKTI NAGAR EXCH--ANUSHAKTI NAGAR MAIN GATE	16	
Z-2	AM(MKD-CHM)	ASNR RSU	Primary	1	2000	1000	ANUSHAKTI NAGAR EXCH --KAMET MARKET	4	
Z-2	AM(MKD-CHM)	ASNR RSU	Primary	1	2000	1500	ANUSHAKTI NAGAR EXCH--ANUSHAKTI NAGAR GATE NO. 6	2	
Z-2	AM(MKD-CHM)	ASNR RSU	Primary	1	2000	2000	ANUSHAKTI NAGAR EXCH--TROMBAY POLICE STATION	2	
Z-2	AM(MKD-CHM)	ASNR RSU	Primary	1	2000	2000	ANUSHAKTI NAGAR EXCH--RAG MALA GARDEN	7	
Z-2	AM(MKD-CHM)	UNPK RSU	Primary	1	2000	1000	UNION PARK EXCH -- CHEMBUR NAKA	1	
Z-2	AM(MKD-CHM)	UNPK RSU	Primary	1	2000	2000	UNION PARK EXCH -- CHEMBUR NAKA	4	
Z-2	AM(MKD-CHM)	UNPK RSU	Primary	1	2000	2500	UNION PARK EXCH -- CHEMBUR RAILWAY STATION	4	
Z-2	AM(MKD-CHM)	UNPK RSU	Primary	1	2000	2000	UNION PARK EXCH -- CHEMBUR CAMP	3	
Z-2	AM(MKD-CHM)	CHM	PIUF	1	800	1200	Chembur	6	
Z-2	AM(MKD-CHM)	CHM	PIUF	1	2400	1500	Chembur	3	
Z-2	AM(MKD-CHM)	CHM	PIUF	1	2400	1500	Chembur	5	

Prateek

IV less than 480V

श्रीक श्रीकांत/PRATEEK SRMASTAVA
 सहायक निदेशक-II/Asstt. Director-II
 केन्द्रीय विद्युत, मंत्रालय/C.E.A.
 विद्युत मंत्रालय/Ministry of Power
 भारत सरकार/Govt. of India
 नई दिल्ली/New Delhi

Sr. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/ Stretch	No of Pillars effected
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	2000	1400	Chembur	4	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	2400	1700	Chembur	5	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	1200	1200	Chembur	3	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	2000	1100	Chembur	3	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	1200	1500	Chembur	2	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	2000	1800	Chembur	4	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	800	1400	Chembur	2	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	1200	1700	Chembur	3	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	2000	1200	Chembur	3	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	1200	1100	Chembur	2	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	1200	1500	Chembur	4	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	1600	1500	Chembur	2	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	1200	1400	Chembur	3	

IV legs
from 430V

Prabek

तरीक श्रीवर्मा/PRADEEK SRIVASTAVA
 प्रमुख निरीक्षक-II/Asstt. Director-II
 क्षेत्रीय विद्युत निरीक्षक/C.E.A.
 विद्युत विभाग/Ministry of Power
 भारत सरकार/Govt. of India
 नई दिल्ली/New Delhi

Sr. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/Stretch	No of Pillars effected
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	1200	1700	Chembur	3	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	800	1200	Chembur	3	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	2000	1100	Chembur	3	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	2000	1500	Chembur	4	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	1600	1800	Chembur	4	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	800	1100	Chembur	4	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	2000	1700	Chembur	3	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	1200	1200	Chembur	3	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	2000	1100	Chembur	2	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	2000	1200	Chembur	5	
Z-2	AM/(MKD-CHM)	CHM	PIUF	1	1600	1100	Chedda Nagar	4	
Z-2	AM/(MKD-CHM)	PLL	PIUF	1	1600	1500	Chedda Nagar	2	
Z-2	AM/(MKD-CHM)	PLL	PIUF	1	1600	1400	Chedda Nagar	2	
Z-2	AM/(MKD-CHM)	PLL	PIUF	1	1600	1700	Chedda Nagar	2	

IV legs
from 430V

Prateek

श्रीक श्रीवास्तव / PRATEEK SRIVASTAVA
 डिप्टी निदेशक-II / Asstt. Director-II
 बिजली विभाग, बिहार सरकार / C.E.A.
 बिहार बिजली विभाग / Ministry of Power
 भारत सरकार / Govt. of India
 नई दिल्ली / New Delhi

Sl. No.	Zone	AREA MANAGER	Exch./RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/Stretch	No. of Pillars effected
Z-2		AM(MKD-CHM)	PLL	PUF	1	1600	1700	Chedda Nagar	3
Z-2		AM(MKD-CHM)	PLL	PUF	1	1600	1200		2
Z-2		AM(MKD-CHM)	PLL	PUF	1	1600	1100		2
Z-2		AM(MKD-CHM)	PLL	PUF	1	1600	1500		3
Z-2		AM(MKD-CHM)	PLL	PUF	1	1600	1400		2
Z-2		AM(GKP-PWI)	HINGWALA RSU	Primary	16	2000	1300	90 ft rd via M G ROAD TILAK ROAD R B Mehta Rd VALLABH Bang Lane and Hingwala Lane	38
Z-2		AM(GKP-PWI)	GARODIA NAGA	Primary	7	2000	1300	90 ft rd Barrister Nath Pai Rd and Railway Qr's Samata Colony	19
Z-2		AM(GKP-PWI)	GKP Exch.	Primary	3	2000 to 2400	3000	GKP Exch. To Khol Rd. Vidhyavihar (W)	6
Z-2		AM(GKP-PWI)	GKP Exch.	Primary	1	2000 pair ca	4000	GKP Exch. To Nathani Rd. & Premiere Rd. Vidhyavihar (W)	3
Z-2		AM(GKP-PWI)	GKP Exch.	Primary	4	2000 to 2400	4000	GKP Exch. To JMM Rd., Kairani	11
Z-2		AM(GKP-PWI)	GKP Exch.	Primary	5	1200 to 2400	5000	GKP Exch. To Link Rd. Sakinaka	14
Z-2		AM(GKP-PWI)	GKP Exch.	Primary	2	1200 to 2400	4000	GKP Exch. To Narayan Nagar & Asalpa, LBS Rd.	6
Z-2		AM(GKP-PWI)	GKP Exch.	Primary	2	1200 pair ca	3000	GKP Exch. To Chirag Nagar & Azad Nagar, LBS Rd.	3
Z-2		AM(GKP-PWI)	GKP Exch.	Primary	2	2400 pair ca	3000	GKP Exch. To Kamani, LBS Rd.	4

IV less than 430V

Protest

श्री. श्रीमती/PRATEEK SRIVASTAVA
 सहायक निदेशक-II/Asstt. Director-II
 केन्द्रीय विद्युत प्राधिकरण/C.E.A.
 विद्युत विभाग/Ministry of Power
 भारत सरकार/Govt. of India
 नई दिल्ली/New Delhi

Sr. No.	Zone	AREA MANAGER	Exch./RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/Stretch	No of pillars effected
Z-2		AM(GKP-PWJ)	GKP Exch.	Primary	3	1200 to 2400	3000	GKP Exch. To Jagdusha Nagar & Rifle range, Godlihar Rd.	6
Z-2		AM(GKP-PWJ)	GKP Exch.	Primary	4	2000 pair c/c 4000		GKP Exch. To Barve Nagar & Bhatwadi	12
Z-2		AM(GKP-PWJ)	GKP Exch.	Primary	4	1200 to 2400	2000	GKP Exch. To M. G. Rd.	4
Z-2		AM(GKP-PWJ)	GKP Exch.	Primary	7	1200 to 2400	4000	GKP Exch. To Sainath Nagar, Gangawadi	4
Z-2		AM(GKP-PWJ)	GKP Exch.	Primary	2	1600 to 2400	3000	GKP Exch. To Jagruti Nagar, Asalpa Village	12
Z-2		AM(GKP-PWJ)	Deep Plaza RDL	Primary	1	2000 pair c/c 4000		Deep Plaza RDLU to Kuria bus depot	4
Z-2		AM(GKP-PWJ)	Deep Plaza RDL	Primary	1	2000 pair c/c 4000		Deep Plaza RDLU to Masrani Indl. Estate	6
Z-2		AM(GKP-PWJ)	Deep Plaza RDL	Primary	1	2000 pair c/c 4000		Deep Plaza RDLU to Sheetal cinema	8
Z-2		AM(GKP-PWJ)	Deep Plaza RDL	Primary	1	2000 pair c/c 5000		Deep Plaza RDLU to Naaz Hotel, kamani	6
Z-2		AM(GKP-PWJ)	GOD Hill RSU	Primary	9	800 to 2400	2500	LBS Marg, Godrej Hill RSU to Kalpataru Aura CHS, LBS Marg Ghatkopar (W)	5
Z-2		AM(GKP-PWJ)	NNGR	Primary	7	800 to 2400	2750	From Amrut nagar Circle to Shreyas Signal, LBS Marg Ghatkopar(W)	11
Z-2		AM(GKP-PWJ)	Powal Main	Primary	10	800 to 2400	1500	LBS Marg, Gandhi Nagar junction to Vikhroli West upto Harchand Mill Compound	16
Z-2		AM(GKP-PWJ)	Powal Main	Primary	3	800 to 2400	1200	LBS Marg, Gandhi Nagar junction to Kanjur Marg West upto Gundecha Altura Society	15
Z-2		AM(GKP-PWJ)	Powal Main	Primary	5	800 to 2400	1100	Gandhi Nagar junction to IIT Main Gate Signal	7
									11

Prateek

IV less than 430V

श्री अशोक प्रतेक सरास्वा
 ज्येष्ठ प्रोग्राम-11/असि. डायरेक्टर-11
 राजा अशोक मिन्डस्ट्री/सी.ई.ओ.
 अर्थ मंत्रालय/गो. ऑफ इंडिया
 नई दिल्ली/दिल्ली-110011

Sr. No.	Zone	AREA MANAGER	Exch./RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/ Stretch	No of Pillars effected
Z-3	AM(MRL/SKV)	MAROL	Primary	10	2000/0.4 Pl	1200	Marol to Kondivita, Akruvi, Vijay nagar MIDC	10	
Z-3	AM(MRL/SKV)	MAROL	Primary	7	2000/0.4 Pl	900	Marol to Seepz, MIDC, Nelco	9	
Z-3	AM(MRL/SKV)	MAROL	Primary	6	2400/0.4 Pl	2000	MAROL to Takshila, VERAVALLI	14	
Z-3	AM(MRL/SKV)	MAROL	Primary	1	1600/0.5 Pl	2500	Marol to Sher E-Punjab	1	
Z-3	AM(MRL/SKV)	MAROL	Primary	5	2000/0.5 Pl	2500	Marol to Sher E-Punjab,	7	
Z-3	AM(MRL/SKV)	MAROL	Primary	6	2000/0.5 Pl	3000	Marol to Chakala, Sahar Road, Airport Colony, pg. T Colony	14	
Z-3	AM(MRL/SKV)	MAROL	Primary	4	2000/0.5 Pl	2000	Marol to Chakala	8	
Z-3	AM(MRL/SKV)	MAROL	Primary	2	2000/0.5 Pl	1500	Marol to Andheri Kurla Road, Kondivita, MIDC	8	
Z-3	AM(MRL/SKV)	SEEPZ RSU	Primary	5	2000/0.4 Pl	2500		15	
Z-3	AM(MRL/SKV)	SEEPZ RSU	Primary	2	2400/0.5 Pl	1000	SEEPZ SEZ PREMISES	8	
Z-3	AM(MRL/SKV)	Sakivihar	Primary	1	1600	2600	Sakivihar Exchange to Filterpada.	17	
Z-3	AM(MRL/SKV)	Sakivihar	Primary	2	1200	2600	Sakivihar Exchange to Post office NITTE		
Z-3	AM(MRL/SKV)	Sakivihar	Primary	1	1200	1400	Sakivihar Exchange to Raheja Vihar Chandivili		
Z-3	AM(MRL/SKV)	Sakivihar	Primary	1	2000	850	Sakivihar to Lake bloom powal		

IV less
from 430 V

Pratish

श्री श्री श्री/PRATEEK SRINIVASTAVA
 सहायक प्रिन्सिपल II/Asstt. Director-II
 राज्य विद्युत निगम/Ministry of Power
 नई दिल्ली/New Delhi

Sr. No.	Zone	AREA MANAGER	Exch./RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/ stretch	No of pillars effected
Z-3	AM(MRL/SKV)	Sakivhar	Primary	1	2000	2200	Sakivhar to Lake Homes Chandavali		
Z-3	AM(MRL/SKV)	Sakivhar	Primary	1	1200	1200	Sakivhar to ILFS House Raheja Vihar Chandavali		
Z-3	AM(MRL/SKV)	Sakivhar	Primary	1	1200	1400	Sakivhar to Ansha Industrial Estate Sakivhar		
Z-3	AM(MRL/SKV)	Sakivhar	Primary	1	2000	500	Sakivhar to Shrishti Complex Sakivhar		
Z-3	AM(MRL/SKV)	Sakivhar	Primary	1	2000	1700	Sakivhar to Hillside Raheja Vihar Chandavali		
Z-3	AM(MRL/SKV)	Sakivhar	Primary	1	2000	2800	Sakivhar to Everest Hieghts Lake homes Chandavali		
Z-3	AM(MRL/SKV)	Sakivhar	Primary	1	1600	2400	Sakivhar to Dmart Nahar Chandavali		
Z-3	AM(MRL/SKV)	Sakivhar	Primary	2	1600	1400	Sakivhar to Boomrang building Candivalli		
Z-3	AM(MRL/SKV)	Sakivhar	Primary	1	2000	2200	Sakivhar to MHADA Chandavali		
Z-3	AM(MRL/SKV)	Sakivhar	Primary	1	2000	2800	Sakivhar to orchid enclave Nahar, Chandavali		
Z-3	AM(MRL/SKV)	Sakivhar	Primary	1	2000	3100	Sakivhar to Vinca Nahar		
Z-3	AM(MRL/SKV)	Maroshi	Primary	4	2000	1500	Marol Maroshi to Panchvati Vijay Nagar Maroshi		
Z-3	AM(MRL/SKV)	Maroshi	Primary	2	2000	1800	Marol Maroshi to Police Camp Bhavani Nagar		

Prateek

श्रीक श्रीराम/PRATEEK SRINASTAVA
 तारांक निदेशक-II / Asstt. Director-II
 विद्युत मंत्रालय, भारत सरकार / C.E.A.
 भारत सरकार / Ministry of Power
 नई दिल्ली / New Delhi

IV less than
 480 V

48

St. No.	Zone	AREA MANAGER	Exch./RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/Stretch	No of Pillars effected
Z-3	AM(MRL/SKV)	SAKINAKA	Maroshi	Primary	2	2000	2100	Marol Maroshi to Lok Darshan Complex Maroshi	
Z-3	AM(MRL/SKV)	SAKINAKA	Maroshi	Primary	3	2000	1900	Marol Maroshi to Manasthal Marwah Road	
Z-3	AM(MRL/SKV)	SAKINAKA	Maroshi	Primary	1	2000	600	Marol Maroshi to Airport Metro AK Road Andhri	25
Z-3	AM(MRL/SKV)	SAKINAKA	SAKINAKA	Primary	1	2000	1000	Sakinaka Exchange to Sakinaka Junction	
Z-3	AM(MRL/SKV)	SAKINAKA	SAKINAKA	Primary	1	1600	2000	Sakinaka Junction to Khairani Road	
Z-3	AM(MRL/SKV)	SAKINAKA	SAKINAKA	Primary	1	800	1500	Khairani Road to Pillars 0608, 0610	2
Z-3	AM(MRL/SKV)	SAKINAKA	SAKINAKA	Primary	1	800	500	Sakinaka Junction to Pillar 0506	1
Z-3	AM(MRL/SKV)	SAKINAKA	SAKINAKA	Primary	1	1600	3000	Sakinaka Exchange to Khairani Road	
Z-3	AM(MRL/SKV)	SAKINAKA	SAKINAKA	Primary	1	800	1000	Khairani Road to Pillars 0614, 0615	2
Z-3	AM(MRL/SKV)	SAKINAKA	SAKINAKA	Primary	1	2400	1000	Sakinaka Exchange to Sakinaka Junction	
Z-3	AM(MRL/SKV)	SAKINAKA	SAKINAKA	Primary	1	2000	1000	Sakinaka Junction to Ghatkoper link road	
Z-3	AM(MRL/SKV)	SAKINAKA	SAKINAKA	Primary	1	800	700	Sakinaka Junction to Kailash puram 0902	1
Z-3	AM(MRL/SKV)	SAKINAKA	SAKINAKA	Primary	1	1600	500	Ghatkoper link road to 90 ft road	
Z-3	AM(MRL/SKV)	SAKINAKA	SAKINAKA	Primary	1	2000	2000	Ghatkoper link road to pillars 0901, 0903, 0905, 0906	4

IV less than 450 V

Prateek

श्रीमती श्रीमती/PRATEEK SRINASTAVA
 पता: फ्लॉर-11/असि. डायरेक्टर-11
 कोस्टल रोड, फ्लॉर-11/सी.ई.ए.
 विद्युत विभाग/Ministry of Power
 ऑफिस, नई दिल्ली, Govt. of India
 नई दिल्ली/New Delhi

Sr. No.	Zone	AREA MANAGER	Exch./RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/ stretch	No of Pillars effected
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	2400	2000	sakinaka exchange to kajupada junction	
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	800	500	kajupada junction to pillar 0410	1
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	1600	500	kajupada junction to kajupada pipeline road	
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	800	800	kajupada pipeline road to pillars 0702, 0705, 0704	3
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	1600	3500	Sakinaka Exchange to Khairani Road	
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	800	1500	Khairani Road to Pillars 0612, 0613, 0609	3
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	2000	3000	Sakinaka Exchange to Mittal Industrial Estate	
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	800	1000	to pillars 0201, 0203, 0208, 0211	4
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	2000	1000	Sakinaka Exchange to Sakinaka Junction	
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	1200	400	sakinaka junction to mittal estate	
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	800	700	mittal estate to pillars 0202, 0209	2
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	800	300	sakinaka junction to pillar 0501	1
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	2400	1800	Sakinaka Exchange to Ghatkoper Link Road	
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	800	2000	to pillars 0907, 0908, 0909, 0910, 0911, 0912	6

IV less than 430V

Prateek

प्रतीक श्रीवास्तव/PRATEEK SRIVASTAVA
 सहायक निदेशक-II/Asstt. Director-II
 क्षेत्रीय विद्युत निदेशक/CEA,
 विद्युत मंत्रालय/Ministry of Power
 भारत सरकार/Govt. of India
 नई दिल्ली/New Delhi

Sr. No.	Zone	AREA MANAGER	Exch./RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH/ (Mtr)	LOCATION/ Stretch	No. of Pillars effected
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	2400	500	Sakinaka Exchange to A K Road		
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	1600	400	on A K road		
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	800		to pillars 0508, 0509, 0510, 0511, 0512	5	
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	2000	2000	Sakinaka Exchange to Marol cooperative		
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	800	1100	Marol cooperative to pillars 0105, 0106, 0108	3	
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	2400	3000	Sakinaka Exchange to Marol Naka		
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	800		marol naka to pillars 0102, 0103, 0104	3	
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	2000	500	Sakinaka Exchange to A K road		
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	800		to pillars 0505, 0507, 0502, 0503	4	
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	2000	1000	sakinaka exchange to kajupada junction		
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	800		to pillars 0701, 0706, 0707	3	
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	2000	2500	Sakinaka Exchange to A K road		
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	800	1000	A. K. road to pillars 0101, 0107, 0109	3	
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	2000	1000	Sakinaka Exchange to Jari mari road		

IV less
then 430V

Prateek

श्री प्रवीण/PRATEEK SRINIVASTAVA
 सहायक निदेशक-II/Asstt. Director-II
 केन्द्रीय विद्युत प्राधिकरण/C.E.A.
 विद्युत मंत्रालय/Ministry of Power
 भारत सरकार/Govt. of India
 नई दिल्ली/New Delhi

Sr. No.	Zone	AREA MANAGER	Exch./RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/ stretch	No of Pillars effected
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	1600	200	Jari mari road to jari mari	1
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	800	1000	to pillars 0401, 0402, 0407	3
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	2000	200	Sakinaka Exchange to gurunanak industrial	
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	1600	500	gurunanak industrial to safed pool	
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	800	700	to pillars 0403, 0404, 0408	3
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	2000	2500	Sakinaka Exchange to Khairani Road	
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	1600	200	Khairani road LI	
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	800	1000	to pillars 0616, 0617, 0619, 0606	4
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	2000	3000	Sakinaka Exchange to Khairani Road	
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	800	2000	to pillars 0611, 0621, 0618	3
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	2000	3000	Sakinaka Exchange to Khairani Road	
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	800	1000	to pillars 0601, 0602, 0605	3
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	2000	2500	Sakinaka Exchange to Khairani Road	
Z-3		AM(MRL/SKV)	SAKINAKA	Primary	1	800	1200	to pillars 0603, 0604, 0607	3

IV less
than 430V

Pradeep
 श्री: प्रवीण/PRATEEK SRIVASTAVA
 सहायक निदेशक-II/Asstt. Director-II
 सशक्ति विद्युत निदेशक/ C.E.A.
 विद्युत विभाग / Ministry of Power
 भारत सरकार / Govt. of India
 नए दिल्ली / New Delhi

Sr. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/Stretch	No of pillars effected
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	2000	200	Sakinaka Exchange to A K road		
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	800	300	to sudarshan hotel		
Z-3	AM(MRL/SKV)	SAKINAKA	Primary	1	800	800	to pillar 0406, 0405, 0409	3	
Z-5	AM(MULUND)	MULUND	Primary	8	2400	3200			
Z-5	AM(MULUND)	MULUND	Primary	7	2000	2900			
Z-5	AM(MULUND)	MULUND	Primary	2	1600	2500			
Z-5	AM(MULUND)	MULUND	Primary	2	1200	2000			
Z-5	AM(MULUND)	MULUND	Primary	1	800	1200			
Z-5	AM(MULUND)	MULUND	Primary	1	400	350			
Z-5	AM(MULUND)	GOVIND UDYOG	Primary	6	2400	3000			
Z-5	AM(MULUND)	GOVIND UDYOG	Primary	4	2000	2500			
Z-5	AM(MULUND)	GOVIND UDYOG	Primary	3	1600	2100			
Z-5	AM(MULUND)	GOVIND UDYOG	Primary	2	1200	1600			
Z-5	AM(MULUND)	MAKISHA RSU	Primary	17	2000	10251		50	

IV less than 430V

Prateek

श्रीक श्रीवास्तव/PRATEEK SRINAGAVA
 सहायक निदेशक-II/Asstt. Director-II
 केंद्रीय विद्युत प्राधिकरण/C.E.A.
 विद्युत मंत्रालय/Ministry of Power
 भारत सरकार/Govt. of India
 नई दिल्ली/New Delhi

Sr. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE		No of Pillars effected
							LENGTH (Mtr)	LOCATION/Stretch	
Z-5		AM(MULUND)	MANISHA RSU	Primary	1	1600	30	30	55
Z-5		AM(MULUND)	MANISHA RSU	Primary	8	1200	1417	1417	
Z-5		AM(MULUND)	MANISHA RSU	Primary	12	800	1301	1301	
Z-5		AM(MULUND)	MANISHA RSU	Primary	5	400	352	352	
Z-5		AM(MULUND)	WAGLE ESTATE	Primary	6	2400			
Z-5		AM(MULUND)	WAGLE ESTATE	Primary	15	2000			
Z-5		AM(MULUND)	WAGLE ESTATE	Primary	13	1600			
Z-5		AM(MULUND)	WAGLE ESTATE	Primary	1	1200			
Z-5		AM(MULUND)	WAGLE ESTATE	Primary	1	800			
Z-5		AM(MULUND)	LOKMANYA	Primary	4	2000			
Z-5		AM(MULUND)	LOKMANYA	Primary	11	1600			
Z-5		AM(MULUND)	BHANDUP VILLAGE	Primary	12	2000			
Z-5		AM(MULUND)	BHANDUP VILLAGE	Primary	1	1600			
Z-5		AM(MULUND)	BHANDUP VILLAGE	Primary	1	700			

IV less
than 430V

Pateel

श्री प्रदीप शिवस्तवा / PRADEEK SRIVASTAVA
 सहायक निदेशक-II / Asstt. Director-II
 क्षेत्रीय विद्युत संचालन / C.E.A.
 विद्युत विभाग / Ministry of Power
 भारत सरकार / Govt. of India
 नई दिल्ली / New Delhi

Sr. No.	Zone	AREA/WANAGER	Exch./RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/Stretch	No of Pillars effected
Z-5	AM(CHARAI)	Kopri	Primary	1	2000	700	Fire Brigade TMC	3	
Z-5	AM(CHARAI)	Kopri	Primary	1	2000	1000	Mangala School	2	
Z-5	AM(CHARAI)	Kopri	Primary	1	1600	400	Mahadev mandir	1	
Z-5	AM(CHARAI)	Kopri	Primary	1	2000	1700	Chendani Kolwada	2	
Z-5	AM(CHARAI)	Kopri	Primary	1	2000	750	Dhobi Ghat	2	
Z-5	AM(CHARAI)	Kopri	Primary	1	1600	1400	Mithabandar Rd	1	
Z-5	AM(CHARAI)	Kopri	Primary	1	2000	1150	Jijamata Hall	1	
Z-5	AM(CHARAI)	Kopri	Primary	1	2000	1100	Harom Nagar	3	
Z-5	AM(CHARAI)	Kopri	Primary	1	2000	1150	12 Bungalow	3	
Z-5	AM(CHARAI)	Kopri	Primary	1	1600	500	Kopri Gaon	2	
Z-5	AM(CHARAI)	Balkum	Primary	1	2000	1600	Rustomji, Boulevar MallNear Aprodithe, MaxinusNear Jupiter Olympia Lodha	4	
Z-5	AM(CHARAI)	Balkum	Primary	1	2000	550	Sababa MandirBalkum Naka, Opp. Post OfficeDadlani ParkKwadi Hospital	4	
Z-5	AM(CHARAI)	Balkum	Primary	1	2000	1150	Yashaswi NagarHighland Residency/Kalpruksh Garden	3	
Z-5	AM(CHARAI)	Balkum	Primary	1	2000	1150	Yashaswi NagarNear Bigbazar, Kapurbawdikapurbawdi	3	

P. Patel

IV less than 430V

NAMEEN SHIVASTAVA
 Manager/Asstt. Director-II
 केन्द्रीय विद्युत अधिकरण/C.E.A.
 विद्युत विभाग/Ministry of Power
 भारत सरकार/GOVT. of India
 नई दिल्ली/New Delhi

Sr. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/ stretch	No of Pillars effected
Z-5	AM(CHARAI)	Balkum	Primary	1	2000	1150	Runwal Garden	1	
Z-5	AM(CHARAI)	Balkum	Primary	1	2000	1400	Church/Majiwade Bus stop Flower Market Majiwade Bus stop	4	
Z-5	AM(CHARAI)	PPK	Primary	1	2000	550	Anargyan Indl. Estate/Punjani Indl. Estates/Shehar Padakolbad Naka, LBS Road	4	
Z-5	AM(CHARAI)	PPK	Primary	1	2000	800	Opp. Fishland Hotel Near Sankalp Heights Service Road/inside Runwal Nagar/Near Golden	5	
Z-5	AM(CHARAI)	PPK	Primary	1	2000	700	Meenathai Thakare Chowk/Near PPK Exchange/Nandgaonkar Heights	4	
Z-5	AM(CHARAI)	PPK	Primary	1	2000	1300	Near Sankalp Heights Service Road/Flower Valley/Shehar Padakolbad/Near Golden Heaven	4	
Z-5	AM(CHARAI)	PPK	Primary	1	2000	550	Meenathai Thakare Chowk/Castle Mill/Meenathai Thakare Chowk/Kolbad Naka	5	
Z-5	AM(CHARAI)	PPK	Primary	1	2000	700	Heights/uthalsar Mandir, Near Cyclewala Court Naka	4	
Z-5	AM(CHARAI)	PPK	Primary	1	2000	550	Building Masanwada	3	
Z-5	AM(CHARAI)	PPK	Primary	1	2000	1300	Garden, Opp. S.P Pumps	4	
Z-5	AM(CHARAI)	VAVI	Primary	1	2400	1100			
Z-5	AM(CHARAI)	VAVI	Primary	1	2000	1300			
Z-5	AM(CHARAI)	VAVI	Primary	1	2400	1200			
Z-5	AM(CHARAI)	VAVI	Primary	1	1200	800			

TV Cells
then 480 V

Prateek

श्रीक प्रतेक/PRATEEK SRIVASTAVA
 कर्तव्य निदेश-11/Asstt. Director-II
 कर्तव्य निदेश निदेशक/ C.E.A.
 कर्तव्य निदेश/Ministry of Power
 कर्तव्य निदेश/ Govt. of India
 कर्तव्य निदेश/ New Delhi

Sr. No.	Zone	AREA/MANAGER	Exch./RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/Stretch	No of Pillars effected
Z-5	AM(CHARAI)	VAVI	Primary	1	1600	1000			
Z-5	AM(CHARAI)	VAVI	Primary	1	800	500			
Z-5	AM(CHARAI)	VAVI	Primary	1	1600	1100			
Z-5	AM(CHARAI)	VAVI	Primary	1	2000	1200			
Z-5	AM(CHARAI)	VAVI	Primary	1	2000	1100			
Z-5	AM(CHARAI)	VAVI	Primary	1	2000	1300			
Z-5	AM(CHARAI)	VAVI	Primary	1	2000	1100			
Z-5	AM(CHARAI)	VAVI	Primary	1	2000	1200			
Z-5	AM(CHARAI)	VAVI	Primary	1	2000	1800			
Z-5	AM(CHARAI)	VAVI	Primary	1	2000	1500			
Z-5	AM(CHARAI)	VAVI	Primary	1	1600	1500			
Z-5	AM(CHARAI)	NMUM	Primary	1	2000	500	Mumbra English School	34	
Z-5	AM(CHARAI)	NMUM	Primary	1	2000	1000	Dagha Rd, Parsik Tunnel, Mumbradevi Rd, MEK company	5	
Z-5	AM(CHARAI)	NMUM	Primary	1	2000	1700	Mithal ground, Bhuranudin Hospital, Canara Bank	4	

IV 1883
Chau 930V

Pradip

निदेशिका
 सहायक निदेशक-II/असिस्ट. डायरेक्टर-II
 क्षेत्रीय निदेशक/सहायक/स.नि.अ.
 विद्युत विभाग/Ministry of Power
 भारत सरकार/Govt. of India
 नई दिल्ली/New Delhi

Sr. No.	Zone	AREA MANAGER	Exch./KSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/Stretch	No. of Pillars effected
Z-5	AM(CHARAI)	AM(CHARAI)	NM/JM	Primary	1	2000	1700	Shankar Mandir, Police station	3
Z-5	AM(CHARAI)	AM(CHARAI)	KAUSA	Primary	1	2000	1000	Kadar Palace, Talao pali	5
Z-5	AM(CHARAI)	AM(CHARAI)	KAUSA	Primary	1	2000	900	Pipe compound, Nesheman, Wara park, tanwar complex, Sainik Nagar, Virani Petrol pump	9
Z-5	AM(CHARAI)	AM(CHARAI)	KAUSA	Primary	1	2000	1000	Shadi mahal rd, Gulab park, Khadija Hall, Dost Apartment, Kabardisthan, kanderi building	8
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	1000	Thane Prison	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	200	Charai TE	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	800	Khopai	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	1200	Samta Nagar	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	1300	Teen Petrol Pump	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	1500	Raymond, Pokran Rd	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	2000	Brindavan society	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	2000	Shreerang Society	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	2300	Rabodi	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	2000	Shreerang Society	

IV
less
than 430V

Prateek

प्रतीक श्रीवास्तव / PRATEEK SRIVASTAVA
 सहायक निदेशक-II / Asstt. Director-II
 क्षेत्रीय विद्युत निदेशक / C.E.A.
 विद्युत शक्ति विभाग / Ministry of Power
 भारत सरकार / Govt. of India
 नई दिल्ली / New Delhi

Sr. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/Stretch	No of Pillars effected
Z-5		AM(CHARAI)	CHR	Primary	1	2000	2000	Brindavan society	
Z-5		AM(CHARAI)	CHR	Primary	1	2000	900	Dhobi Ali	
Z-5		AM(CHARAI)	CHR	Primary	1	2000	1100	Vikas palms, Khopat	
Z-5		AM(CHARAI)	CHR	Primary	1	2000	1000	Tembi Naka	
Z-5		AM(CHARAI)	CHR	Primary	1	2000	1000	ST Workshop, Uthakar Naka	
Z-5		AM(CHARAI)	CHR	Primary	1	2000	1500	Ramchandra Nagar	
Z-5		AM(CHARAI)	CHR	Primary	1	2000	1500	Dagdi School	
Z-5		AM(CHARAI)	CHR	Primary	1	2000	1500	Tembi Naka	
Z-5		AM(CHARAI)	CHR	Primary	1	2000	2000	Majiwada	
Z-5		AM(CHARAI)	CHR	Primary	1	2000	2000	Brindavan society	
Z-5		AM(CHARAI)	CHR	Primary	1	2000	2400	Ram Maruti Rd	
Z-5		AM(CHARAI)	CHR	Primary	1	2000	2000	Shreerang Society	
Z-5		AM(CHARAI)	CHR	Primary	1	2000	600	Eduji Rd, Charai	
Z-5		AM(CHARAI)	CHR	Primary	1	2000	600	Eduji Rd, Charai	

IV less
than 480V

Prepared

पुनर्विद्युत आपूर्ति प्रकल्प
 Director-II / Asstt. Director-II
 C.E.A.
 Ministry of Power
 Govt. of India
 New Delhi

Sr. No.	Zone	AREA MANAGER	Exch./RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/Stretch	No of Pillars effected
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	1200	Khilla, rabodi	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	1500	Samta Nagar	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Prabhat talkies, Station Rd	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Teen Petrol Pump	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Panchpakdi	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Teen Petrol Pump	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Prabhat talkies, Station Rd	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Shivaji Nagar	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Naupada	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Chandanwadi	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Chendani Kolwada	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Mahagiri	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Panchpakdi	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Naupada	

Prabhat

IV less
trans 430V

श्रीक श्रीमती/PRATEEK SRINASTAVA
 सहायक निदेशक-II/Asstt. Director-II
 क्षेत्रीय विद्युत निदेशकता/C.E.A.
 विद्युत शक्ति विभाग/Ministry of Power
 भारत सरकार/Govt. of India
 नई दिल्ली/New Delhi

Sr. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/ stretch	No of pillars effected
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	2000	Bhaskar Colony	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	2000	Panchpakdi	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	1200	Hans Nagar, Khopat	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	1000	Dhobi Ali	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	2400	Naupada	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	1200	Talao pall	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	1500	Nitin Company	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	1500	Ghantaili	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	1500	Jambhli Naka	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	1500	CPO	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	1500	Mahagiri	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	1500	CIDCO	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	1500	Akashganga, Rabodi	
Z-5	AM(CHARAI)	AM(CHARAI)	CHR	Primary	1	2000	1500	Kharkar Ali	

Prasad

*IV bars
from 430V*

श्रीमान् श्रीप्रदीप/PRATEEK SRMASTAVA
 श्रीमान् श्रीप्रदीप/Asstt. Director-II
 श्रीमान् श्रीप्रदीप/अधीक्षक/अधीक्षक/अधीक्षक/C.E.A.
 श्रीमान् श्रीप्रदीप/Ministry of Power
 श्रीमान् श्रीप्रदीप/Govt. of India
 श्रीमान् श्रीप्रदीप/New Delhi

Sr. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH/ (Mtr)	LOCATION/ Stretch	No of Pillars effected
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Saket	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	1500	Temphi Naka	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Govind Bachachi Rd	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2100	Thane Station RD	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	1800	Court Naka	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	1600	Jambhli Naka	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Gokhale Rd	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2200	Saket Complex	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Vishnu Nagar, Naupada	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Teen Petrol Pump	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Brindavan society	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Ramchandira Nagar	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	Gokhale Rd, Naupada	
Z-5	AM(CHARAI)	CHR	CHR	Primary	1	2000	2000	RamMaruti Rd	

IV leads
over 480V

Pakret

श्रीक श्रीवाकरा, PRATEC.
सहायक निदेशक-II/Asstt. Director-II
केन्द्रीय विद्युत निदेशक/ C.E.A.
विद्युत विभाग/Ministry of Power
भारत सरकार/Govt. of India
एन. सिटी/ New Delhi

Sr. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/Stretch	No of Pillars effected
Z-5	AM(CHARAI)	CHR	Primary	1	2000	2000	2000	Hariniwas Circle	
Z-5	AM(CHARAI)	CHR	Primary	1	2000	2000	2000	Gokhale Rd, Naupada	
Z-5	AM(CHARAI)	CHR	Primary	1	2000	2000	2000	Tarangan, Samta Nagar	
Z-5	AM(CHARAI)	CHR	Primary	1	2000	2000	2000	Teen Petrol Pump	
Z-5	AM(CHARAI)	CHR	Primary	1	2000	2000	2000	Samta Nagar	
Z-5	AM(CHARAI)	CHR	Primary	1	2000	2000	2000	Panchpakdi	
Z-5	AM(CHARAI)	CHR	Primary	1	2000	2000	2000	Makhmali Talao	
Z-5	AM(CHARAI)	CHR	Primary	1	2000	2000	2000	Hariniwas Circle	
Z-5	AM(CHARAI)	CHR	Primary	1	2000	2300	2300	Majiwada	
Z-5	AM(CHARAI)	CHR	Primary	1	2000	2000	2000	Raymond, Pokran Rd	
Z-5	AM(CHARAI)	CHR	Primary	1	2000	2300	2300	Rutu Park	
Z-5	AM(CHARAI)	CHR	Primary	1	2000	2300	2300	TMC, Panchpakahadi	
Z-5	AM(CHARAI)	CHR	Primary	1	2000	4000	4000	Vitawa, Kaiwa	
Z-5	AM(CHARAI)	CHR	Primary	1	2000	2000	2000	Alameda Rd, Panchpakahadi	

IV less than
435 V

Prateek

श्री श्री प्रतीक/PRATEEK SHIVASTAVA
 सहायक निदेशक-II/Asstt. Director-II
 कक्षा निदेशक/असिस्टेंट/CEA.
 विद्युत विभाग/Ministry of Power
 भारत सरकार/Govt. of India
 नए दिल्ली/New Delhi

Sr. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/ Street	Nd of Pillars effected
Z-5	AM(CHARAI)	CHR	Primary	1	2000	2000	Vishnu Nagar, Naupada	96	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1200	560	SEC-9, SEC-10 AND SEC-15	3	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1200	290	SEC-9	2	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1200	280	SEC-9A AND SEC-16	1	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	800	760	SEC-15	2	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1200	440	SEC-9 AND SEC-9A	3	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	2000	550	SEC-9, SEC-9A, SEC-10, SEC-11 AND SEC-12	9	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1600	1200	SEC-18	2	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1200	1220	SEC-19	2	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1600	1200	SEC-19	2	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1200	290	SEC-9, SEC-9A AND SEC-10	4	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	2000	750	SEC-14 AND SEC-15	6	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1600	1450	SEC-12, SEC-14 AND SEC-29	7	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1200	1250	SEC-14, SEC-28 AND SEC-29	8	

9V less than 430V

Prateek

श्री अशोक प्रतेक शर्मा
 अशोक प्रतेक शर्मा / Prateek Sh.
 सहायक निदेशक-II / Asstt. Director-II
 संचालन विभाग / Distribution / C.E.A.
 बिजली विभाग / Ministry of Power
 रायपुर / Raipur / C.E.A. of India
 मोबा. 98261 44444

Sr. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/ Stretch	No of Pillars effected
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1200	160	SEC-14, SEC-15, SEC-16 AND SEC-16A	7	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1200	1350	SEC-18	1	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1200	160	SEC-14, SEC-15, SEC-16 AND SEC-16A	6	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1200	1200	SEC-14, SEC-15, SEC-16 AND SEC-29	6	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1600	550	SEC-9, SEC-9A, SEC-10 AND SEC-11	6	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1600	1200	SEC-19	1	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1600	550	SEC-9, SEC-9A, SEC-10, SEC-10A, SEC-11, SEC-12, AND SEC-14	9	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	2000	160	SEC-16 AND SEC-16A	6	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	2000	400	SEC-17	4	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	2000	400	SEC-17	4	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	2000	720	SEC-17	3	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	2000	350	SEC-17	4	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	2000	400	SEC-17	7	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	2000	200	SEC-17	4	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	2000	200	SEC-17	4	

IV less than 480V

Prateek

श्रीक शीवाकर/PRATEEK SRIVASTAVA
 सहायक निदेशक-II/Asstt. Director-II
 केंद्रीय विद्युत प्राधिकरण/C.E.A.
 विद्युत मंत्रालय/Ministry of Power
 भारत सरकार/Govt. of India
 नई दिल्ली/New Delhi

Sl. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/ Stretch	No of Pillars effected
Z-5	AM(VASHI)	VASHI	PRIMARY	1	2000	560	SEC-9, SEC-9A, SEC-10, SEC-11 AND SEC-12	6	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	2000	780	SEC-14, SEC-15, AND SEC-29	9	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1600	1100	SEC-19	2	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	2000	780	SEC-15 AND SEC-28	5	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	2000	1500	SEC-19 AND SEC-29	4	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	1600	1000	SEC-14 AND SEC-29	9	
Z-5	AM(VASHI)	VASHI	PRIMARY	1	2000	1710	SEC-14 AND SEC-29	2	
Z-5	AM(VASHI)	VMART	PRIMARY	1	800	1100	SEC-28	3	
Z-5	AM(VASHI)	VSI Sec 7	PRIMARY	3	2000	2000	Galaxy Building Sec 2 Vashi	5	
Z-5	AM(VASHI)	VSI Sec 7	PRIMARY	4	2000	600	F Type Market Sec 6 Vashi	10	
Z-5	AM(VASHI)	EL ZONE RSU	Primary	1	400	400	NR EL-87	1	
Z-5	AM(VASHI)	EL ZONE RSU	Primary	1	400	1000	global electronics EL Zone	1	
Z-5	AM(VASHI)	EL ZONE RSU	primary	1	400	200	Gold star EL zone	1	
Z-5	AM(VASHI)	EL ZONE RSU	Primary	1	400	150	Near EL Zone RSU	1	

SV less than 430V

Prateek

श्री. प्रदीप शर्मा / PRADEEP SRIVASTAVA
 Director - II / Asst. Director - II
 शक्ति विभाग / Ministry of Power
 भारत सरकार / Govt. of India
 नया दिल्ली / NEW Delhi

Sr. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/ Stretch	No of Pillars effected
Z-5	AM(VASHI)	MBP	Primary	1	400	50	MIDC pillar-10104, Near MIDC office.	1	
Z-5	AM(VASHI)	MBP	Primary	1	400	1000	Garden pillar-near, A 220	1	
Z-5	AM(VASHI)	MBP	Primary	1	400	1000	The pillar, near A412	1	
Z-5	AM(VASHI)	MBP	Primary	1	400	1000	Sshiv kripa pillar, Shiv kripa hotel	1	
Z-5	AM(VASHI)	MBP	Primary	1	400	500	Techno city pillar, near Techno city, under bridge	1	
Z-5	AM(VASHI)	MBP	Primary	1	800	104	MBP to Ashirvad hotel/pillar no-0101		
Z-5	AM(VASHI)	MBP	Primary	1	800	1458	MBP to Hexaware, MBP		
Z-5	AM(VASHI)	MBP	Primary	1	800	2270	MBP to Fire station		
Z-5	AM(VASHI)	AIROLI	PRIMARY	1	2000	1700	Sec1		
Z-5	AM(VASHI)	AIROLI	PRIMARY	1	2000	800	Sec3		
Z-5	AM(VASHI)	AIROLI	PRIMARY	1	2000	435	Sec4		
Z-5	AM(VASHI)	AIROLI	PRIMARY	1	2000	2500	Sec5		
Z-5	AM(VASHI)	AIROLI	PRIMARY	1	2000	1800	Sec15		
Z-5	AM(VASHI)	AIROLI	PRIMARY	1	2000	2900	Digha		

EV led
480V

Passed

श्रीकेश शर्मा/PRATEEK SRINASTAVA
 Director, Divison-11/ASST. Director-II
 फोर्टिस रिजल्ट सर्विसेज/CL&A,
 फोर्टिस रिजल्ट/Ministry of Power
 भारत सरकार/Govt. of India
 १०१, फोर्टिस/NEW DELHI

Sr. No.	Zone	AREA MANAGER	Exch/RSU	CABLE TYPE	No. of Cable	Size of CABLE	CABLE LENGTH (Mtr)	LOCATION/ stretch	No of Pillars effected
Z-5	AM(VASHI)	APMC	Primary	5	2000	5000	Janta Market Sec-22, Sec-19E and Sec26	16	
Z-5	AM(VASHI)	APMC	Primary	4	2000	2400	Sec-24 & Sec 19	20	
Z-5	AM(VASHI)	KKR	Primary	6	2000	6000	Sector-1, 2, 3, 4, 14, 16, 17, 18, 19, 20, 22, 23	20	
Z-5	AM(VASHI)	KKR	Primary	4	2000	2400	Sector-4, 5, 6, 7, 8, 11, 12, 19C	15	
Z-5	AM(VASHI)	KKR	Primary	1	1600	1200	Sector 9, 10, 11	3	
Z-5	AM(VASHI)	KKR	Primary	1	1600	600	BALAJI GARDEN	3	

Handwritten notes and signatures in the middle of the page.

Prateek

IV less
430 V

श्रीक श्रीवास्तव/PRATEEK SRIVASTAVA
 सहायक निदेशक-II/Asstt. Director-II
 केन्द्रीय विद्युत प्राधिकरण/C.E.A.
 विद्युत मंत्रालय/Ministry of Power
 भारत सरकार/Govt. of India
 नई दिल्ली/New Delhi

CEA Case No.: MRA-1181

Name of the Power line: 400 kV D/C LILO on Talegaon – Kalwa line at 400 kV Vikhroli GIS substation

Map Scale : 1 cm=500 m

Total Length : 12.103 कस

S.R. Value : 30,000 Ω -cm

S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.
7	Mankhurd - Vashi	1.6	0.0001	12000	1
8	Vashi - Sanpada	Out of parallelism			0
9	Sanpada – Jui Nagar				0
Kurla – Trombay Section					
1	Kurla - Trombay	Out of parallelism			0
Airoli – Sanpada Section					
1	Airoli - Rabale	1.4	0.0011	9400	10
2	Rabale - Ghansoli	1.5	0.0008	8000	6
3	Ghansoli – Kopar Khairane	1.2	0.0006	8800	5
4	Kopar Khairane - Turbhe	Out of parallelism			0
5	Turbhe – Sanpada				0
Dombivli – Dativli Cabin Section					
1	Dombivli – Dativli Cabin	Out of parallelism			0

Prateek

प्रतीक श्रीवास्तव / PRATEEK SRIVASTAVA
सहायक निदेशक-II / Assk. Director-II
केन्द्रीय विद्युत प्राधिकरण / C.E.A.
विद्युत मंत्रालय / Ministry of Power
भारत सरकार / Govt. of India
नई दिल्ली / New Delhi

ANNEXURE - II

CEA Case No.: MRA-1181 Name of the Power line: 400 kV D/C LILO on Talegaon – Kalwa line at 400 kV Vikhroli GIS substation			Map Scale : 1 cm=500 m Total Length : 12.103 कस S.R. Value : 30,000 Ω-cm		
S.No.	Telecom. Details	Length of Parallelism in Km.	Mutual Coupling in Ohms.	Effective Fault current in Amps.	I.V in Volts.

CENTRAL RAIWAY Ref. No: N.153/PTCC/400kV/MAH-780

Dated: 26.08.2021

Affected Blocks & Telecom Circuits Details

Sion – Dombivli Section

1	Sion – Kurla	Out of parallelism			0
2	Kurla - Vidyavihar				0
3	Vidyavihar - Ghatkopar				0
4	Ghatkopar - Vikhroli	2.3	0.0065	10500	68
5	Vikhroli - Kanjurmarg	1.75	0.0047	9000	42
6	Kanjurmarg - Bhandup	1.5	0.0048	8500	41
7	Bhandup - Nahur	3.1	0.0047	9200	43
8	Nahur - Mulund	Out of parallelism			0
9	Mulund - Thane	0.75	0.0011	11000	12
10	Thane - Kalva	0.7	0.0009	12000	11
11	Kalva - Mumbra	1	0.0004	12000	5
12	Mumbra – Diva Jn	Out of parallelism			0
13	Div a Jn - Kopar				0
14	Kopar - Dombivli				0

Guru Teg Bahadur Nagar – Jui Nagar Section

1	Guru Teg Bahadur Nagar - Chunabhati	Out of parallelism			0
2	Chunabhati - Kurla				0
3	Kurla – Tilak Nagar				0
4	Tilak Nagar - Chembur	0.3	0.0001	13000	1
5	Chembur - Govandi	Out of parallelism			0
6	Govandi - Mankhurd				0

Prateek

प्रतीक श्रीवास्तव / PRATEEK SRIVASTAVA
 सहायक निदेशक-II / Assst. Director-II
 केन्द्रीय विद्युत प्राधिकरण / C.E.A.

Tele : 23019746

MRA-1181

Annex-III

Directorate General of Signals
Signals 7
General Staff Branch
Integrated HQ of MoD, (Army)
DHQ PO, New Delhi - 110011

B/46937/Sigs 7(b)/2465/

04 Aug 2021

Kharghar Vikhroli Transmission Private Limited
Adani Corporate House, Shantigram
Nr. Vaishno Devi Circle, SG Highway,
Ahmedabad-382481, Gujarat, India

**PTCC CLEARANCE FOR 400KV D/C LILO ON TALEGAON-KALWA AT
VIKHROLI GIS TRANSMISSION LINE IN THANE & MUMBAI SUBURBAN
DISTRICT OF MAHARASHTRA STATE**

1. Refer your letter No KVPTL/21-22/290621-01 dt 29 Jun 2021 (copy att).
2. No Objection Certificate (NOC) is accorded based on inputs provided as per Map sheet received under your letter mentioned above.
3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(A Rawat)
Lt Col
GSO 1 (Comn)
for SO-in-C

Enclosures : As above

Copy to :-

✓ The Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi - 110016

The DET (PTCC), Northern Zone
O/o PGM (North), QA & Inspection Circle,
D-Tax Building, Eastern Court, Janpath
New Delhi-110001

for information

Dr
17/8

MTC-1181
17/8

A 237

703

23/8/21