

File No.CEA-PS-17-11(11)/15/2022-PCD Division



75
आजादी का
अमृत महोत्सव

भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

के.वि.प्रा. केस सं. : RAJ-701&702 / 294-296
पी.टी.सी.सी. प्रस्ताव 400 kV S/C transmission line on D/C towers of M/s NTPC from (i) CPSU1 400/33 kV PSS of M/s NTPC to PGCIL 765/400/220 kV GSS Bhadla – II (26.311 km) (ii) CPSU2 400/33 kV PSS of M/s NTPC to CPSU1 400/33 kV PSS of M/s NTPC at Nokhra, Bikaner, Rajasthan (1.675 km)

सन्दर्भ:		
क्रमांक	सन्दर्भ सं.	दिनांक
(i)	NTPC: SKB/CPSU—I&II/21-22/39	28.02.2022
(ii)	BSNL: DET/PTCC/ND/DV-10059/UTR-36/2021-2022	23.03.2022
(iii)	North Western Railway: SG/158/NWR/PTCC/885	23.03.2022

संदर्भ (i) द्वारा प्रस्तुत पीटीसीसी प्रस्ताव की जांच की गई है। बीएसएनएल ने उपरोक्त संदर्भ (ii) के द्वारा अनापत्ति प्रमाण पत्र जारी किया है। उत्तर पश्चिम रेलवे द्वारा उपरोक्त संदर्भ (iii) में दिए गए ब्लॉक एवं टेलिकॉम सर्किटों topographical map में इंकित नहीं होने के कारण प्रेरित वोल्टेज गणना संभव नहीं है। रक्षा प्राधिकरण से दूरसंचार विवरण लंबित हैं और बिजली प्राधिकरण ने लाइन की चार्जिंग के लिए तत्कालता दिखाई है।

उपरोक्त को देखते हुए के लिए विषयांकित प्रस्तावों के लिए अनंतिम पीटीसीसी अप्रूवल जारी करने के संबंध में आवश्यक कार्रवाई की जाए।

संलग्न: ऊपरोक्त अनुसार

सचिव
निदेशक 24.03.22

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi-110001.	
2.	Dy. CSTE (Tele)	North Western Railway, Head Quarter Office, Room no. 136, First Floor, Near Jawahar Circle, Jaipur – 302017	With a request to send telecom details marked on topo map urgently so that IV calculations can be carried out
3.	M/s NTPC	Sambhu ki Bhurj, Solar Project, Vill: Nokhra/Tokla, Tehsil: Kolayat, Bikaner, Rajasthan – 334004	With a request to coordinate with NWR to expedite in forwarding telecom details to CEA



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

CEA Case No. : RAJ-701&702 / 294-296
PTCC proposal of 400 kV S/C transmission line on D/C towers of M/s NTPC from (i) CPSU1 400/33 kV PSS of M/s NTPC to PGCIL 765/400/220 kV GSS Bhadla – II (26.311 km) (ii) CPSU2 400/33 kV PSS of M/s NTPC to CPSU1 400/33 kV PSS of M/s NTPC at Nokhra, Bikaner, Rajasthan (1.675 km)

Reference:		
S. No.	Reference No.	Dated
(i)	NTPC: SKB/CPSU—I&II/21-22/39	28.02.2022
(ii)	BSNL: DET/PTCC/ND/DV-10059/UTR-36/2021-2022	23.03.2022
(iii)	North Western Railway: SG/158/NWR/PTCC/885	23.03.2022

The PTCC proposal submitted vide reference (i) has been examined. Vide reference (ii), BSNL has conveyed its No Objection Certificate (NOC). The block & telecom circuit details provided by North Western Railway vide above reference (iii) is not visible on topographical map due to which Induced Voltage calculation could not be done. Telecommunication details from Defense are pending and the power authority has shown urgency for the charging of the line.

In view of the above, take necessary action regarding issuance of **provisional PTCC approval for the subject proposal.**

Encl.: As above.

राष्ट्रीय विद्युत प्राधिकरण
 Director 24.03.22

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi-110001.	
2.	Dy. CSTE (Tele)	North Western Railway, Head Quarter Office, Room no. 136, First Floor, Near Jawahar Circle, Jaipur – 302017	With a request to send telecom details marked on topo map urgently so that IV calculations can be carried out
3.	M/s NTPC	Sambhu ki Bhurj, Solar Project, Vill: Nokhra/Tokla, Tehsil: Kolayat, Bikaner, Rajasthan – 334004	With a request to coordinate with NWR to expedite in forwarding telecom details to CEA