



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

के.वि.प्रा. केस सं. : RAJ-683 / 252 - 253
पी.टी.सी.सी. प्रस्ताव 220 kV S/C line on D/C & M/C tower from 150 MW & 90 MW NTPC Ltd Solar Power Plant at Devikot, Jaisalmer to 220 kV bay of Fatehgarh-II PGCIL GSS (3.8 km)

सन्दर्भ:		
क्रमांक	सन्दर्भ सं.	दिनांक
(i)	M/s NTPC Ltd: NTPC/Devikot/21-22/78	13.11.2021
(ii)	BSNL: DET/PTCC/ND/DV-10045/Raj-1360/2021-2022/	08.02.2022
(iii)	North Western Railway: SG/158/NWR/PTCC/857	23.11.2021
(iv)	Defense: B/46947/Sigs 7(b)/2668	01.02.2022

संदर्भ (i) द्वारा प्रस्तुत पीटीसीसी प्रस्ताव की जांच की गई है। बीएसएनएल ने उपरोक्त संदर्भ (ii) के द्वारा अवगत कराया है कि पावर लाइन एवं उपकेन्द्र के 8 कि.मी. परिधि में कोई बीएसएनएल लाइन अथवा एक्सचेंज नहीं है तथा अनापत्ति प्रमाण पत्र जारी किया है। उत्तर पश्चिम रेलवे ने उपरोक्त संदर्भ (iii) द्वारा अवगत कराया है कि प्रस्तावित पावर लाइन की 8 कि.मी परिधि में कोई रेलवे ट्रैक नहीं है। रक्षा प्राधिकरण ने उपरोक्त संदर्भ (iv) के द्वारा अनापत्ति प्रमाण पत्र जारी किया है।

उपरोक्त को ध्यान में रखते हुए, पीटीसीसी मार्ग अनुमोदन जारी करने के संबंध में आवश्यक कार्रवाई की जाए।

संलग्न: ऊपरोक्त अनुसार

राजेश कुमार प्रसाद सिंह
12.04.22
निदेशक

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/c PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001.	
2.	Head of Projects	M/s NTPC Ltd, 240MW Devikot Solar Project, Plot no. 553, KL Achalvanshi Colony, Jaisalmer, Rajasthan - 345001	For kind information

File No.CEA-PS-17-11(11)/7/2022-PCD Division



भारत सरकार
Government of India
विद्युत मंत्रालय
Ministry of Power
केन्द्रीय विद्युत प्राधिकरण
Central Electricity Authority
विद्युत संचार विकास प्रभाग
Power Communication Development Division

CEA Case No. : RAJ-683 / 252 - 253
PTCC proposal of 220 kV S/C line on D/C & M/C tower from 150 MW & 90 MW NTPC Ltd Solar Power Plant at Devikot, Jaisalmer to 220 kV bay of Fatehgarh-II PGCIL GSS (3.8 km)

Reference:		
S. No.	Reference No.	Dated
(i)	M/s NTPC Ltd: NTPC/Devikot/21-22/78	13.11.2021
(ii)	BSNL: DET/PTCC/ND/DV-10645/Raj-1360/2021-2022/	08.02.2022
(iii)	North Western Railway: SG/158/NWR/PTCC/857	23.11.2021
(iv)	Defense: B/46947/Sigs 7(b)/2668	01.02.2022

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide above reference (ii) has intimated that there are no BSNL lines (copper cable and armored OFC) and exchanges within 8 km boundary of substations and line and conveyed its NOC (North Western Railway vide above reference (iii) has conveyed that there is no railway track within the vicinity of 8 km from the proposed power line. Vide reference (iv) above, The Defence Authority have issued No Objection Certificate (NOC).

Taking above into consideration, necessary action regarding issuance of PTCC route approval may be taken.

Encl.: As above.

राघवेंद्र कुमार सिंह
Director 12.04.22

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001	
2.	Head of Projects	M/s NTPC Ltd, 240MW Devikot Solar Project, Plot no. 553, KL Achalvanshi Colony, Jaisalmer, Rajasthan - 345001	For kind information