



भारत सरकार Government of India विद्युत मंत्रालय Ministry of Power केन्द्रीय विद्युत प्राधिकरण Central Electricity Authority विद्युत संचार विकास प्रभाग

Power Communication Development Division

CEA Case No.: UP-583 / 2 6 0 - 2 6 2

PTCC proposal of LILO of 220 kV D/C Moradabad (400 kV) - Rampur (220 kV) line at Rampur (765 kV) (8.390 km)

S. No.	Reference No.		
(i)	UPPTCL: 1230/ETD/Rampur	Dated	
(ii)	BSNL: DET/PTCC/ND/DV-9036/LID 001/2004	24.07.202	
(iii)	1 - Orthorn Railway: 34/-SIG/1/DTCC/2021 22/	03.03.2022	
(iv)_	Defense: B/46947/Sigs 7(b)/2562	02.09.2021	
	83 / (0)/2502	25.10.2021	

The PTCC proposal submitted vide reference (i) has been examined. BSNL, vide above reference (ii), has conveyed its No Objection Certificate (NOC). The LF induction on Block & Telecom circuits of Northern Railway with respect to details furnished vide above reference (iii) has been computed. The voltages likely to be induced on paralleling Block & Telecom circuits of Northern Railway under Single Line to Ground fault condition are enclosed at Annexure-I. The screening factors, as applicable, have been considered. Vide reference (iv) above, The Defence Authority have issued No Objection Certificate (NOC). (a

Taking above into consideration, necessary action regarding issuance of PTCC route approval may be taken.

Encl.: As above.

Director 12.04.22

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001.	
2.	AESTE/UTS	Northern Railway, Headquarter Office, Baroda House, New Delhi	Only
3.	Executive Engineer	UPPTCL, Electricity Transmission Division, Rampur (U.P.)	Annexure-I Copy for information

File No.CEA-PS-17-11(11)/23/2022-PCD Division





भारत सरकार **Government of India** विद्युत मंत्रालय **Ministry of Power** केन्द्रीय विद्युत प्राधिकरण **Central Electricity Authority** विद्युत संचार विकास प्रभाग

Power Communication Development Division

के.वि.प्रा. केस सं. : UP-583 | 266 - 262 पी.टी.सी. प्रस्ताव LILO of 220 kV D/C Moradabad (400 kV) – Rampur (220 kV) line at Rampur (765 kV) (8.390 km)

सन्दर्भ:		
क्रमांक	सन्दर्भ सं.	दिनांक
(i)	UPPTCL: 1230/ETD/Rampur	24.07.2021
(ii)	BSNL: DET/PTCC/ND/DV-9936/UP-981/2021-2022	03.03.2022
(iii)	Northern Railway: 342-SIG/1/PTCC/2021-22/09/02	02.09.2021
(iv)	Defense: B/46947/Sigs 7(b)/2562	25.10.2021

संदर्भ (i) द्वारा प्रस्तुत पीटीसीसी प्रस्ताव की जांच की गई है। बीएसएनएल ने उपरोक्त सन्दर्भ (ii) के द्वारा अनापत्ति प्रमाण पत्र जारी किया है। उत्तर रेलवे के ब्लॉक और टेलीकॉम सर्किट पर निम्न आवृत्ति प्रेरण गणना उपरोक्त संदर्भ (iii) में दिए गए विवरणों के संबंध में की गई है। सिंगल लाइन टू ग्राउंड फाल्ट अवस्था में समानांतर उत्तर रेलवे के ब्लॉक और टेलीकॉम सर्किट पर प्रेरित वोल्टेज अनुलग्नक-। में संलग्न है। स्क्रीनिंग कारक का मान यथानुरूप लिया गया है। रक्षा प्राधिकरण ने उपरोक्त सन्दर्भ (iv) के द्वारा अनापति प्रमाण पत्र जारी किया है। (अनुलग्नक- ॥। में संलग्न)।

उपरोक्त को ध्यान में रखते हुए, पीटीसीसी मार्ग अनुमोदन जारी करने के संबंध में आवश्यक कार्रवाई

की जाएं।

संलग्न: ऊपरोक्त अनुसार

To,			
	Divisional	BSNL O/o PGM (N), QA & Inspection Circle,	
1.	Engineer (PTCC),	D-Tax Building, Eastern Court, Janpath, New	
	Northern Zone	Delhi 110001.	
		Northern Railway, Headquarter Office, Baroda	Only
2.	AESTE/UTS	House, New Delhi	Annexure-I
	Executive	UPPTCL, Electricity Transmission Division,	Copy for
3.	Engineer	Rampur (U.P.)	information

ANNEXURE-I

Effective

Fault

current

in Amps.

I.V

in

Volts.

CEA Case No.: UP-583

S.No.

Name of the Power line: LILO of 220 kV D/C Moradabad (400 $\,$

Telecom. Details

kV) - Rampur (220 kV) line at Rampur (765 kV)

Map Scale : 1 cm=500 mTotal Length: 8.390 km S.R. Value: $20,000 \Omega$ -cm

Mutual

Coupling

in Ohms.

	MODTHEDAY			L	
	NORTHERN RAILWAY Ref. No: 342-S Affected Blocks &	SIG/1/PTCC/2 Felecom Circ	021-22/09/02 Dauits Details	ated: 02.09.202	
1	Rampur R/S – Shahzadnagar R/S	Out of parallelism		m	0
2	Shahzadnagar R/S – Dhamora R/s	0.9	0.0014	10000	14
3	Dhamora R/s – Duganpur R/S	3.8	0.0019	8500	16
5	Duganpur R/S – Milak R/S	1.8	0.0003	8200	2
	Milak R/S – Nagaria Sadat R/S	(Out of parallelism	n	

Length of

Parallelism

in Km.

प्रतीक श्रीवास्त्रव/PRATEEK SRIVASTAVA प्रताक श्रवास्तव/PRAILEK SRIVASTAVA राज्ञयक निदेशक-II/Assti. Director-II केन्द्रीय विद्युत प्राधिकरण/C.E.A. विद्युत मंत्रालय/Ministry of Power भारत सरकार/Govt. of India गर्स मिक्सी/Mean Pow'H Tele: 23019746

Annex-II UP-583

Directorate General of Signals Signals 7 General Staff Branch Integrated HQ of MoD, (Army) DHQ PO, New Delhi – 110011

JK Oct 2021

B/46937/Sigs 7(b)/2562/

Office of the Executive Engineer
Electricity Transmission Division
U.P. Power Transmission Corporation Limited
Rampur 244901

PTCC CLEARANCE FOR 220KV MORADABAD (400)- RAMPUR (220) LILO AT 765KV RAMPUR D/C TRANSMISSION LINE OF UPPTCL

- 1. Refer your letter No 1230/ETD/Rampur dt 24 Jul 2021 (copy att).
- 2. No Objection Certificate (NOC) is accorded based on inputs provided as per Map sheet received under your letter mentioned above.
- 3. Documents alongwith map sheets (in original) are returned herewith for your further necessary action.

(A Rawat) Lt Col GSO 1 (Comn) for SO-in-C

Enclosures : As above

Copy to :-

Phe Director (PTCC), CEA
Power Communication Development Division
NRPC Complex, 18-A Shaheed Jeet Singh Marg
Katwaria Sarai, New Delhi – 110016

for information

The DET(PTCC), Northern Zone O/o PGM (North), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath New Delhi-110001



· 82. Tamy