



7-2022  
जासलमेर  
अभूत महीलम

भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
केन्द्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
विद्युत संचार विकास प्रभाग  
Power Communication Development Division

\*\*\*\*\*

CEA Case No. : RAJ-688 / 394 - 395
PTCC proposal of 220 kV S/C line on M/C towers for 10 km and S/C line on D/C towers for approx. 6 km from Fatehgarh – II PGCIL GSS to 180 MW Solar PSS of M/s SBE Renewable Sixteen Pvt Ltd in Jaisalmer, Rajasthan (15.8 km)

Reference:		
S. No.	Reference No.	Dated
(i)	M/s SBE Renewable Sixteen Pvt Ltd: AGL/JSM/450 MW/21/01	06.10.2021
(ii)	BSNL: DET/PTCC/ND/DV-10070/Raj-1375/2022-2023/	27.04.2022
(iii)	North Western Railway: SG/158/NWR/PTCC/856	16.11.2021
(iv)	Defense: B/46937/Sigs 7(b)/2652	01.02.2022

The PTCC proposal submitted vide reference (i) has been examined. BSNL vide above reference (ii) has intimated that there are no BSNL lines (copper cable and armored OFC) in the route of the proposed power line and conveyed its NOC. North Western Railway vide above reference (iii) has intimated that there is no railway track within the vicinity of 8 km from the proposed power line. The Defence Authority, vide above reference (iv) have issued No Objection Certificate (NOC).

Taking above into consideration, as there is no protection required, PTCC route approval may be issued at the earliest to avoid any charging delays.

डा. अ. व. ड. अ. व. ड. 143  
09.05.22  
Director

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001.	For n.a.
2.	Associate General Manager	M/s SBE Renewables Sixteen Private Ltd, 1 <sup>st</sup> floor, Worldmark-2, Asset Area-8, Hospitality District, Aerocity, NH-8, Delhi - 110037	For kind information

OTC



75  
असतो मा सद्गमय  
असतो मा सद्गमय

भारत सरकार  
Government of India  
विद्युत मंत्रालय  
Ministry of Power  
केन्द्रीय विद्युत प्राधिकरण  
Central Electricity Authority  
विद्युत संचार विकास प्रभाग  
Power Communication Development Division  
\*\*\*\*\*

के.वि.प्रा. केस सं. : RAJ-688 / 394-395
पी.टी.सी.सी. प्रस्ताव 220 kV S/C line on M/C towers for 10 km and S/C line on D/C towers for approx. 6 km from Fatehgarh - II PGCIL GSS to 180 MW Solar PSS of M/s SBE Renewable Sixteen Pvt Ltd in Jaisalmer, Rajasthan (15.8 km)

सन्दर्भ:		
क्रमांक	सन्दर्भ सं.	दिनांक
(i)	M/s SBE Renewable Sixteen Pvt Ltd: AGL/JSM/450/MW/21/01	06.10.2021
(ii)	BSNL: DET/PTCC/ND/DV-10070/Raj-1375/2022-2023/	27.04.2022
(iii)	North Western Railway: SG/158/NWR/PTCC/856	16.11.2021
(iv)	Défense: B/46937/Sigs 7(b)/2652	01.02.2022

सन्दर्भ (i) द्वारा प्रस्तुत पीटीसीसी प्रस्ताव की जांच की गई है। बीएसएनएल ने उपरोक्त सन्दर्भ (ii) के द्वारा अवगत कराया है कि पावर लाइन के परिधि में कोई बीएसएनएल लाइन नहीं है तथा अनापत्ति प्रमाण पत्र जारी किया है। उत्तर पश्चिम रेल ने उपरोक्त सन्दर्भ (iii) के द्वारा अवगत कराया है कि पावर लाइन के 8 कि.मी. परिधि में कोई रेलवे ट्रैक नहीं है। रक्षा प्राधिकरण ने उपरोक्त सन्दर्भ (iv) के द्वारा अनापत्ति प्रमाण पत्र जारी किया है।

उपरोक्त को ध्यान में रखते हुए, चूंकि पीटीसीसी सुरक्षा की आवश्यकता नहीं है, चार्जिंग में विलम्ब से बचने के लिए पीटीसीसी मार्ग अनुमोदन जल्द से जल्द जारी किया जाए।

31/05/22  
09.05.22  
निदेशक

To,

1.	Divisional Engineer (PTCC), Northern Zone	BSNL O/o PGM (N), QA & Inspection Circle, D-Tax Building, Eastern Court, Janpath, New Delhi 110001.	For n.a.
2.	Associate General Manager	M/s SBE Renewables Sixteen Private Ltd, 1 <sup>st</sup> floor, Worldmark-2, Asset Area-8, Hospitality District, Acrocity, NH-8, Delhi - 110037	For kind information